

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes.
 - .1 Methods and procedures for start-up, verification and commissioning, for building Energy Monitoring and Control System (EMCS) and includes:
 - .1 Start-up testing and verification of systems.
 - .2 Check out demonstration or proper operation of components.
 - .3 On-site operational tests.
 - .2 Related Sections.
 - .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 01 78 00 - Closeout Submittals.
 - .3 Section 01 91 13 - General Commissioning (Cx) Requirements.
 - .4 Section 01 79 00 - Demonstration and Training.
 - .5 Section 25 05 01 - EMCS: General Requirements.

1.2 DEFINITIONS

- .1 For additional acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.
- .2 AEL: ratio between total test period less any system downtime accumulated within that period and test period.
- .3 Downtime: results whenever EMCS is unable to fulfill required functions due to malfunction of equipment defined under responsibility of EMCS contractor. Downtime is measured by duration, in time, between time that Contractor is notified of failure and time system is restored to proper operating condition. Downtime not to include following:
 - .1 Outage of main power supply in excess of back-up power sources, provided that:
 - .1 Automatic initiation of back-up was accomplished.
 - .2 Automatic shut-down and re-start of components was as specified.
 - .2 Failure of communications link, provided that:
 - .1 Controller automatically and correctly operated in stand-alone mode.
 - .2 Failure was not due to failure of any specified EMCS equipment.

1.2 DEFINITIONS
(Cont'd)

- .3 (Cont'd)
 - .2 (Cont'd)
 - .3 Functional failure resulting from individual sensor inputs or output devices, provided that:
 - .1 System recorded said fault.
 - .2 Equipment defaulted to fail-safe mode.
 - .3 AEL of total of all input sensors and output devices is at least 90% during test period.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Final Report: submit report to Departmental Representative.
 - .1 Include measurements, final settings and certified test results.
 - .2 Report format to be approved by Departmental Representative before commissioning is started.
 - .3 Revise "as-built" documentation, commissioning reports to reflect changes, adjustments and modifications to EMCS as set during commissioning and submit to Departmental Representative in accordance with Section 01 78 00 - Closeout Submittals.
 - .4 Recommend additional changes and/or modifications deemed advisable in order to improve performance, environmental conditions or energy consumption.

1.4 CLOSEOUT
SUBMITTALS

- .1 Provide documentation, O&M Manuals, and training of O&M personnel for review of Departmental Representative before interim acceptance in accordance with Section 01 78 00 - Closeout Submittals.

1.5 COMMISSIONING

- .1 Do commissioning in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements.
- .2 Carry out commissioning under direction of Departmental Representative and in presence of Departmental Representative.

1.5 COMMISSIONING
(Cont'd)

- .3 Inform, and obtain approval from, Departmental Representative in writing at least 14 days prior to commissioning or each test. Indicate:
 - .1 Location and part of system to be tested or commissioned.
 - .2 Testing/commissioning procedures, anticipated results.
 - .3 Names of testing/commissioning personnel.
- .4 Correct deficiencies, re-test in presence of Departmental Representative until satisfactory performance is obtained.
- .5 Acceptance of tests will not relieve Contractor from responsibility for ensuring that complete systems meet every requirement of Contract.
- .6 Load system with project software.
- .7 Perform tests as required.

1.6 COMPLETION OF
COMMISSIONING

- .1 Commissioning to be considered as satisfactorily completed when objectives of commissioning have been achieved and reviewed by Departmental Representative.

1.7 ISSUANCE OF
FINAL CERTIFICATE
OF COMPLETION

- .1 Final Certificate of Completion will not be issued until receipt of written approval indicating successful completion of specified commissioning activities including receipt of commissioning documentation.

PART 2 - PRODUCTS

2.1 EQUIPMENT

- .1 Provide sufficient instrumentation to verify and commission the installed system. Provide two-way radios.
- .2 Instrumentation accuracy tolerances : higher order of magnitude than equipment or system being tested.
- .3 Independent testing laboratory to certify test equipment as accurate to within approved tolerances no more than 2 months prior to tests.

2.1 EQUIPMENT
(Cont'd)

- .4 Locations to be approved, readily accessible and readable.
- .5 Application: to conform to normal industry standards.

PART 3 - EXECUTION

3.1 PROCEDURES

- .1 Test each system independently and then in unison with other related systems.
- .2 Commission each system using procedures prescribed by the Departmental Representative.
- .3 Commission integrated systems using procedures prescribed by Departmental Representative.
- .4 Debug system software.
- .5 Optimize operation and performance of systems by fine-tuning PID values and modifying CDLs as required.
- .6 Test full scale emergency evacuation and life safety procedures including operation and integrity of smoke management systems under normal and emergency power conditions as applicable.

3.2 FIELD QUALITY
CONTROL

- .1 Pre-Installation Testing.
 - .1 General: consists of field tests of equipment just prior to installation.
 - .2 Testing may be on site or at Contractor's premises as approved by Departmental Representative.
 - .3 Configure major components to be tested in same architecture as designed system. Include BECC equipment and 2 sets of Building Controller's including MCU's, LCU's, and TCU's.
 - .4 Equip each Building Controller with sensor and controlled device of each type (AI, AO, DI, DO).
 - .5 After setting, test zero and span in 10 % increments through entire range while both increasing and decreasing pressure.
 - .6 Departmental Representative to mark instruments tracking within 0.5 % in both directions as "approved for installation".

3.2 FIELD QUALITY .1
CONTROL
(Cont'd)

(Cont'd)

.7 Transmitters above 0.5 % error will be rejected.

.8 DP switches to open and close within 2% of setpoint.

.2 Completion Testing.

.1 General: test after installation of each part of system and after completion of mechanical and electrical hook-ups, to verify correct installation and functioning.

.2 Include following activities:

.1 Test and calibrate field hardware including stand-alone capability of each controller.

.2 Verify each A-to-D convertor.

.3 Test and calibrate each AI using calibrated digital instruments.

.4 Test each DI to ensure proper settings and switching contacts.

.5 Test each DO to ensure proper operation and lag time.

.6 Test each AO to ensure proper operation of controlled devices. Verify tight closure and signals.

.7 Test operating software.

.8 Test application software and provide samples of logs and commands.

.9 Verify each CDL including energy optimization programs.

.10 Debug software.

.11 Provide point verification list in table format including point identifier, point identifier expansion, point type and address, low and high limits and engineering units. Include space on commissioning technician and Departmental Representative. This document will be used in final startup testing.

.3 Final Startup Testing: Upon satisfactory completion of tests, perform point-by-point test of entire system under direction of Departmental Representative and provide:

.1 1 technical personnel capable of re-calibrating field hardware and modifying software.

.2 Detailed daily schedule showing items to be tested and personnel available.

.3 Departmental Representative's acceptance signature to be on executive and applications programs.

.4 Commissioning to commence during final startup testing.

3.2 FIELD QUALITY CONTROL
(Cont'd)

.2 (Cont'd)

.3 (Cont'd)

.5 O&M personnel to assist in commissioning procedures as part of training.

.6 Commissioning to be supervised by qualified supervisory personnel and Departmental Representative.

.7 Commission systems considered as life safety systems before affected parts of the facility are occupied.

.8 Operate systems as long as necessary to commission entire project.

.9 Monitor progress and keep detailed records of activities and results.

3.3 ADJUSTING

.1 Final adjusting: upon completion of commissioning as reviewed by Departmental Representative, set and lock devices in final position and permanently mark settings.

3.4 DEMONSTRATION

.1 Demonstrate to Departmental Representative operation of systems including sequence of operations in regular and emergency modes, under normal and emergency conditions, start-up, shut-down interlocks and lock-outs in accordance with Section 01 79 00 - Demonstration and Training.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes.
 - .1 Requirements and procedures for training program, instructors and training materials, for building Energy Monitoring and Control System (EMCS) Work.
- .2 Related Sections.
 - .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 25 05 01 - EMCS: General Requirements.

1.2 DEFINITIONS

- .1 CDL - Control Description Logic.
- .2 For additional acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures, supplemented and modified by requirements of this Section.
- .2 Submit training proposal complete with hour-by-hour schedule including brief overview of content of each segment to Departmental Representative 30 days prior to anticipated date of beginning of training.
 - .1 List name of trainer, and type of visual and audio aids to be used.
 - .2 Show co-ordinated interface with other EMCS mechanical and electrical training programs.
- .3 Submit reports within one week after completion of training program that training has been satisfactorily completed.

1.4 QUALITY ASSURANCE

- .1 Provide competent instructors thoroughly familiar with aspects of EMCS installed in facility.

- | | | |
|-----------------------------------|----|--|
| <u>1.5 INSTRUCTIONS</u> | .1 | Provide instruction to designated personnel in adjustment, operation, maintenance and pertinent safety requirements of EMCS installed. |
| | .2 | Training to be project-specific. |
| | | |
| <u>1.6 TIME FOR INSTRUCTION</u> | .1 | Number of days of instruction to be as specified in this section (1 day = 8 hours including two 15 minute breaks and excluding lunch time). |
| | | |
| <u>1.7 TRAINING MATERIALS</u> | .1 | Supply manual for each trainee, describing in detail data included in each training program.
.1 Review contents of manual in detail to explain aspects of operation and maintenance (O&M) . |
| | | |
| <u>1.8 TRAINING PROGRAM</u> | .1 | Train O&M personnel in functional operations and procedures to be employed for system operation.
.1 Include overview of system architecture, communications, operation of computer and peripherals, report generation.
.2 Include detailed training on operator interface functions for control of mechanical systems, CDL's for each system, and elementary preventive maintenance. |
| | | |
| <u>1.9 MONITORING OF TRAINING</u> | .1 | Departmental Representative to monitor training program and may modify schedule and content. |

PART 2 - PRODUCTS

- | | | |
|---------------------|----|-----------|
| <u>2.1 NOT USED</u> | .1 | Not Used. |
|---------------------|----|-----------|

PART 3 - EXECUTION

- | | | |
|---------------------|----|-----------|
| <u>3.1 NOT USED</u> | .1 | Not Used. |
|---------------------|----|-----------|

PART 1 - GENERAL

- 1.1 SUMMARY
- .1 Related Sections:
 - .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 09 91 99 - Painting for Minor Works.
 - .3 Section 25 05 54 - EMCS: Identification.
 - .4 Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation.
- 1.2 REFERENCES
- .1 American National Standards Institute (ANSI)/The Instrumentation, Systems and Automation Society (ISA).
 - .1 ANSI/ISA 5.5-1985, Graphic Symbols for Process Displays.
 - .2 American National Standards Institute (ANSI)/ Institute of Electrical and Electronics Engineers (IEEE).
 - .1 ANSI/IEEE 260.1-1993, American National Standard Letter Symbols Units of Measurement (SI Units, Customary Inch-Pound Units, and Certain Other Units).
 - .3 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
 - .1 ASHRAE STD 135-R2001, BACNET - Data Communication Protocol for Building Automation and Control Network.
 - .4 Canadian Standards Association (CSA International).
 - .1 CAN/CSA-Z234.1-89(R1995), Canadian Metric Practice Guide.
 - .5 Consumer Electronics Association (CEA).
 - .1 CEA-709.1-B-2002, Control Network Protocol Specification.
 - .6 Department of Justice Canada (Jus).
 - .1 Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
 - .2 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .7 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
-

1.2 REFERENCES

(Cont'd)

- .8 Transport Canada (TC).
.1 Transportation of Dangerous Goods Act
(TDGA), 1992, c. 34.

1.3 ACRONYMS AND ABBREVIATIONS

- .1 Acronyms used in EMCS:
.1 AEL - Average Effectiveness Level.
.2 AI - Analog Input.
.3 AIT - Agreement on International Trade.
.4 AO - Analog Output.
.5 BACnet - Building Automation and
Control Network.
.6 BC(s) - Building Controller(s).
.7 BECC - Building Environmental Control
Center.
.8 CAD - Computer Aided Design.
.9 CDL - Control Description Logic.
.10 CDS - Control Design Schematic.
.11 COSV - Change of State or Value.
.12 CPU - Central Processing Unit.
.13 DI - Digital Input.
.14 DO - Digital Output.
.15 DP - Differential Pressure.
.16 ECU - Equipment Control Unit.
.17 EMCS - Energy Monitoring and Control
System.
.18 HVAC - Heating, Ventilation, Air
Conditioning.
.19 IDE - Interface Device Equipment.
.20 I/O - Input/Output.
.21 ISA - Industry Standard Architecture.
.22 LAN - Local Area Network.
.23 LCU - Local Control Unit.
.24 MCU - Master Control Unit.
.25 NAFTA - North American Free Trade
Agreement.
.26 NC - Normally Closed.
.27 NO - Normally Open.
.28 OS - Operating System.
.29 O&M - Operation and Maintenance.
.30 OWS - Operator Work Station.
.31 PC - Personal Computer.
.32 PCI - Peripheral Control Interface.
.33 PCMCIA - Personal Computer Micro-Card
Interface Adapter.
.34 PID - Proportional, Integral and
Derivative.
.35 RAM - Random Access Memory.
.36 SP - Static Pressure.
.37 ROM - Read Only Memory.
.38 TCU - Terminal Control Unit.
.39 USB - Universal Serial Bus.
.40 UPS - Uninterruptible Power Supply.
.41 VAV - Variable Air Volume.

1.4 DEFINITIONS

- .1 Point: may be logical or physical.
 - .1 Logical points: values calculated by system such as setpoints, totals, counts, derived corrections and may include, but not limited to result of and statements in CDL's.
 - .2 Physical points: inputs or outputs which have hardware wired to controllers which are measuring physical properties, or providing status conditions of contacts or relays which provide interaction with related equipment (stop, start) and valve or damper actuators.
- .2 Point Name: composed of two parts, point identifier and point expansion.
 - .1 Point identifier: comprised of three descriptors, "area" descriptor, "system" descriptor and "point" descriptor, for which database to provide 25 character field for each point identifier. "System" is system that point is located on.
 - .1 Area descriptor: building or part of building where point is located.
 - .2 System descriptor: system that point is located on.
 - .3 Point descriptor: physical or logical point description. For point identifier "area", "system" and "point" will be shortforms or acronyms. Database must provide 25 character field for each point identifier.
 - .2 Point expansion : comprised of three fields, one for each descriptor. Expanded form of shortform or acronym used in "area", "system" and "point" descriptors is placed into appropriate point expansion field. Database must provide 32 character field for each point expansion.
 - .3 Bilingual systems to include additional point identifier expansion fields of equal capacity for each point name for second language.
 - .1 System to support use of numbers and readable characters including blanks, periods or underscores to enhance user readability for each of the above strings.
- .3 Point Object Type: points fall into following object types:
 - .1 AI (analog input).
 - .2 AO (analog output).
 - .3 DI (digital input).
 - .4 DO (digital output).
 - .5 Pulse inputs.

1.4 DEFINITIONS
(Cont'd)

- .4 Symbols and engineering unit abbreviations utilized in displays: to ANSI/ISA S5.5.
 - .1 Printouts: to ANSI/IEEE 260.1.
 - .2 Refer also to Section 25 05 54 - EMCS: Identification.

1.5 SYSTEM
DESCRIPTION

- .1 Refer to control schematics for system architecture.
- .2 Work covered by sections referred to above consists of fully operational EMCS, including, but not limited to, following:
 - .1 Building Controllers.
 - .2 Control devices as listed in I/O point summary tables.
 - .3 Data communications equipment necessary to effect EMCS data transmission system.
 - .4 Field control devices.
 - .5 Software/Hardware complete with full documentation.
 - .6 Complete operating and maintenance manuals.
 - .7 Training of personnel.
 - .8 Acceptance tests, technical support during commissioning, full documentation.
 - .9 Wiring interface co-ordination of equipment supplied by others.
 - .10 Miscellaneous work as specified in these sections and as indicated.
- .3 Design Requirements:
 - .1 Design and provide conduit and wiring linking elements of system.
 - .2 Supply sufficient programmable controllers of types to meet project requirements. Quantity and points contents as reviewed by Departmental Representative prior to installation.
 - .3 Location of controllers as reviewed by Departmental Representative prior to installation.
 - .4 Provide utility power to EMCS.
 - .5 Metric references: in accordance with CAN/CSA Z234.1.
- .4 Language Operating Requirements:
 - .1 Provide English operator selectable access codes.
 - .2 Use non-linguistic symbols for displays on graphic terminals wherever possible. Other information to be in English and French.

1.5 SYSTEM
DESCRIPTION
(Cont'd)

- .4 (Cont'd)
 - .3 Operating system executive: provide primary hardware-to-software interface with associated documentation to be in English.
 - .4 System manager software: include in English system definition point database, additions, deletions or modifications, control loop statements, use of high level programming languages, report generator utility and other OS utilities used for maintaining optimal operating efficiency.
 - .5 Include, in English:
 - .1 Input and output commands and messages from operator-initiated functions and field related changes as defined in CDL's or assigned limits (i.e. commands relating to day-to-day operating functions and not related to system modifications, additions, or logic re-definitions).
 - .2 Graphic "display" functions, point commands to turn systems on or off, manually override automatic control of specified hardware points.
 - .3 Reporting function such as trend log, trend graphics, alarm report logs, energy report logs, maintenance generated logs.

1.6 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit for review:
 - .1 Equipment list and systems manufacturers within 48 h after award of contract.
 - .3 Quality Control:
 - .1 Provide equipment and material from manufacturer's regular production, CSA certified, manufactured to standard quoted plus additional specified requirements.
 - .2 Where CSA certified equipment is not available submit such equipment to inspection authorities for special inspection and approval before delivery to site.
 - .3 Submit proof of compliance to specified standards with shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures. Label or listing of specified organization is acceptable evidence.
-

1.6 SUBMITTALS
(Cont'd)

- .3 (Cont'd)
- .4 In lieu of such evidence, submit certificate from testing organization, approved by Departmental Representative certifying that item was tested in accordance with their test methods and that item conforms to their standard/code.
- .5 For materials whose compliance with organizational standards/codes/specifications is not regulated by organization using its own listing or label as proof of compliance, furnish certificate stating that material complies with applicable referenced standard or specification.
- .6 Permits and fees: in accordance with general conditions of contract.
- .7 Submit certificate of acceptance from authority having jurisdiction to Departmental Representative.

1.7 QUALITY
ASSURANCE

- .1 Have local office within New Brunswick staffed by trained personnel capable of providing instruction, routine maintenance and emergency service on systems,
- .2 Have access to local supplies of essential parts and provide 7 year guarantee of availability of spare parts after obsolescence.
- .3 Ensure qualified supervisory personnel continuously direct and monitor Work and attend site meetings.
- .4 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

PART 3 - EXECUTION

2.1 MANUFACTURER'S
RECOMMENDATIONS

- .1 Installation: to manufacturer's recommendations.

2.2 PAINTING

- .1 Painting: in accordance with Section 09 91 99 - Painting for Minor Works, supplemented as follows:
- .1 Clean and touch up marred or scratched surfaces of factory finished equipment to match original finish.
 - .2 Restore to new condition, finished surfaces too extensively damaged to be primed and touched up to make good.
 - .3 Clean and prime exposed hangers, racks, fastenings, and other support components.
 - .4 Paint unfinished equipment installed indoors to EEMAC 2Y-1.

PART 1 - GENERAL

- 1.1 SUMMARY .1 Section Includes.
- .1 Methods and procedures for shop drawings submittals, preliminary and detailed review process including review meetings, for building Energy Monitoring and Control System (EMCS).
- .2 Related Sections.
- .1 Section 01 33 00 - Submittal Procedures.
 - .2 Section 25 05 01 - EMCS: General Requirements.
 - .3 Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.
- 1.2 DEFINITIONS .1 Acronyms and definitions: refer to Section 25 05 01 - EMCS: General Requirements.
- 1.3 SUBMITTALS .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures and coordinate with requirements in this Section.
- 1.4 DETAIL SHOP DRAWING REVIEW .1 Submit detailed shop drawings within 60 working days after award of contract and before start of installation and include following:
- .1 Wiring diagrams.
 - .2 Piping diagrams and hook-ups.
 - .3 Interface wiring diagrams showing termination connections and signal levels for equipment to be supplied by others.
 - .4 Shop drawings for each input/output point, sensors, transmitters, showing information associated with each particular point including:
 - .1 Sensing element type and location.
 - .2 Transmitter type and range.
 - .3 Associated field wiring schematics, schedules and terminations.
 - .4 Complete Point Name Lists.
 - .5 Setpoints, curves or graphs and alarm limits (high and low, 3 types critical, cautionary and maintenance), signal range.

2016-02-19

- | | |
|--|--|
| <u>1.4 DETAIL SHOP
DRAWING REVIEW
(Cont'd)</u> | .1 (Cont'd)
.4 (Cont'd)
.6 Software and programming details associated with each point.
.7 Manufacturer's recommended installation instructions and procedures.
.8 Input and output signal levels or pressures where new system ties into existing control equipment.
.5 Control schematics, narrative description, CDL's fully showing and describing automatic and manual procedure required to achieve proper operation of project, including under complete failure of EMCS.
.6 Complete system CDL's including companion English language explanations on same sheet but with different font and italics. CDL's to contain specified energy optimization programs.
.7 Listing and example of specified reports.
.8 Listing of time of day schedules.
.9 Mark up to-scale construction drawing to detail control room showing location of equipment and operator work space.
.10 Type and size of memory with statement of spare memory capacity.
.11 Full description of software programs provided.
.12 Sample of "Operating Instructions Manual" to be used for training purposes.
.13 Outline of proposed start-up and verification procedures. Refer to Section 25 01 11 - EMCS: Start-up, Verification and Commissioning. |
|--|--|

PART 2 - PRODUCTS

- | | |
|---------------------|--------------|
| <u>2.1 NOT USED</u> | .1 Not Used. |
|---------------------|--------------|

PART 3 - EXECUTION

- | | |
|---------------------|--------------|
| <u>3.1 NOT USED</u> | .1 Not Used. |
|---------------------|--------------|

PART 1 - GENERAL

- 1.1 SUMMARY .1 Section Includes.
.1 Requirements and procedures for identification of devices, sensors, wiring tubing, conduit and equipment, for building Energy Monitoring and Control System (EMCS) Work and nameplates materials, colours and lettering sizes.
.2 Related Sections.
.1 Section 01 33 00 - Submittal Procedures.
.2 Section 25 05 01 - EMCS: General Requirements.
- 1.2 REFERENCES .1 Canadian Standards Association (CSA International).
.1 CSA C22.1-02, The Canadian Electrical Code, Part I (19th Edition), Safety Standard for Electrical Installations.
- 1.3 DEFINITIONS .1 For acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.
- 1.4 SYSTEM DESCRIPTION .1 Language Operating Requirements: provide identification for control items in English.
- 1.5 SUBMITTALS .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures supplemented and modified by requirements of this Section.
.2 Submit to Departmental Representative for approval samples of nameplates, identification tags and list of proposed wording.

PART 2 - PRODUCTS

- 2.1 NAMEPLATES FOR PANELS .1 Identify by Plastic laminate, square corners, lettering accurately aligned and engraved into core.
.2 Sizes: 25 x 67mm minimum.

2.1 NAMEPLATES FOR
PANELS
(Cont'd)

- .3 Lettering: minimum 7 mm high, black.
- .4 Inscriptions: machine engraved to identify function.

2.2 NAMEPLATES FOR
FIELD DEVICES

- .1 Identify by plastic encased cards attached by plastic tie.
- .2 Sizes: 50 x 100 mm minimum.
- .3 Lettering: minimum 5 mm high produced from laser printer in black.
- .4 Data to include: point name and point address.
- .5 Companion cabinet: identify interior components using plastic enclosed cards with point name and point address.

2.3 NAMEPLATES FOR
ROOM SENSORS

- .1 Identify by stick-on labels using point identifier.
- .2 Location: as directed by Departmental Representative.
- .3 Letter size: to suit, clearly legible.

2.4 WARNING SIGNS

- .1 Equipment including motors, starters under remote automatic control: supply and install orange coloured signs warning of automatic starting under control of EMCS.
- .2 Sign to read: "Caution: This equipment is under automatic remote control of EMCS".

2.5 WIRING

- .1 Supply and install numbered tape markings on wiring at panels, junction boxes, splitters, cabinets and outlet boxes.
- .2 Colour coding: to CSA C22.1. Use colour coded wiring in communications cables, matched throughout system.
- .3 Power wiring: identify circuit breaker panel/circuit breaker number inside each EMCS panel.

2.6 PNEUMATIC TUBING .1 Numbered tape markings on tubing to provide uninterrupted tracing capability.

2.7 CONDUIT .1 Colour code EMCS conduit.
.2 Pre-paint box covers and conduit fittings.
.3 Coding: use fluorescent orange paint and confirm colour with Departmental Representative during "Preliminary Design Review".

PART 3 - EXECUTION

3.1 NAMEPLATES AND LABELS .1 Ensure that manufacturer's nameplates, CSA labels and identification nameplates are visible and legible at all times.

3.2 EXISTING PANELS .1 Correct existing nameplates and legends to reflect changes made during Work.

PART 1 - GENERAL

- | | | |
|------------------------|----|--|
| <u>1.1 SUMMARY</u> | .1 | Related Sections: <ul style="list-style-type: none">.1 Section 25 05 01 - EMCS: General Requirements..2 Section 25 05 02 - EMCS: Shop Drawings, Product Data and Review Process..3 Section 25 30 02 - EMCS: Field Control Devices..4 Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation. |
| <u>1.2 REFERENCES</u> | .1 | American Society of Heating, Refrigeration and Air-Conditioning Engineers, Inc. (ASHRAE). <ul style="list-style-type: none">.1 ASHRAE 2003, Applications Handbook, SI Edition. |
| | .2 | Canadian Standards Association (CSA International). <ul style="list-style-type: none">.1 C22.2 No.205-M1983(R1999), Signal Equipment. |
| | .3 | Institute of Electrical and Electronics Engineers (IEEE). <ul style="list-style-type: none">.1 IEEE C37.90.1-02, Surge Withstand Capabilities (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus. |
| | .4 | Public Works and Government Services Canada (PWGSC)/Real Property Branch/Architectural and Engineering Services. <ul style="list-style-type: none">.1 MD13800-September 2000, Energy Management and Control Systems (EMCS) Design Manual. English:
ftp://ftp.pwgsc.gc.ca/rps/docentre/mechanica/me214-e.pdf |
| <u>1.3 DEFINITIONS</u> | .1 | Acronyms and definitions: refer to Section 25 05 01 - EMCS: General Requirements. |
-

1.4 SYSTEM
DESCRIPTION

- .1 General: Network of controllers comprising of MCU('s), LCU('s), ECU('s) or TCU('s) to be provided as indicated in System Architecture Diagram to support building systems and associated sequence(s) of operations as detailed in these specifications.
 - .1 Provide sufficient controllers to meet intents and requirements of this section.
 - .2 Controller quantity, and point contents to be approved by Departmental Representative at time of preliminary design review.
- .2 Controllers: stand-alone intelligent Control Units.
 - .1 Incorporate programmable microprocessor, non-volatile program memory, RAM, power supplies, as required to perform specified functions.
 - .2 Incorporate communication interface ports for communication to LANs to exchange information with other Controllers.
 - .3 Capable of interfacing with operator interface device.
 - .4 Execute its logic and control using primary inputs and outputs connected directly to its onboard input/output field terminations or slave devices, and without need to interact with other controller. Secondary input used for reset such as outdoor air temperature may be located in other Controller(s).
 - .1 Secondary input used for reset such as outdoor air temperature may be located in other Controller(s).

1.5 DESIGN
REQUIREMENTS

- .1 To include:
 - .1 Scanning of AI and DI connected inputs for detection of change of value and processing detection of alarm conditions.
 - .2 Perform On-Off digital control of connected points, including resulting required states generated through programmable logic output.
 - .3 Perform Analog control using programmable logic, (including PID) with adjustable dead bands and deviation alarms.
 - .4 Control of systems as described in sequence of operations.
 - .5 Execution of optimization routines as listed in this section.

1.5 DESIGN
REQUIREMENTS
(Cont'd)

- .2 Total spare capacity for MCUs and LCUs: at least 25 % of each point type distributed throughout the MCUs and LCUs.
- .3 Field Termination and Interface Devices:
 - .1 To: CSA C22.2 No.205.
 - .2 Electronically interface sensors and control devices to processor unit.
 - .3 Include, but not be limited to, following:
 - .1 Programmed firmware or logic circuits to meet functional and technical requirements.
 - .2 Power supplies for operation of logics devices and associated field equipment.
 - .3 Lockable wall cabinet.
 - .4 Required communications equipment and wiring (if remote units).
 - .5 Leave controlled system in "fail-safe" mode in event of loss of communication with, or failure of, processor unit.
 - .6 Input Output interface to accept as minimum AI, AO, DI, DO functions as specified.
 - .7 Wiring terminations: use conveniently located screw type or spade lug terminals.
 - .4 AI interface equipment to:
 - .1 Convert analog signals to digital format with 10 bit analog-to-digital resolution.
 - .2 Provide for following input signal types and ranges:
 - .1 4 - 20 mA;
 - .2 0 - 10 V DC;
 - .3 100/1000 ohm RTD input;
 - .3 Meet IEEE C37.90.1 surge withstand capability.
 - .4 Have common mode signal rejection greater than 60 dB to 60 Hz.
 - .5 Where required, dropping resistors to be certified precision devices which complement accuracy of sensor and transmitter range specified.
 - .5 AO interface equipment:
 - .1 Convert digital data from controller processor to acceptable analog output signals using 8 bit digital-to-analog resolution.
 - .2 Provide for following output signal types and ranges:
 - .1 4 - 20 mA.
 - .2 0 - 10 V DC.

1.5 DESIGN
REQUIREMENTS
(Cont'd)

- .3 (Cont'd)
- .5 (Cont'd)
 - .3 Meet IEEE C37.90.1 surge withstand capability.
- .6 DI interface equipment:
 - .1 Able to reliably detect contact change of sensed field contact and transmit condition to controller.
 - .2 Meet IEEE C37.90.1 surge withstand capability.
 - .3 Accept pulsed inputs up to 2 kHz.
- .7 DO interface equipment:
 - .1 Respond to controller processor output, switch respective outputs. Each DO hardware to be capable of switching up to 0.5 amps at 24 V AC.
 - .2 Switch up to 5 amps at 220 V AC using optional interface relay.
- .4 Controllers and associated hardware and software: operate in conditions of 0 degrees C to 44 degrees C and 20 % to 90 % non-condensing RH.
- .5 Controllers (MCU, LCU): mount in wall mounted cabinet with hinged, keyed-alike locked door.
 - .1 Provide for conduit entrance from top, bottom or sides of panel.
 - .2 ECUs and TCUs to be mounted in equipment enclosures or separate enclosures.
 - .3 Mounting details as approved by Departmental Representative for ceiling mounting.
- .6 Cabinets to provide protection from water dripping from above, while allowing sufficient airflow to prevent internal overheating.
- .7 Provide surge and low voltage protection for interconnecting wiring connections.

1.6 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00 - Submittal Procedures and Section 25 05 02 - EMCS: Shop Drawings, Product Data and Review Process.
 - .1 Submit product data sheets for each product item proposed for this project.

- | | | |
|---------------------------------------|----|---|
| <u>1.7 MAINTENANCE
PROCEDURES</u> | .1 | Provide manufacturers recommended maintenance procedures for insertion in Section 01 78 00 - Closeout Submittals. |
|---------------------------------------|----|---|

PART 2 - PRODUCTS

- | | | |
|--|----|---|
| <u>2.1 MASTER CONTROL
UNIT (MCU)</u> | .1 | General: primary function of MCU is to provide co-ordination and supervision of subordinate devices in execution of optimization routines such as demand limiting or enthalpy control. |
| | .2 | Include high speed communication LAN Port for Peer to Peer communications with OWS(s) and other MCU level devices.
.1 MCU must support BACnet. |
| | .3 | MCU local I/O capacity as follows:
.1 MCU I/O points as allocated in I/O Summary Table referenced in MD13800.
.2 LCUs may be added to support system functions. |
| | .4 | Central Processing Unit (CPU).
.1 Processor to consist of minimum 16 bit microprocessor capable of supporting software to meet specified requirements.
.2 CPU idle time to be more than 30 % when system configured to maximum input and output with worst case program use.
.3 Minimum addressable memory to be at manufacturer's discretion but to support at least performance and technical specifications to include but not limited to:
.1 Non-volatile EEPROM to contain operating system, executive, application, sub-routine, other configurations definition software. Tape media not acceptable.
.2 Battery backed (72 hour minimum capacity) RAM (to reduce the need to reload operating data in event of power failure) to contain CDLs, application parameters, operating data or software that is required to be modifiable from operational standpoint such as schedules, setpoints, alarm limits, PID constants and CDL and hence modifiable on-line through operator panel or remote operator's interface. RAM to be downline loadable from OWS. |

- 2.1 MASTER CONTROL .4 (Cont'd)
UNIT (MCU) .3 (Cont'd)
(Cont'd)
- .4 Include uninterruptible clock accurate to plus or minus 5 secs/month, capable of deriving year/month/day/hour/minute/second, with rechargeable batteries for minimum 72 hour operation in event of power failure.
- .5 Local Operator Terminal (OT): Provide OT for each MCU unless otherwise specified in Section 25 90 01 - EMCS: Site Requirements, Applications and System Sequences of Operation.
- .1 Mount access/display panel in MCU or in suitable enclosure beside MCU as approved by Departmental Representative.
- .2 Support operator's terminal for local command entry, instantaneous and historical data display, programs, additions and modifications.
- .3 Display simultaneously minimum of 16 point identifiers to allow operator to view single screen dynamic displays depicting entire mechanical systems. Point identifiers to be in English.
- .4 Functions to include, but not be limited to, following:
- .1 Start and stop points.
- .2 Modify setpoints.
- .3 Modify PID loop parameters.
- .4 Override PID control.
- .5 Change time/date.
- .6 Add/modify/start/stop weekly scheduling.
- .7 Add/modify setpoint weekly scheduling.
- .8 Enter temporary override schedules.
- .9 Define holiday schedules.
- .10 View analog limits.
- .11 Enter/modify analog warning limits.
- .12 Enter/modify analog alarm limits.
- .13 Enter/modify analog differentials.
- .5 Provide access to real and calculated points in controller to which it is connected or to other controller in network. This capability not to be restricted to subset of predefined "global points" but to provide totally open exchange of data between OT and other controller in network.
- .6 Operator access to OTs: user password and password changes to automatically be downloaded to controllers on network.

- 2.1 MASTER CONTROL .5 (Cont'd)
UNIT (MCU)
(Cont'd)
- .7 Provide prompting to eliminate need for user to remember command format or point names. Prompting to be consistent with user's password clearance and types of points displayed to eliminate possibility of operator error.
- .8 Identity of real or calculated points to be consistent with network devices. Use same point identifier as at OWS's for access of points at OT to eliminate cross-reference or look-up tables.
- 2.2 LOCAL CONTROL .1
UNIT (LCU)
- .1 Provide multiple control functions for typical built-up and package HVAC systems, hydronic systems and electrical systems.
- .2 Minimum of 16 I/O points of which minimum be 4 AOs, 4 AIs, 4 DIs, 4 DOs.
- .3 Points integral to one Building System to be resident on only one controller.
- .4 Microprocessor capable of supporting necessary software and hardware to meet specified requirements as listed in previous MCU article with following additions:
- .1 Include minimum 2 interface ports for connection of local computer terminal.
- .2 Design so that shorts, opens or grounds on input or output will not interfere with other input or output signals.
- .3 Physically separate line voltage (70V and over) circuits from DC logic circuits to permit maintenance on either circuit with minimum hazards to technician and equipment.
- .4 Include power supplies for operation of LCU and associated field equipment.
- .5 In event of loss of communications with, or failure of, MCU, LCU to continue to perform control. Controllers that use defaults or fail to open or close positions not acceptable.
- .6 Provide conveniently located screw type or spade lug terminals for field wiring.
- 2.3 .1
TERMINAL/EQUIPMENT
CONTROL UNIT
(TCU/ECU)
- Microprocessor capable of supporting necessary software and hardware to meet TCU/ECU functional specifications.
- .1 TCU/ECU definition to be consistent with those defined in ASHRAE HVAC Applications Handbook section 45.
-

2.3

TERMINAL/EQUIPMENT .2
CONTROL UNIT
(TCU/ECU)
(Cont'd)

Controller to communicate directly with EMCS through EMCS LAN and provide access from EMCS OWS for setting occupied and unoccupied space temperature setpoints, flow setpoints, and associated alarm values, permit reading of sensor values, field control values (% open) and transmit alarm conditions to EMCS OWS.

2.4 SOFTWARE

- .1 General.
 - .1 Include as minimum: operating system executive, communications, application programs, operator interface, and systems sequence of operation - CDL's.
 - .2 Include "firmware" or instructions which are programmed into ROM, EPROM, EEPROM or other non-volatile memory.
 - .3 Include initial programming of Controllers, for entire system.
- .2 Program and data storage.
 - .1 Store executive programs and site configuration data in ROM, EEPROM or other non-volatile memory.
 - .2 Maintain CDL and operating data including setpoints, operating constants, alarm limits in battery-backed RAM or EEPROM for display and modification by operator.
- .3 Programming languages.
 - .1 Program Control Description Logic software (CDL) using English like or graphical, high level, general control language.
 - .2 Structure software in modular fashion to permit simple restructuring of program modules if future software additions or modifications are required. GO TO constructs not allowed unless approved by Departmental Representative.
- .4 Operator Terminal interface.
 - .1 Operating and control functions include:
 - .1 Multi-level password access protection to allow user/manager to limit workstation control.
 - .2 Alarm management: processing and messages.
 - .3 Operator commands.
 - .4 Reports.
 - .5 Displays.
 - .6 Point identification.

2.4 SOFTWARE

(Cont'd)

- .4 (Cont'd)
 - .1 (Cont'd)
- .5 Pseudo or calculated points.
 - .1 Software to provide access to value or status in controller or other networked controller in order to define and calculate pseudo point. When current pseudo point value is derived, normal alarm checks must be performed or value used to totalize.
 - .2 Inputs and outputs for process: include data from controllers to permit development of network-wide control strategies. Processes also to permit operator to use results of one process as input to number of other processes (e.g. cascading).
- .6 Control Description Logic (CDL):
 - .1 Capable of generating on-line project-specific CDLs which are software based, programmed into RAM or EEPROM and backed up to OWS. Owner must have access to these algorithms for modification or to be able to create new ones and to integrate these into CDLs on BC(s) from OWS.
 - .2 Write CDL in high level language that allows algorithms and interlocking programs to be written simply and clearly. Use parameters entered into system (e.g. setpoints) to determine operation of algorithm. Operator to be able to alter operating parameters on-line from OWS and BC(s) to tune control loops.
 - .3 Perform changes to CDL on-line.
 - .4 Control logic to have access to values or status of points available to controller including global or common values, allowing cascading or inter-locking control.
 - .5 Energy optimization routines including enthalpy control, supply temperature reset, to be LCU or MCU resident functions and form part of CDL.
 - .6 MCU to be able to perform following pre-tested control algorithms:
 - .1 Two position control.
 - .2 Proportional Integral and Derivative (PID) control.
 - .7 Control software to provide ability to define time between successive starts for each piece of equipment to reduce cycling of motors.
 - .8 Provide protection against excessive electrical-demand situations during start-up periods by automatically introducing time delays between successive start commands to heavy electrical loads.

2.4 SOFTWARE
(Cont'd)

- .6 (Cont'd)
 - .9 Power Fail Restart: upon detection of power failure system to verify availability of Emergency Power as determined by emergency power transfer switches and analyze controlled equipment to determine its appropriate status under Emergency power conditions and start or stop equipment as defined by I/O Summary. Upon resumption of normal power as determined by emergency power transfer switches, MCU to analyze status of controlled equipment, compare with normal occupancy scheduling, turn equipment on or off as necessary to resume normal operation.
- .7 Event and Alarm management: use management by exception concept for Alarm Reporting. This is system wide requirement. This approach will insure that only principal alarms are reported to OWS. Events which occur as direct result of primary event to be suppressed by system and only events which fail to occur to be reported. Such event sequence to be identified in I/O Summary and sequence of operation. Examples of above are, operational temperature alarms limits which are exceeded when main air handler is stopped, or General Fire condition shuts air handlers down, only Fire alarm status shall be reported. Exception is, when air handler which is supposed to stop or start fails to do so under event condition.
- .8 Energy management programs: include specific summarizing reports, with date stamp indicating sensor details which activated and or terminated feature.
 - .1 MCU in coordination with subordinate LCU, TCU, ECU to provide for the following energy management routines:
 - .1 Time of day scheduling.
 - .2 Calendar based scheduling.
 - .3 Holiday scheduling.
 - .4 Temporary schedule overrides.
 - .5 Optimal start stop.
 - .6 Night setback control.
 - .7 Temperature compensated load rolling.
 - .8 Fan speed/flow rate control.
 - .2 Programs to be executed automatically without need for operator intervention and be flexible enough to allow customization.

2.4 SOFTWARE (Cont'd) .8 (Cont'd)
.3 Apply programs to equipment and systems as specified or requested by the Departmental Representative.

2.5 POINT NAME SUPPORT .1 Controllers (MCU, LCU) to support PWGSC point naming convention as defined in Section 25 05 01 - EMCS: General Requirements.

PART 3 - EXECUTION

3.1 LOCATION .1 Location of Controllers to be approved by Departmental Representative.

3.2 INSTALLATION .1 Install Controllers in secure locking enclosures as directed by Departmental Representative.
.2 Provide necessary power from local 120 V branch circuit panel for equipment.
.3 Install tamper locks on breakers of circuit breaker panel.
.4 Use uninterruptible Power Supply (UPS) and emergency power when equipment must operate in emergency and co-ordinating mode.

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Control devices integral to the Building Energy Monitoring and Control System (EMCS): transmitters, sensors, controls, meters, switches, dampers, damper operators, valves, valve actuators.
 - .2 Related Sections:
 - .1 Section 07 84 00 - Firestopping.
 - .2 Section 23 33 15 - Dampers - Operating.
 - .3 Section 25 01 11 - EMCS: Start-Up, Verification and Commissioning.
 - .4 Section 25 05 01 - EMCS: General Requirements.
 - .5 Section 25 05 54 - EMCS: Identification.
 - .6 Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation.
 - .7 Section 26 05 00 - Common Work Results - Electrical.
 - .8 Section 26 27 26 - Wiring Devices.

1.2 REFERENCES

- .1 American National Standards Institute (ANSI).
 - .1 ANSI C12.7-1993(R1999), Requirements for Watthour Meter Sockets.
 - .2 ANSI/IEEE C57.13-1993, Standard Requirements for Instrument Transformers.
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM B 148-97(03), Standard Specification for Aluminum-Bronze Sand Castings.
- .3 National Electrical Manufacturer's Association (NEMA).
 - .1 NEMA 250-03, Enclosures for Electrical Equipment (1000 Volts Maximum).
- .4 Air Movement and Control Association, Inc. (AMCA).
 - .1 AMCA Standard 500-D-98, Laboratory Method of Testing Dampers For Rating.
- .5 Canadian Standards Association (CSA International).
 - .1 CSA-C22.1-02, Canadian Electrical Code, Part 1 (19th Edition), Safety Standard for Electrical Installations.

1.3 DEFINITIONS .1 Acronyms and Definitions: refer to Section 25 05 01 - EMCS: General Requirements.

1.4 SUBMITTALS .1 Submit shop drawings and manufacturer's installation instructions in accordance with Section 01 33 00 - Submittal Procedures.

.2 Manufacturer's Instructions:
.1 Submit manufacturer's installation instructions for specified equipment and devices.

1.5 EXISTING CONDITIONS .1 Repair surfaces damaged during execution of Work.

.2 Turn over to Departmental Representative existing materials removed from Work not identified for re-use.

PART 2 - PRODUCTS

2.1 GENERAL .1 Control devices of each category to be of same type and manufacturer.

.2 External trim materials to be corrosion resistant. Internal parts to be assembled in watertight, shockproof, vibration-proof, heat resistant, assembly.

.3 Operating conditions: 0 - 32 degrees C with 10 - 90 % RH (non-condensing) unless otherwise specified.

.4 Terminations: use standard conduit box with slot screwdriver compression connector block unless otherwise specified.

.5 Transmitters and sensors to be unaffected by external transmitters including walkie talkies.

.6 Account for hysteresis, relaxation time, maximum and minimum limits in applications of sensors and controls.

.7 Outdoor installations: use weatherproof construction in NEMA 4 enclosures.

2.1 GENERAL
(Cont'd)

- .8 Devices installed in user occupied space not exceed Noise Criteria (NC) of 35. Noise generated by any device must not be detectable above space ambient conditions.
- .9 Range: including temperature, humidity, pressure, as indicated in I/O summary in Section 25 90 01 - EMCS: Site Requirements, Applications and System Sequences of Operation.

2.2 TEMPERATURE
SENSORS

- .1 General: except for room sensors to be resistance or thermocouple type to following requirements:
 - .1 RTD's: 100 or 1000 ohm at 0 degrees C (plus or minus 0.2 ohms) platinum element with strain minimizing construction, 3 integral anchored leadwires. Coefficient of resistivity: 0.00385 ohms/ohm degrees C.
 - .2 Sensing element: hermetically sealed.
 - .3 Stem and tip construction: copper or type 304 stainless steel.
 - .4 Time constant response: less than 3 seconds to temperature change of 10 degrees C.
- .2 Room temperature sensors and display wall modules.
 - .1 Temperature sensing and display wall module.
 - .1 LCD display to show space temperature and temperature setpoint.
 - .2 Buttons for occupant selection of temperature setpoint.
 - .3 Integral thermistor sensing element 10,000 ohm at 24 degrees.
 - .4 Accuracy 0.2 degrees C over range of 0 to 70 degrees C.
 - .5 Stability 0.02 degrees C drift per year.
 - .6 Separate mounting base for ease of installation.
 - .2 Room temperature sensors.
 - .1 Wall mounting, in slotted type covers having brushed aluminum finish.
 - .2 Element 10-50 mm long RTD with ceramic tube or equivalent protection or thermistor, 10,000 ohm, accuracy of plus or minus 0.2 degrees C.
- .3 Duct temperature sensors:
 - .1 General purpose duct type: suitable for insertion into ducts at various orientations, insertion length 460 mm or as indicated.

2016-02-19

2.2 TEMPERATURE
SENSORS
(Cont'd)

- .3 (Cont'd)
 - .2 Averaging duct type: incorporates numerous sensors inside assembly which are averaged to provide one reading. Minimum insertion length 6000 mm. Bend probe at field installation time to 100 mm radius at point along probe without degradation of performance.
- .4 Outdoor air temperature sensors:
 - .1 Outside air type: complete with probe length 100 - 150 mm long, non-corroding shield to minimize solar and wind effects, threaded fitting for mating to 13 mm conduit, weatherproof construction in NEMA 4 enclosure.

2.3 TEMPERATURE
SWITCHES

- .1 Requirements:
 - .1 Operate automatically. Reset automatically, except as follows:
 - .1 Low temperature detection: manual reset.
 - .2 High temperature detection: manual reset.
 - .2 Adjustable setpoint and differential.
 - .3 Accuracy: plus or minus 1 degrees C.
 - .4 Snap action rating: 120V, 15 amps or 24V DC as required. Switch to be DPST for hardwire and EMCS connections.
 - .5 Type as follows:
 - .1 Room: for wall mounting on standard electrical box without protective guard as indicated.
 - .2 Duct, general purpose: insertion length = 460 mm.
 - .3 Low temperature detection: continuous element with 6000 mm insertion length, duct mounting, to detect coldest temperature in any 30 mm length.
 - .4 Strap-on: with helical screw stainless steel clamp.

2.4
ELECTROMECHANICAL
RELAYS

- .1 Requirements:
 - .1 Double voltage, DPDT, plug-in type with termination base.
 - .2 Coils: rated for 120V AC or 24V DC. Other voltage: provide transformer.
 - .3 Contacts: rated at 5 amps at 120 V AC.
 - .4 Relay to have visual status indication

2.5 SOLID STATE
RELAYS

- .1 General:
 - .1 Relays to be socket or rail mounted.
 - .2 Relays to have LED Indicator
 - .3 Input and output Barrier Strips to accept 14 to 28 AWG wire.
 - .4 Operating temperature range to be -20 degrees C to 70 degrees C.
 - .5 Relays to be CSA Certified.
 - .6 Input/output Isolation Voltage to be 4000 VAC at 25 degrees C for 1 second maximum duration.
 - .7 Operational frequency range, 45 to 65 HZ.
- .2 Input:
 - .1 Control voltage, 3 to 32 VDC.
 - .2 Drop out voltage, 1.2 VDC.
 - .3 Maximum input current to match AO (Analog Output) board.
- .3 Output.
 - .1 AC or DC Output Model to suit application.

2.6 CONTROL
DAMPERS

- .1 Construction: blades, 152 mm wide, 1219 mm long, maximum. Modular maximum size, 1219 mm wide x 1219 mm high.
- .2 Materials:
 - .1 Frame: 2.03 mm minimum thickness extruded aluminum. For outdoor air and exhaust air applications, frames to be insulated.
 - .2 Blades: extruded aluminum. For outdoor air/exhaust air applications, blades to be internally insulated.
 - .3 Bearings: maintenance free, synthetic type of material.
 - .4 Linkage and shafts: aluminum, zinc and nickel plated steel.
 - .5 Seals: synthetic type, mechanically locked into blade edges.
 - .1 Frame seals: synthetic type, mechanically locked into frame sides.
- .3 Performance: minimum damper leakage meet or exceed AMCA Standard 500-D ratings.
 - .1 Size/Capacity: refer to damper schedule
 - .2 25 L/s/m² maximum allowable leakage against 1000 Pa static pressure for outdoor air and exhaust air applications.
 - .3 Temperature range: minus 40 degrees C to plus 100 degrees C.

2.6 CONTROL
DAMPERS
(Cont'd)

- .4 Arrangements: dampers mixing warm and cold air to be parallel blade, mounted at right angles to each other, with blades opening to mix air stream.
- .5 Jack shafts:
 - .1 25 mm diameter solid shaft, constructed of corrosion resistant metal complete with required number of pillow block bearings to support jack shaft and operate dampers throughout their range.
 - .2 Include corrosion resistant connecting hardware to accommodate connection to damper actuating device.
 - .3 Install using manufacturers installation guidelines.
 - .4 Use same manufacturer as damper sections.

2.7 ELECTRONIC
CONTROL DAMPER
ACTUATORS

- .1 Requirements:
 - .1 Direct mount proportional type as indicated.
 - .2 Spring return for "fail-safe" in Normally Open or Normally Closed position as indicated.
 - .3 Operator: size to control dampers against maximum pressure and dynamic closing/opening pressure, whichever is greater.
 - .4 Power requirements: 5 VA maximum at 24 V AC.
 - .5 Operating range: 0 - 10 V DC or 4 - 20 mA DC.
 - .6 For VAV box applications floating control type actuators may be used.

2.8 PANELS

- .1 Wall mounted enamelled steel cabinets with hinged and key-locked front door.
- .2 Multiple panels as required to handle requirements with additional space to accommodate 25% additional capacity as required by Departmental Representative without adding additional cabinets.
- .3 Panels to be lockable with same key.

2.9 WIRING

- .1 In accordance with Section 26 27 26 - Wiring Devices.

2.9 WIRING
(Cont'd)

- .2 For wiring under 70 volts use FT6 rated wiring where wiring is not run in conduit. Other cases use FT4 wiring.
- .3 Wiring must be continuous without joints.
- .4 Sizes:
 - .1 Field wiring to digital device: #18AWG 20AWG stranded twisted pair.
 - .2 Analog input and output: shielded #18 minimum solid copper #20 minimum stranded twisted pair.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install equipment, components so that manufacturer's and CSA labels are visible and legible after commissioning is complete.
- .2 Install field control devices in accordance with manufacturers recommended methods, procedures and instructions.
- .3 Temperature transmitters, controllers, relays: install in NEMA I enclosure or as required for specific applications. Provide for electrolytic isolation in cases when dissimilar metals make contact.
- .4 Support field-mounted panels, transmitters and sensors on pipe stands or channel brackets.
- .5 Fire stopping: provide space for fire stopping in accordance with Section 07 84 00 - Firestopping. Maintain fire rating integrity.
- .6 Electrical:
 - .1 Complete installation in accordance with Section 26 05 00 - Common Work Results For Electrical.
 - .2 Modify existing starters to provide for EMCS as indicated in I/O Summaries and as indicated.
 - .3 Refer to electrical control schematics included as part of control design schematics in Section 25 90 01 - EMCS: Site Requirements Applications and Systems Sequences of Operation on drawings. Trace existing control wiring installation and provide updated wiring schematics including additions, deletions to control circuits for review by Departmental Representative before beginning Work.

-
- 3.1 INSTALLATION .6 (Cont'd)
(Cont'd)
- .4 Terminate wires with screw terminal type connectors suitable for wire size, and number of terminations.
 - .5 Install communication wiring in conduit.
 - .1 Provide complete conduit system to link Building Controllers, field panels and OWS(s).
 - .2 Conduit sizes to suit wiring requirements and to allow for future expansion capabilities specified for systems.
 - .3 Maximum conduit fill not to exceed 40%.
 - .4 Design drawings do not show conduit layout.
 - .6 Do not run exposed conduits in normally occupied spaces unless otherwise indicated or unless impossible to do otherwise. Departmental Representative to review before starting Work. Wiring in mechanical rooms, wiring in service rooms and exposed wiring must be in conduit.
-
- 3.2 TEMPERATURE AND HUMIDITY SENSORS .1 Stabilize to ensure minimum field adjustments or calibrations.
-
- .2 Readily accessible and adaptable to each type of application to allow for quick easy replacement and servicing without special tools or skills.
- .3 Outdoor installation:
 - .1 Protect from solar radiation and wind effects by non-corroding shields.
 - .2 Install in NEMA 4 enclosures.
- .4 Duct installations:
 - .1 Do not mount in dead air space.
 - .2 Locate within sensor vibration and velocity limits.
 - .3 Securely mount extended surface sensor used to sense average temperature.
 - .4 Thermally isolate elements from brackets and supports to respond to air temperature only.
 - .5 Support sensor element separately from coils, filter racks.
- .5 Averaging duct type temperature sensors.
-

3.2 TEMPERATURE AND HUMIDITY SENSORS
(Cont'd)

- .5 (Cont'd)
- .1 Install averaging element horizontally across the ductwork starting 300 mm from top of ductwork. Each additional horizontal run to be no more than 300 mm from one above it. Continue until complete cross sectional area of ductwork is covered. Use multiple sensors where single sensor does not meet required coverage.
- .2 Wire multiple sensors in series for low temperature protection applications.
- .3 Wire multiple sensors separately for temperature measurement.
- .4 Use software averaging algorithm to derive overall average for control purposes.

3.3 PANELS

- .1 Arrange for conduit and tubing entry from top, bottom or either side.
- .2 Wiring and tubing within panels: locate in trays or individually clipped to back of panel.
- .3 Identify wiring and conduit clearly.

3.4 PRESSURE AND DIFFERENTIAL PRESSURE SWITCHES AND SENSORS

- .1 Install isolation valve and snubber on sensors between sensor and pressure source where code allows.
- .1 Protect sensing elements on steam and high temperature hot water service with pigtail syphon between valve and sensor.

3.5 IDENTIFICATION

- .1 Identify field devices in accordance with Section 25 05 54 - EMCS: Identification.

3.6 TESTING AND COMMISSIONING

- .1 Calibrate and test field devices for accuracy and performance in accordance with Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.