

## PART 1 - GENERAL

- 1.1 REFERENCES
- .1 Canadian Standards Association (CSA International)
    - .1 CSA C22.1-12, Canadian Electrical Code, Part 1 (22nd Edition), Safety Standard for Electrical Installations.
    - .2 CSA C22.2 No. 0-10.
    - .3 CAN3-C235-83(R2010), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
  - .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC)
    - .1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
  - .3 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
    - .1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.
- 1.2 DEFINITIONS
- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.
- 1.3 DESIGN REQUIREMENTS
- .1 Operating voltages: to CAN3-C235.
  - .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
    - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
  - .3 Language operating requirements: provide identification nameplates and labels for control items in English and French.
  - .4 Use one nameplate or label for each language.
-

- 1.4 SUBMITTALS
- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data: submit WHMIS MSDS in accordance with Section 01 47 15 - Sustainable Requirements: Construction and Section 02 81 01 - Hazardous Materials.
  - .3 Submit for review single line electrical diagrams under plexiglass and locate as indicated.
    - .1 Electrical distribution system in main electrical room.
    - .2 Electrical power generation and distribution systems in generator room.
  - .4 Submit for review fire alarm riser diagram, plan and zoning of building under plexiglass at fire alarm control panel and annunciator at alarm room.
  - .5 Shop drawings:
    - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Newfoundland and Labrador, Canada.
    - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.
    - .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
    - .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
    - .5 Submit one (1) electronic digital file for reproduction 8½ X 11 of product data to authority having jurisdiction, inspection authorities and Departmental Representative.
    - .6 If changes are required, notify Departmental Representative of these changes before they are made.
  - .6 Quality Control: in accordance with Section 01 45 00 - Quality Control.
    - .1 Provide CSA certified equipment and material.
    - .2 Where CSA certified equipment and material is not available, submit such equipment and material to authority having
-

- |                            |    |   |
|----------------------------|----|---|
| 1.4 SUBMITTALS<br>(Cont'd) | .6 | Quality Control: (Cont'd)<br>.2 (Cont'd)<br>jurisdiction inspection authorities for special approval before delivery to site.<br>.3 Submit test results of installed electrical systems and instrumentation.<br>.4 Permits and fees: in accordance with General Conditions of contract.<br>.5 Submit, upon completion of Work, load balance report as described in PART 3 - LOAD BALANCE.<br>.6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.   |
|                            | .7 | Manufacturer's Field Reports: submit to Departmental Representative Engineer Consultant manufacturer's written report, within 3 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.   |
| 1.5 QUALITY ASSURANCE      | .1 | Quality Assurance: in accordance with Section 01 45 00 - Quality Control.   |
|                            | .2 | Qualifications: electrical Work to be carried out by qualified, licensed electricians who hold valid Master Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Act respecting manpower vocational training and qualification.<br>.1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.<br>.2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties. |
|                            | .3 | Site Meetings:<br>.1 In accordance with Section 01 32 16.06 - Construction Progress Schedule - Critical Path Method (CPM) Section 01 32 16.07 - Construction Progress Schedule - Bar (GANTT) Charts.<br>.2 Site Meetings: as part of Manufacturer's Field Services described in Part 3 - FIELD  |
-

- |   |    |   |
|---|----|---|
| <u>1.5 QUALITY ASSURANCE (Cont'd)</u>     | .3 | Site Meetings:(Cont'd)<br>.2 Site Meetings:(Cont'd)<br>QUALITY CONTROL, schedule site visits, to review Work, at stages listed.<br>.1 After delivery and storage of products, and when preparatory Work is complete but before installation begins.<br>.2 Twice during progress of Work at rough in and 70% complete.<br>.3 Upon completion of Work, after cleaning is carried out.<br><br>.4 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements. |
| <u>1.6 DELIVERY, STORAGE AND HANDLING</u> | .1 | Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.   |
|   | .2 | Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.  |
| <u>1.7 SYSTEM STARTUP</u>                 | .1 | Instruct Departmental Representative and operating personnel in operation, care and maintenance of systems, system equipment and components.  |
|   | .2 | Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.  |
|   | .3 | Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant will aspects of its care and operation.   |
-



- |                                   |    |   |
|-----------------------------------|----|---|
| <u>1.8 OPERATING INSTRUCTIONS</u> | .1 | Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.  |
|                                   | .2 | Operating instructions to include following:<br>.1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.<br>.2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.<br>.3 Safety precautions.<br>.4 Procedures to be followed in event of equipment failure.<br>.5 Other items of instruction as recommended by manufacturer of each system or item of equipment. |
|                                   | .3 | Print or engrave operating instructions and frame under glass or in approved laminated plastic.   |
|                                   | .4 | Post instructions where directed.   |
|                                   | .5 | For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.  |
|                                   | .6 | Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.  |

## PART 2 - PRODUCTS

- |                                     |    |   |
|-------------------------------------|----|---|
| <u>2.1 SUSTAINABLE REQUIREMENTS</u> | .1 | Materials and products in accordance with Section 01 47 15 - Sustainable Requirements: Construction.<br>.1.             |
|                                     | .2 | Do verification requirements in accordance with Section 01 47 17 - Sustainable Requirements: Contractor's Verification. |
| <u>2.2 MATERIALS AND EQUIPMENT</u>  | .1 | Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.                       |
|                                     | .2 | Material and equipment to be CSA certified. Where CSA certified material and equipment is                               |
-

- |   |    |   |
|---|----|---|
| 2.2 MATERIALS AND EQUIPMENT<br>(Cont'd)     | .2 | (Cont'd)<br>are not available, obtain special approval from authority having jurisdiction before delivery to site and submit such approval as described in PART 1 - SUBMITTALS.   |
|   | .3 | Factory assemble control panels and component assemblies.   |
| 2.3 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS | .1 | Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.   |
|   | .2 | Control wiring and conduit: in accordance with Section 26 29 03 - Control Devices except for conduit, wiring and connections below 50 V which are related to control systems specified in mechanical sections and as shown on mechanical drawings.        |
| 2.4 WARNING SIGNS                           | .1 | Warning Signs: in accordance with requirements of authority having jurisdiction, inspection authorities and Departmental Representative.  |
|   | .2 | Decal signs, minimum size 175 x 250 mm.   |
| 2.5 WIRING TERMINATIONS                     | .1 | Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.  |
| 2.6 EQUIPMENT IDENTIFICATION                | .1 | Identify electrical equipment with nameplates and labels as follows:<br>.1 Nameplates: lamicoid 3 mm, black face, white core, lettering accurately aligned and engraved into core mechanically attached with self tapping screws.<br>.2 Sizes as follows: |
-

#### NAMEPLATE SIZES

Size 1	10 x 50 mm	1 line	3 mm high letters
Size 2	12 x 70 mm	1 line	5 mm high letters
Size 3	12 x 70 mm	2 lines	3 mm high letters
Size 4	20 x 90 mm	1 line	8 mm high letters
Size 5	20 x 90 mm	2 lines	5 mm high letters
Size 6	25 x 100 mm	1 line	12 mm high letters
Size 7	25 x 100 mm	2 lines	6 mm high letters

- .2 Labels: embossed plastic labels with 6 mm high letters unless specified otherwise.
- .3 Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .4 Allow for minimum of twenty-five (25) letters per nameplate and label.
- .5 Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .6 Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .7 Terminal cabinets and pull boxes: indicate system and voltage.
- .8 Transformers: indicate capacity, primary and secondary voltages.

#### 2.7 WIRING IDENTIFICATION

- .1 Identify wiring with permanent indelible identifying markings, numbered, coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.

2.7 WIRING IDENTIFICATION (Cont'd)

- .2 Maintain phase sequence and colour coding throughout.
- .3 Colour coding: to CSA C22.1.
- .4 Use colour coded wires in communication cables, matched throughout system.

2.8 CONDUIT AND CABLE IDENTIFICATION

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

	Prime	Auxiliary
up to 250 V	Yellow	
up to 600 V	Yellow	Green
up to 5 kV	Yellow	Blue
up to 15 kV	Yellow	Red
Telephone	Green	
Other	Green	Blue
Communication Systems		
Fire Alarm	Red	
Emergency	Red	Blue
Voice		
Other	Red	Yellow
Security Systems		

2.9 FINISHES

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish enamel.
  - .1 Paint indoor switchgear and distribution enclosures light gray to EEMAC 2Y-1.

PART 3 - EXECUTION

- |   |    |  |
|---|----|--|
| <u>3.1 INSTALLATION</u>                   | .1 | Do complete installation in accordance with CSA C22.1 except where specified otherwise.  |
|   | .2 | Do overhead and underground systems in accordance with CSA C22.3 No.1 except where specified otherwise.  |
| <u>3.2 NAMEPLATES AND LABELS</u>          | .1 | Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.                 |
| <u>3.3 CONDUIT AND CABLE INSTALLATION</u> | .1 | Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.                 |
| <u>3.4 LOCATION OF OUTLETS</u>            | .1 | Locate outlets in accordance with Section 26 05 32 - Outlet Boxes, Conduit Boxes and Fittings.   |
|   | .2 | Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.  |
|   | .3 | Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation. |
|   | .4 | Locate light switches on latch side of doors.<br>.1 Locate disconnect devices in mechanical and elevator machine rooms on latch side of floor.   |
| <u>3.5 MOUNTING HEIGHTS</u>               | .1 | Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.                          |
|   | .2 | If mounting height of equipment is not specified or indicated, verify before proceeding with installation.                                       |
-

- |   |    |  |
|---|----|--|
| 3.5 MOUNTING<br>HEIGHTS<br>(Cont'd)           | .3 | Install electrical equipment at following heights unless indicated otherwise.<br>.1 Local switches: 1200 mm or match existing.<br>.2 Wall receptacles:<br>.1 General: 450 mm or match existing.<br>.2 Above top of continuous baseboard heater: 200 mm.<br>.3 Above top of counters or counter splash backs: 175 mm.<br>.4 In mechanical rooms: 450 mm.<br>.3 Panelboards: as required by Code or as indicated.<br>.4 Telephone and interphone outlets: 450 mm.<br>.5 Wall mounted telephone and interphone outlets: 1200 mm.<br>.6 Fire alarm stations: 1200 mm or match existing.<br>.7 Fire alarm bells: 2100 mm.<br>.8 Television outlets: 300 mm.                 |
| 3.6 CO-ORDINATION<br>OF PROTECTIVE<br>DEVICES | .1 | Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.   |
| 3.7 FIELD QUALITY<br>CONTROL                  | .1 | Load Balance:<br>.1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.<br>.2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.<br>.3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test. |
|   | .2 | Conduct following tests in accordance with Section 01 45 00 - Quality Control.<br>.1 Power distribution system including phasing, voltage, grounding and load balancing.   |
-

- 3.7 FIELD QUALITY CONTROL  
(Cont'd)
- .2 (Cont'd)
- .2 Circuits originating from branch distribution panels.
- .3 Lighting and its control.
- .4 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
- .5 Systems: fire alarm system communications.
- .6 Insulation resistance testing:
- .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
- .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
- .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.
- .5 Manufacturer's Field Services:
- .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
- .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
- .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.
- 3.8 CLEANING
- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

## PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Materials and installation for wire and box connectors.
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CAN/CSA-C22.2 No.18.2-06 (R2011), Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware. .2 CSA C22.2 No.65-93(R1999), Wire Connectors.
	.2	Electrical and Electronic Manufacturers' Association of Canada (EEMAC) .1 EEMAC 1Y-2, 1961 Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
	.3	National Electrical Manufacturers Association (NEMA)
<u>1.4 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
	.2	Remove from site and dispose of all packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.
	.4	Divert unused wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

---



## PART 2 - PRODUCTS

- 2.1 MATERIALS
- .1 Pressure type wire connectors to: CSA C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
  - .2 Fixture type splicing connectors to: CSA C22.2 No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
  - .3 Bushing stud connectors: to EEMAC 1Y-2 NEMA to consist of:
    - .1 Connector body and stud clamp for round copper conductors.
    - .2 Clamp for round copper conductors.
    - .3 Stud clamp bolts.
    - .4 Bolts for copper conductors and bars.
    - .5 Sized for conductors as indicated.
  - .4 Clamps or connectors for armoured cable, flexible conduit as required to: CAN/CSA-C22.2 No.18.

## PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Remove insulation carefully from ends of conductors and:
    - .1 Apply coat of zinc joint compound on aluminum conductors prior to installation of connectors.
    - .2 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CSA C22.2 No.65.
    - .3 Install fixture type connectors and tighten. Replace insulating cap.
    - .4 Install bushing stud connectors in accordance with EEMAC 1Y-2 NEMA.

PART 1 - GENERAL

- |   |    |   |
|---|----|---|
| <u>1.1 PRODUCT DATA</u>                   | .1 | Provide product data in accordance with Section 01 33 00 - Submittal Procedures.  |
| <u>1.2 DELIVERY, STORAGE AND HANDLING</u> | .1 | Packaging Waste Management: remove for reuse and return of pallets crates paddling and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal. |

PART 2 - PRODUCTS

- |                           |    |   |
|---------------------------|----|---|
| <u>2.1 BUILDING WIRES</u> | .1 | Conductors: stranded for 8 AWG and larger. Minimum size: 12 AWG.  |
|                           | .2 | Copper conductors: size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE, Non Jacketted.   |
|                           | .3 | Neutral supported cable: 3 phase insulated conductors of Copper and one neutral conductor of Copper steel reinforced, size as indicated. Type: NS75 Insulation: Type NSF-2 flame retardant rated 600 V. |
| <u>2.2 TECK 90 CABLE</u>  | .1 | Cable: in accordance with Section 26 05 00 - Common Work Results for Electrical.  |
|                           | .2 | Conductors:<br>.1 Grounding conductor: copper.<br>.2 Circuit conductors: copper, size as indicated.   |
|                           | .3 | Insulation:<br>.1 Cross-linked polyethylene XLPE.<br>.2 Rating: 600 V.  |
|                           | .4 | Inner jacket: polyvinyl chloride material.  |
|                           | .5 | Armour: interlocking aluminum.  |
-

- 2.2 TECK 90 CABLE (Cont'd)
- .6 Overall covering: thermoplastic polyvinyl chloride, compliant to applicable Building Code classification for this project.
  - .7 Fastenings:
    - .1 One hole aluminum straps to secure surface cables 50 mm and smaller. Two hole steel straps for cables larger than 50 mm.
    - .2 Channel type supports for two or more cables at 1500 mm centers.
    - .3 Threaded rods: 6 mm diameter to support suspended channels.
  - .8 Connectors:
    - .1 Watertight, approved for TECK cable.

- 2.3 ARMOURED CABLES
- .1 Conductors: insulated, copper aluminum, size as indicated.
  - .2 Type: AC90.
  - .3 Armour: interlocking type fabricated from aluminum strip.
  - .4 Type: ACWU90 jacket over armour and compliant to applicable Building Code classification for this project.
  - .5 Connectors: anti short connectors.
  - .6 Only to be used for fixture drops or vibrating eqi.

PART 3 - EXECUTION

- 3.1 FIELD QUALITY CONTROL
- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
  - .2 Perform tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
  - .3 Perform tests before energizing electrical system.
-

- 3.2 GENERAL CABLE INSTALLATION
- .1 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - (0-1000 V).
  - .2 Cable Colour Coding: to Section 26 05 00 Common Work Results for Electrical.
  - .3 Conductor length for parallel feeders to be identical.
  - .4 Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.
  - .5 Wiring in walls: typically drop or loop vertically from above to better facilitate future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.
  - .6 Branch circuit wiring for surge suppression receptacles and permanently wired computer and electronic equipment to be 2-wire circuits only, i.e. common neutrals not permitted.
  - .7 Provide numbered wire collars for control wiring. Numbers to correspond to control shop drawing legend. Obtain wiring diagram for control wiring.
- 3.3 INSTALLATION OF BUILDING WIRES
- .1 Install wiring as follows:
    - .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.
    - .2 In surface and lighting fixture raceways in accordance with Section 26.
    - .3 Overhead service conductors in accordance with Section 21.
- 3.4 INSTALLATION OF TECK90 CABLE (0-1000 V)
- .1 Group cables wherever possible on channels.
  - .2 Install cable exposed, securely supported by straps or hangers.
-

3.5 INSTALLATION OF .1 Group cables wherever possible on channels.  
ARMOURED CABLES

3.6 INSTALLATION OF .1 Install control cables in conduit cable.  
CONTROL CABLES .2 Ground control cable shield.

## PART 1 - GENERAL

- |  |    |   |
|--|----|---|
| <u>1.1 RELATED SECTIONS</u>              | .1 | Section 01 74 19 - Construction/Demolition Waste Management And Disposal.   |
|  | .2 | Section 26 05 01 - Common Work Results - Electrical.  |
| <u>1.2 REFERENCES</u>                    | .1 | American National Standards Institute (ANSI)/Institute of Electrical and Electronics Engineers (IEEE)<br>.1 ANSI/IEEE 837-1989(R1996), Qualifying Permanent Connections Used in Substation Grounding. |
|  | .2 | Canadian Standards Association, (CSA International)   |
| <u>1.3 WASTE MANAGEMENT AND DISPOSAL</u> | .1 | Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.   |
|  | .2 | Remove from site and dispose of all packaging materials at appropriate recycling facilities.  |
|  | .3 | Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material for recycling in accordance with Waste Management Plan.                                       |
|  | .4 | Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.   |
|  | .5 | Fold up metal banding, flatten and place in designated area for recycling.  |
-

## PART 2 - PRODUCTS

- |                      |    |   |
|----------------------|----|---|
| <u>2.1 EQUIPMENT</u> | .1 | Clamps for grounding of conductor: size as required to electrically conductive underground water pipe.  |
|                      | .2 | Grounding conductors: bare stranded copper, soft annealed, size as indicated.   |
|                      | .3 | Insulated grounding conductors: green, type THW.  |
|                      | .4 | Ground bus: copper, size as indicated, complete with insulated supports, fastenings, connectors.  |
|                      | .5 | Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to: <ul style="list-style-type: none"><li>.1 Grounding and bonding bushings.</li><li>.2 Protective type clamps.</li><li>.3 Bolted type conductor connectors.</li><li>.4 Thermit welded type conductor connectors.</li><li>.5 Bonding jumpers, straps.</li><li>.6 Pressure wire connectors.</li></ul> |

## PART 3 - EXECUTION

- |                         |    |   |
|-------------------------|----|---|
| <u>3.1 INSTALLATION</u> | .1 | Install complete permanent, continuous grounding system including, electrodes, conductors, connectors, accessories. Where EMT is used, run ground wire in conduit.                          |
| <u>GENERAL</u>          | .2 | Install connectors in accordance with manufacturer's instructions.  |
|                         | .3 | Protect exposed grounding conductors from mechanical injury.  |
|                         | .4 | Make buried connections, and connections to conductive water main, electrodes, using permanent mechanical connectors or inspectable wrought copper compression connectors to ANSI/IEEE 837. |
|                         | .5 | Use mechanical connectors for grounding connections to equipment provided with lugs.  |
-

- |     |                                     |     |  |
|-----|-------------------------------------|-----|--|
| 3.1 | INSTALLATION<br>GENERAL<br>(Cont'd) | .6  | Soldered joints not permitted.   |
|     |                                     | .7  | Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.  |
|     |                                     | .8  | Install flexible ground straps for bus duct enclosure joints, where such bonding is not inherently provided with equipment.  |
|     |                                     | .9  | Install separate ground conductor to outdoor lighting standards.   |
|     |                                     | .10 | Connect building structural steel and metal siding to ground by welding copper to steel.   |
|     |                                     | .11 | Make grounding connections in radial configuration only, with connections terminating at single grounding point street side of water pipe. Avoid loop connections.   |
|     |                                     | .12 | Bond single conductor, metallic armoured cables to cabinet at supply end, and load end.  |
|     |                                     | .13 | Ground secondary service pedestals.  |
| 3.2 | SYSTEM AND<br>CIRCUIT GROUNDING     | .1  | Install system and circuit grounding connections to neutral of primary V system, secondary 120/208V system.  |
| 3.3 | EQUIPMENT<br>GROUNDING              | .1  | Install grounding connections to typical equipment included in, but not necessarily limited to following list. Service equipment, transformers, switchgear, duct systems, frames of motors, motor control centres, starters, control panels, building steel work, generators, elevators and escalators, distribution panels, outdoor lighting. |
| 3.4 | GROUNDING BUS                       | .1  | Install copper grounding bus mounted on insulated supports on wall of electrical room.   |
|     |                                     | .2  | Ground items of electrical equipment in electrical room to ground bus with individual bare stranded copper connections size 2/0AWG.  |



3.5 COMMUNICATION SYSTEMS .1 Install grounding connections for telephone, sound, fire alarm, intercommunication systems as follows:  
.1 Telephones: make telephone grounding system in accordance with telephone company's requirements.  
.2 Sound, fire alarm, intercommunication systems as indicated.

3.6 FIELD QUALITY CONTROL .1 Perform tests in accordance with Section 26 05 01 - Common Work Results - Electrical.  
.2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.  
.3 Perform tests before energizing electrical system.  
.4 Disconnect ground fault indicator during tests.

## PART 1 - GENERAL

- |  |    |  |
|--|----|--|
| <u>1.1 RELATED<br/>SECTIONS</u>                  | .1 | Section 01 74 19 - Construction/Demolition Waste Management And Disposal.  |
| <u>1.2 WASTE<br/>MANAGEMENT AND<br/>DISPOSAL</u> | .1 | Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.                              |
|  | .2 | Remove from site and dispose of all packaging materials at appropriate recycling facilities.   |
|  | .3 | Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan. |
|  | .4 | Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.  |
|  | .5 | Fold up metal banding, flatten and place in designated area for recycling.   |

## PART 2 - PRODUCTS

- |                                 |    |  |
|---------------------------------|----|--|
| <u>2.1 SUPPORT<br/>CHANNELS</u> | .1 | U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted and suspended. |
|---------------------------------|----|--|

## PART 3 - EXECUTION

- |                         |    |  |
|-------------------------|----|--|
| <u>3.1 INSTALLATION</u> | .1 | Secure equipment to solid masonry, tile and plaster surfaces with lead anchors or nylon shields. |
|                         | .2 | Secure equipment to poured concrete with expandable inserts.                                     |
|                         | .3 | Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.                |
|                         | .4 | Secure surface mounted equipment with twist clip fasteners to inverted T bar ceilings.           |
-

3.1 INSTALLATION  
(Cont'd)

---

- .4 (Cont'd)  
Ensure that T bars are adequately supported to carry weight of equipment specified before installation.
- .5 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.
- .6 Fasten exposed conduit or cables to building construction or support system using straps.
  - .1 One-hole malleable iron steel straps to secure surface conduits and cables 50 mm and smaller.
  - .2 Two-hole steel straps for conduits and cables larger than 50 mm.
  - .3 Beam clamps to secure conduit to exposed steel work.
- .7 Suspended support systems.
  - .1 Support individual cable or conduit runs with 6 mm dia threaded rods and spring clips.
  - .2 Support 2 or more cables or conduits on channels supported by 6 mm dia threaded rod hangers where direct fastening to building construction is impractical.
- .8 For surface mounting of two or more conduits use channels at 1.5m on centre spacing.
- .9 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
- .10 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
- .11 Do not use wire lashing or perforated strap to support or secure raceways or cables.
- .12 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of Departmental Representative.
- .13 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.

PART 1 - GENERAL

1.1 RELATED .1.  
SECTIONS

1.2 REFERENCES .1 Canadian Standards Association (CSA  
International)  
.1 CSA C22.1-12, Canadian Electrical Code,  
Part 1, 22nd Edition.

1.3 SUBMITTALS .1 Provide submittals in accordance with Section  
01 33 00 - Submittal Procedures.  
.2 Product Data:  
.1 Provide manufacturer's printed product  
literature, specifications and datasheet and  
include product characteristics, performance  
criteria, physical size, finish and  
limitations.  
.3 Provide shop drawings: in accordance with  
Section 01 33 00 - Submittal Procedures.  
.1 Provide drawings stamped and signed by  
professional engineer registered or licensed  
in Province of Newfoundland & Labrador,  
Canada.

1.4 DELIVERY, .1 Waste Management and Disposal:  
STORAGE AND  
HANDLING .1 Separate waste materials for reuse and  
recycling in accordance with Section 01 74 21  
- Construction/Demolition Waste Management and  
Disposal.

---

## PART 2 - PRODUCTS

- |                                    |    |  |
|------------------------------------|----|--|
| <u>2.1 SPLITTERS</u>               | .1 | Construction: sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.   |
|                                    | .2 | Terminations: main and branch lugs to match required size and number of incoming and outgoing conductors as indicated. |
|                                    | .3 | Spare Terminals: minimum three spare terminals or lugs on each connection or lug block sized less than 400 A.          |
| <u>2.2 JUNCTION AND PULL BOXES</u> | .1 | Construction:welded steel enclosure.   |
|                                    | .2 | Covers Flush Mounted: 25 mm minimum extension all around.  |
|                                    | .3 | Covers Surface Mounted: screw-on flat covers.  |

## PART 3 - EXECUTION

- |   |    |  |
|---|----|--|
| <u>3.1 SPLITTER INSTALLATION</u>                          | .1 | Mount plumb, true and square to building lines.  |
|   | .2 | Extend splitters full length of equipment arrangement except where indicated otherwise.                  |
| <u>3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION</u> | .1 | Install pull boxes in inconspicuous but accessible locations.  |
|   | .2 | Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.       |
|   | .3 | Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1. |
-

- 3.3 IDENTIFICATION .1 Equipment Identification: to Section  
2. 05 00- Common Work Results for Electrical
- .2 Identification Labels: size 2  
indicatingsystem name voltage and phase or as  
indicated.

## PART 1 - GENERAL

- |   |    |  |
|---|----|--|
| <u>1.1 REFERENCES</u>                     | .1 | Canadian Standards Association (CSA International)<br>.1 CSA C22.1-12, Canadian Electrical Code, Part 1, 22nd Edition.   |
| <u>1.2 SUBMITTALS</u>                     | .1 | Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.   |
| <u>1.3 DELIVERY, STORAGE AND HANDLING</u> | .1 | Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.   |
|   | .2 | Waste Management and Disposal:<br>.1 Separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal. |

## PART 2 - PRODUCTS

- |   |    |   |
|---|----|---|
| <u>2.1 OUTLET AND CONDUIT BOXES GENERAL</u> | .1 | Size boxes in accordance with CSA C22.1.  |
|   | .2 | 102 mm square or larger outlet boxes as required.   |
|   | .3 | Gang boxes where wiring devices are grouped.  |
|   | .4 | Blank cover plates for boxes without wiring devices.  |
|   | .5 | Combination boxes with barriers where outlets for more than one system are grouped.   |
| <u>2.2 GALVANIZED STEEL OUTLET BOXES</u>    | .1 | One-piece electro-galvanized construction.  |
|   | .2 | Single and multi gang flush device boxes for flush installation, minimum size 76 x 50 x 38 mm or as indicated. 102 mm square outlet boxes |
-

- 2.2 GALVANIZED STEEL OUTLET BOXES (Cont'd)
- .2 (Cont'd)  
when more than one conduit enters one side with extension and plaster rings as required.
  - .3 Utility boxes for outlets connected to surface-mounted EMT conduit, minimum size 102 x 54 x 48 mm.
  - .4 102 mm square or octagonal outlet boxes for lighting fixture outlets.
  - .5 Extension and plaster rings for flush mounting devices in finished tile walls.

- 2.3 MASONRY BOXES
- .1 Electro-galvanized steel masonry single and multi gang boxes for devices flush mounted in exposed block walls.

- 2.4 FITTINGS - GENERAL
- .1 Bushing and connectors with nylon insulated throats.
  - .2 Knock-out fillers to prevent entry of debris.
  - .3 Conduit outlet bodies for conduit up to 35 mm and pull boxes for larger conduits.
  - .4 Double locknuts and insulated bushings on sheet metal boxes.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Support boxes independently of connecting conduits.
  - .2 Fill boxes with paper, sponges or foam or similar approved material to prevent entry of debris during construction. Remove upon completion of work.
  - .3 For flush installations mount outlets flush with finished wall using plaster rings to permit wall finish to come within 6 mm of opening.
  - .4 Provide correct size of openings in boxes for conduit, mineral insulated and armoured cable connections. Do not install reducing washers.
-



- |                              |    |  |
|------------------------------|----|--|
| 3.1 INSTALLATION<br>(Cont'd) | .5 | Vacuum clean interior of outlet boxes before installation of wiring devices. |
|                              | .6 | Identify systems for outlet boxes as required.                               |

## PART 1 - GENERAL

- |  |        |   |
|--|--------|---|
| <u>1.1 REFERENCES</u>                        | .1     | Canadian Standards Association (CSA International)  |
|  | .1     | CAN/CSA C22.2 No. 18-98(R2003), Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware, A National Standard of Canada.                                 |
|  | .2     | CSA C22.2 No. 45-M1981(R2003), Rigid Metal Conduit.   |
|  | .3     | CSA C22.2 No. 56-04, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.  |
|  | .4     | CSA C22.2 No. 83-M1985(R2003), Electrical Metallic Tubing.  |
|  | .5     | CSA C22.2 No. 211.2-M1984(R2003), Rigid PVC (Unplasticized) Conduit.  |
|  | .6     | CAN/CSA C22.2 No. 227.3-05, Nonmetallic Mechanical Protection Tubing (NMPT), A National Standard of Canada (February 2006).                                   |
| <br><u>1.2 SUBMITTALS</u>                    | <br>.1 | <br>Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.  |
|  | .2     | Product data: submit manufacturer's printed product literature, specifications and datasheets.  |
|  | .1     | Submit cable manufacturing data.  |
|  | .3     | Quality assurance submittals:   |
|  | .1     | Test reports: submit certified test reports.  |
|  | .2     | Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties. |
|  | .3     | Instructions: submit manufacturer's installation instructions.  |
| <br><u>1.3 WASTE MANAGEMENT AND DISPOSAL</u> | <br>.1 | <br>Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.             |
|  | .2     | Place materials defined as hazardous or toxic waste in designated containers.   |
|  | .3     | Ensure emptied containers are sealed and stored safely for disposal away from children.   |
-

## PART 2 - PRODUCTS

### 2.1 CABLES AND REELS

- .1 Provide cables on reels or coils.
  - .1 Mark or tag each cable and outside of each reel or coil, to indicate cable length, voltage rating, conductor size, and manufacturer's lot number and reel number.
- .2 Each coil or reel of cable to contain only one continuous cable without splices.
- .3 Identify cables for exclusively dc applications.
- .4 Reel and mark shielded cables rated 2,001 volts and above.

### 2.2 CONDUITS

- .1 Rigid metal conduit: to CSA C22.2 No. 45, galvanized steel threaded.
- .2 Epoxy coated conduit: to CSA C22.2 No. 45, with zinc coating and corrosion resistant epoxy finish inside and outside.
- .3 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .4 Rigid pvc conduit: to CSA C22.2 No. 211.2.
- .5 Flexible metal conduit: to CSA C22.2 No. 56, aluminum and liquid-tight flexible metal.

### 2.3 CONDUIT FASTENINGS

- .1 One hole steel straps to secure surface conduits 50 mm and smaller.
    - .1 Two hole steel straps for conduits larger than 50 mm.
  - .2 Beam clamps to secure conduits to exposed steel work.
  - .3 Channel type supports for two or more conduits at 1.5m on centre.
  - .4 Threaded rods, 6 mm diameter, to support suspended channels.
-

- |                                 |    |   |
|---------------------------------|----|---|
| <u>2.4 CONDUIT<br/>FITTINGS</u> | .1 | Fittings: to CAN/CSA C22.2 No. 18,<br>manufactured for use with conduit specified.<br>Coating: same as conduit. |
|                                 | .2 | Ensure factory "ells" where 90 degrees bends<br>for NPS 1 25 mm and larger conduits.                            |
|                                 | .3 | Watertight connectors and couplings for EMT.<br>.1 Set-screws are not acceptable.                               |

- |   |    |  |
|---|----|--|
| <u>2.5 EXPANSION<br/>FITTINGS FOR RIGID<br/>CONDUIT</u> | .1 | Weatherproof expansion fittings with internal<br>bonding assembly suitable for 200 mm linear<br>expansion.           |
|   | .2 | Watertight expansion fittings with integral<br>bonding jumper suitable for linear expansion<br>and 19 mm deflection. |
|   | .3 | Weatherproof expansion fittings for linear<br>expansion at entry to panel.   |

- |                      |    |                |
|----------------------|----|----------------|
| <u>2.6 FISH CORD</u> | .1 | Polypropylene. |
|----------------------|----|----------------|

PART 3 - EXECUTION

- |  |    |   |
|--|----|---|
| <u>3.1 MANUFACTURER'S<br/>INSTRUCTIONS</u> | .1 | Compliance: comply with manufacturer's<br>written recommendations or specifications,<br>including product technical bulletins,<br>handling, storage and installation<br>instructions, and datasheets. |
|--|----|---|

- |                         |    |   |
|-------------------------|----|---|
| <u>3.2 INSTALLATION</u> | .1 | Install conduits to conserve headroom in<br>exposed locations and cause minimum<br>interference in spaces through which they<br>pass. |
|                         | .2 | Conceal conduits except in unfinished areas.  |
|                         | .3 | Use rigid galvanized steel threaded conduit<br>except where specified otherwise.  |
|                         | .4 | Use electrical metallic tubing (EMT) above<br>2.4 m not subject to mechanical injury.   |
-

3.2 INSTALLATION  
(Cont'd)

---

- .5 Use flexible metal conduit for connection to motors in dry areas and connection to surface or recessed fluorescent fixtures.
- .6 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment in damp, wet or corrosive locations.
- .7 Minimum conduit size for lighting and power circuits: 19 mm.
- .8 Bend conduit cold:
  - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .9 Mechanically bend steel conduit over 19 mm diameter.
- .10 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .11 Install fish cord in empty conduits.
- .12 Run 2 25 mm spare conduits up to ceiling space and 2 25 mm spare conduits down to ceiling space from each flush panel.
  - .1 Terminate these conduits in 152 x 152 x 102 mm junction boxes in ceiling space or in case of an exposed concrete slab, terminate each conduit in flush concrete surface type box.
- .13 Remove and replace blocked conduit sections.
  - .1 Do not use liquids to clean out conduits.
- .14 Dry conduits out before installing wire.

3.3 SURFACE  
CONDUITS

---

- .1 Run parallel or perpendicular to building lines.
  - .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
  - .3 Run conduits in flanged portion of structural steel.
  - .4 Group conduits wherever possible on suspended channels.
  - .5 Do not pass conduits through structural members except as indicated.
-

<u>3.3 SURFACE CONDUITS (Cont'd)</u>	.6	Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.
--	----	--

<u>3.4 CONCEALED CONDUITS</u>	.1	Run parallel or perpendicular to building lines.
	.2	Do not install horizontal runs in masonry walls.
	.3	Do not install conduits in terrazzo or concrete toppings.

<u>3.5 CLEANING</u>	.1	Proceed in accordance with Section 01 74 11 - Cleaning.
	.2	On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Materials and installation for standard and custom breaker type panelboards.
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
	.3	Section 06 10 00.01 - Rough Carpentry - Short Form: Plywood Backboard.
	.4	Section 26 05 00 - Common Work Results - Electrical.
	.5	Section 26 28 21 - Moulded Case Circuit Breakers.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CSA C22.2 No.29-M1989(R2000), Panelboards and enclosed Panelboards.
<u>1.4 SHOP DRAWINGS</u>	.1	Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
	.2	Drawings to include electrical detail of panel, branch breaker type, quantity, ampacity and enclosure dimension.
<u>1.5 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
	.2	Remove from site and dispose of packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.

---

1.5 WASTE  
MANAGEMENT AND  
DISPOSAL  
(Cont'd)

---

- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.

PART 2 - PRODUCTS

2.1 PANELBOARDS

- .1 Panelboards: to CSA C22.2 No.29 and product of one manufacturer.  
.1 Install circuit breakers in panelboards before shipment.  
.2 In addition to CSA requirements manufacturer's nameplate must show fault current that panel including breakers has been built to withstand.
- .2 250 V panelboards: bus and breakers rated for 400 A (symmetrical) interrupting capacity or as indicated.
- .3 Sequence phase bussing with odd numbered breakers on left and even on right, with each breaker identified by permanent number identification as to circuit number and phase.
- .4 Panelboards: mains, number of circuits, and number and size of branch circuit breakers as indicated.
- .5 Two keys for each panelboard and key panelboards alike.
- .6 Copper bus with neutral of same ampere rating as mains.
- .7 Mains: suitable for bolt-on breakers.
- .8 Trim with concealed front bolts and hinges.
- .9 Trim and door finish: baked grey enamel as per colour schedule.

2.2 BREAKERS

- .1 Breakers: to Section 26 28 21 - Moulded Case Circuit Breakers.
- .2 Breakers with thermal and magnetic tripping in panelboards except as indicated otherwise.
- .3 Main breaker: separately mounted on top or bottom of panel to suit cable entry. When
-



- 2.2 BREAKERS  
(Cont'd)
- .3 Main breaker: (Cont'd)  
mounted vertically, down position should open  
breaker.
  - .4 Lock-on devices for 10% of from 15 to 30 A  
breakers installed as indicated. Turn over  
unused lock-on devices to Departmental  
Representative.
  - .5 Lock-on devices for fire alarm, emergency,  
door supervisory, exit and night light  
circuits.

- 2.3 EQUIPMENT  
IDENTIFICATION
- .1 Provide equipment identification in  
accordance with Section 26 05 00 - Common Work  
Results - Electrical.
  - .2 Nameplate for each panelboard size 4 engraved  
as indicated.
  - .3 Nameplate for each circuit in distribution  
panelboards size 2 engraved as indicated.
  - .4 Complete circuit directory with typewritten  
legend showing location and load of each  
circuit.

PART 3 - EXECUTION

- 3.1 INSTALLATION
- .1 Locate panelboards as indicated and mount  
securely, plumb, true and square, to adjoining  
surfaces.
  - .2 Mount panelboards to height specified in  
Section 26 05 00 - Common Work Results -  
Electrical or as indicated.
  - .3 Connect loads to circuits.
  - .4 Connect neutral conductors to common neutral  
bus with respective neutral identified

PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Switches, receptacles, wiring devices, cover plates and their installation.
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
	.3	Section 26 05 01 - Common Work Results - Electrical.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International)
	.1	CSA-C22.2 No.42-99(R2002), General Use Receptacles, Attachment Plugs and Similar Devices.
	.2	CSA-C22.2 No.42.1-00, Cover Plates for Flush-Mounted Wiring Devices (Bi-national standard, with UL 514D).
	.3	CSA-C22.2 No.55-M1986(July 2001), Special Use Switches.
	.4	CSA-C22.2 No.111-00, General-Use Snap Switches (Bi-national standard, with UL 20, twelfth edition).
<u>1.4 SHOP DRAWINGS AND PRODUCT DATA</u>	.1	Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
<u>1.5 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
	.2	Remove from site and dispose of all packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material for recycling in accordance with Waste Management Plan.

---

1.5 WASTE  
MANAGEMENT AND  
DISPOSAL  
(Cont'd)

---

.4 Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

PART 2 - PRODUCTS

2.1 SWITCHES

.1 15 A, 120 V, commercial grade for offices and finished areas, single pole, three-way, switches to: CSA-C22.2 No.55 and CSA-C22.2 No.111.

.2 15 A, 120 V, industrial grade for garage and workshop, single pole, three-way, switches to: CSA-C22.2 No.55 and CSA-C22.2 No.111.

.3 Manually-operated general purpose ac switches with following features:

.1 Terminal holes approved for No. 10 AWG wire.

.2 Silver alloy contacts.

.3 Urea or melamine moulding for parts subject to carbon tracking.

.4 Suitable for back and side wiring.

.5 Ivory toggle.

.4 Toggle operated fully rated for LED filament and fluorescent lamps, and up to 80% of rated capacity of motor loads.

.5 Switches of one manufacturer throughout project.

.6 Acceptable manufacturer: Hubbell.

2.2 RECEPTACLES

.1 Duplex receptacles, commercial grade for offices and finished areas, CSA type 5-15 R, 125 V, 15 A, U ground, to: CSA-C22.2 No.42 with following features:

.1 Ivory urea moulded housing.

.2 Suitable for No. 10 AWG for back and side wiring.

.3 Break-off links for use as split receptacles.

.4 Eight back wired entrances, four side wiring screws.

.5 Triple wipe contacts and rivetted grounding contacts.

---

- 2.2 RECEPTACLES  
(Cont'd)
- .2 Duplex receptacles, industrial grade for garage and workshop, CSA type 5-15 R, 125 V, 15 A, U ground, to: CSA-C22.2 No.42 with following features:
    - .1 Ivory urea moulded housing.
    - .2 Suitable for No. 10 AWG for back and side wiring.
    - .3 Break-off links for use as split receptacles.
    - .4 Eight back wired entrances, four side wiring screws.
    - .5 Triple wipe contacts and rivetted grounding contacts.
  - .3 Other receptacles with ampacity and voltage as indicated.
  - .4 Receptacles of one manufacturer throughout project.
  - .5 Acceptable materials:.
- 2.3 COVER PLATES
- .1 Cover plates for wiring devices to: CSA-C22.2 No.42.1.
  - .2 Cover plates from one manufacturer throughout project.
  - .3 Sheet steel utility box cover for wiring devices installed in surface-mounted utility boxes.
  - .4 Stainless steel, vertically brushed, 1 mm thick cover plates for wiring devices mounted in flush-mounted outlet box.
  - .5 Weatherproof double lift spring-loaded cast aluminum cover plates, complete with gaskets for duplex receptacles as indicated.
-

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Switches:
  - .1 Install single throw switches with handle in "UP" position when switch closed.
  - .2 Install switches in gang type outlet box when more than one switch is required in one location.
  - .3 Mount toggle switches at height in accordance with Section 26 05 01 - Common Work Results - Electrical.
- .2 Receptacles:
  - .1 Install receptacles in gang type outlet box when more than one receptacle is required in one location.
  - .2 Mount receptacles at height in accordance with Section 26 05 01 - Common Work Results - Electrical.
  - .3 Where split receptacle has one portion switched, mount vertically and switch upper portion.
- .3 Cover plates:
  - .1 Protect stainless steel cover plate finish with paper or plastic film until painting and other work is finished.
  - .2 Install suitable common cover plates where wiring devices are grouped.
  - .3 Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.

PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Materials for moulded-case circuit breakers, and ground-fault circuit-interrupters.
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International). .1 CSA-C22.2 No. 5-02, Moulded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, tenth edition, and the second edition of NMX-J-266-ANCE).
<u>1.4 SUBMITTALS</u>	.1	Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
	.2	Include time-current characteristic curves for breakers with ampacity of 30A and over with interrupting capacity of 22,000 A symmetrical (rms) and over at system voltage.
	.3	Letter of authenticity by manufacturer's representative.
<u>1.5 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
	.2	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.
	.3	Separate for recycling, and place in designated containers, Steel, Metal and Plastic waste in accordance with Waste Management Plan.

---

## PART 2 - PRODUCTS

- |   |    |   |
|---|----|---|
| 2.1 BREAKERS<br><u>GENERAL</u>                          | .1 | Moulded-case circuit breakers, and<br>Ground-fault circuit-interrupters to: CSA<br>C22.2 No. 5  |
|   | .2 | Bolt-on moulded case circuit breaker: quick-<br>make, quick-break type, for manual and<br>automatic operation with temperature<br>compensation for 40 degrees C ambient.  |
|   | .3 | Common-trip breakers: with single handle for<br>multi-pole applications.  |
|   | .4 | Magnetic instantaneous trip elements in<br>circuit breakers to operate only when value of<br>current reaches setting.<br>.1 Trip settings on breakers with<br>adjustable trips to range from 3-8 times<br>current rating. |
|   | .5 | Circuit breakers to have minimum 10,000A<br>symmetrical rms interrupting capacity rating.   |
| 2.2 THERMAL<br>MAGNETIC BREAKERS<br><u>DESIGN A</u>     | .1 | Moulded case circuit breaker to operate<br>automatically by means of thermal and magnetic<br>tripping devices to provide inverse time<br>current tripping and instantaneous tripping<br>for short circuit protection.     |
| 2.3 OPTIONAL<br>FEATURES<br><u>                    </u> | .1 | Include:<br><br>.1 On-off locking device.   |
-

PART 3 - EXECUTION

3.1 INSTALLATION .1 Install circuit breakers as indicated in panel schedule.



PART 1 - GENERAL

- |                               |    |   |
|-------------------------------|----|---|
| <u>1.1 SECTION INCLUDES</u>   | .1 | Equipment and installation for ground fault circuit interrupters (GFCI).  |
| <u>1.2 RELATED SECTIONS</u>   | .1 | Section 01 29 83 - Payment Procedures: testing Laboratory Services.   |
|                               | .2 | Section 01 33 00 - Submittal Procedures.  |
|                               | .3 | Section 01 74 19 - Construction/Demolition Waste Management And Disposal.   |
|                               | .4 | Section 01 45 00 - Quality Control.   |
|                               | .5 | Section 26 05 01 - Common Work Results - Electrical.  |
| <u>1.3 PAYMENT PROCEDURES</u> | .1 | Payment for field testing of ground fault equipment performed by Contractor in accordance with Section 01 29 83 - Payment Procedures: Testing Laboratory Services.        |
| <u>1.4 REFERENCES</u>         | .1 | Canadian Standards Association (CSA International)<br>.1 CAN/CSA-C22.2 No.144-M91(R2001), Ground Fault Circuit Interrupters.  |
|                               | .2 | National Electrical Manufacturers Association (NEMA)<br>.1 NEMA PG 2.2-1999, Application Guide for Ground Fault Protection Devices for Equipment.                         |
| <u>1.5 SUBMITTALS</u>         | .1 | Submittals in accordance with Section 01 33 00 - Submittal Procedures.  |
|                               | .2 | Submit product data and shop drawings.  |
|                               | .3 | Submit test report for field testing of ground fault equipment to Departmental Representative and a certificate that system as installed meets criteria specified herein. |
-

1.6 WASTE  
MANAGEMENT AND  
DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Equipment and components for ground fault circuit interrupters (GFCI): to CAN/CSA-C22.2 No.144 NEMA PG 2.2.
- .2 Components comprising ground fault protective system to be of same manufacturer.

2.2 GROUND FAULT  
PROTECTOR UNIT

- .1 Self-contained with 15 A, 120 V circuit interrupter and duplex receptacle complete with:
  - .1 Solid state ground sensing device.
  - .2 Facility for testing and reset.
  - .3 CSA Enclosure 1, flush mounted with stainless steel face plate.

PART 3 - EXECUTION

- |                                  |    |   |
|----------------------------------|----|---|
| <u>3.1 INSTALLATION</u>          | .1 | Do not ground neutral on load side of ground fault relay.   |
|                                  | .2 | Connect supply and load wiring to equipment in accordance with manufacturer's recommendations.  |
| <u>3.2 FIELD QUALITY CONTROL</u> | .1 | Perform tests in accordance with Section 26 05 01 - Common Work Results - Electrical and co-ordinate with Section 01 45 00 - Quality Control if required. |
|                                  | .2 | Arrange for field testing of ground fault equipment by Contractor before commissioning service.   |
|                                  | .3 | Demonstrate simulated ground fault tests.   |

## PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Materials and installation for fused and non-fused disconnect switches.
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 35 29.06 - Health and Safety Requirements.
	.3	Section 01 74 19 - Construction/Demolition Waste Management and Disposal.
	.4	Section 26 05 01 - Common Work Results - Electrical.
	.5	Section 26 28 13.01 - Fuses - Low Voltage.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International).
	.1	CAN/CSA C22.2 No.4-M89 (R2000), Enclosed Switches.
	.2	CSA C22.2 No.39-M89 (R2003), Fuseholder Assemblies.
<u>1.4 SUBMITTALS</u>	.1	Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
<u>1.5 HEALTH AND SAFETY</u>	.1	Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.
<u>1.6 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate waste materials for recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.
	.2	Remove from site and dispose of packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard

---

- |   |   |
|---|---|
| <u>1.6 WASTE<br/>MANAGEMENT AND<br/>DISPOSAL<br/>(Cont'd)</u> | .3 (Cont'd)<br>packaging material for recycling in accordance with Waste Management Plan.<br><br>.4 Separate for recycling and place in designated containers Steel, Metal and Plastic waste in accordance with Waste Management Plan.<br><br>.5 Fold up metal banding, flatten and place in designated area for recycling. |
|---|---|

## PART 2 - PRODUCTS

- |   |   |
|---|---|
| <u>2.1 DISCONNECT<br/>SWITCHES</u>      | .1 Fusible and non-fusible, disconnect switch in CSA Enclosure NEMA 1 for indoor use and NEMA 4x for outdoor use, to CAN/CSA C22.2 No.4 size as indicated.<br><br>.2 Provision for padlocking in off switch position by three locks.<br><br>.3 Mechanically interlocked door to prevent opening when handle in ON position.<br><br>.4 Fuses: size as indicated, in accordance with Section 26 28 13.01 - Fuses - Low Voltage.<br><br>.5 Fuseholders: to CSA C22.2 No.39relocatable and suitable without adaptors, for type and size of fuse indicated.<br><br>.6 Quick-make, quick-break action.<br><br>.7 ON-OFF switch position indication on switch enclosure cover. |
| <u>2.2 EQUIPMENT<br/>IDENTIFICATION</u> | .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.<br><br>.2 Indicate name of load controlled on size 4 nameplate.   |
-

PART 3 - EXECUTION

3.1 INSTALLATION .1 Install disconnect switches complete with  
fuses if applicable.

PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Materials and installation for contactors for system voltages up to 600 V
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
	.3	Section 26 05 01 - Common Work Results - Electrical.
	.4	Section 26 29 03 - Control Devices.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CSA C22.2 No.14-95 (R2001), Industrial Control Equipment.
<u>1.4 PRODUCT DATA</u>	.1	Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
<u>1.5 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
	.2	Remove from site and dispose of all packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.
	.4	Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Departmental Representative.

---

PART 2 - PRODUCTS

- 2.1 CONTACTORS
- .1 Contactors: to CSA C22.2 No.14.
  - .2 Electrically held controlled by pilot devices as indicated and rated for type of load controlled. Half size contactors not accepted.
  - .3 Breaker combination contactor as indicated.
  - .4 Complete with 3 normally open and 3 normally closed auxiliary contacts unless indicated otherwise.
  - .5 Mount in CSA Enclosure NEMA 1 unless otherwise indicated.
  - .6 Mechanical interlock between normally closed and normally open contacts as indicated.
  - .7 Include following options in cover:
    - .1 Red LED indicating lamp.
    - .2 Stop-Start reset pushbutton.
    - .3 Hand-Off-Auto selector switch.
  - .8 Control transformer: in accordance with Section 26 29 03 - Control Devices, in contactor enclosure.
- 2.2 EQUIPMENT IDENTIFICATION
- .1 Provide equipment identification in accordance with Section 26 05 01 - Common Work Results - Electrical.
  - .2 Size 4 nameplate indicating name of load controlled as indicated.
-



PART 3 - EXECUTION

3.1 INSTALLATION .1 Install contactors and connect auxiliary control devices.

# PART 1 - GENERAL

- |  |    |   |
|--|----|---|
| <u>1.1 SECTION INCLUDES</u>              | .1 | Materials and installation for industrial control devices including pushbutton stations, control and relay panels.                |
| <u>1.2 RELATED SECTIONS</u>              | .1 | Section 01 33 00 - Submittal Procedures.  |
|  | .2 | Section 01 74 19 - Construction/Demolition Waste Management And Disposal.   |
|  | .3 | Section 26 05 01 - Common Work Results - Electrical.  |
| <u>1.3 REFERENCES</u>                    | .1 | Canadian Standards Association (CSA International)<br>.1 CSA C22.2 No.14-95(R2001), Industrial Control Equipment.                 |
|  | .2 | National Electrical Manufacturers Association (NEMA)<br>.1 NEMA ICS 1-2001, Industrial Control and Systems: General Requirements. |
| <u>1.4 SHOP DRAWINGS</u>                 | .1 | Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.  |
|  | .2 | Include schematic, wiring, interconnection diagrams.  |
| <u>1.5 QUALITY ASSURANCE</u>             | .1 | Submit to Departmental Representative Consultant one copy of test results.  |
| <u>1.6 WASTE MANAGEMENT AND DISPOSAL</u> | .1 | Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal. |
|  | .2 | Remove from site and dispose of all packaging materials at appropriate recycling facilities.                                      |
-

- |   |    |  |
|---|----|--|
| 1.6 WASTE<br>MANAGEMENT AND<br>DISPOSAL<br>(Cont'd) | .3 | Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan. |
|   | .4 | Divert unused metal and wiring materials from landfill to metal recycling facility as approved by Departmental Representative.                                 |

## PART 2 - PRODUCTS

- |                                  |    |  |
|----------------------------------|----|--|
| 2.1 AC CONTROL<br>RELAYS         | .1 | Control Relays: to CSA C22.2 No.14 and NEMA 1.   |
|                                  | .2 | Sealed contact type: electrically held with 3 poles and front mounted contact block to provide 3 additional poles. Coil rating: as indicated on drawing. Contact rating: as indicated on drawing.                      |
| 2.2 RELAY<br>ACCESSORIES         | .1 | Standard contact cartridges: normally-open - convertible to normally-closed in field.  |
| 2.3 OPERATOR<br>CONTROL STATIONS | .1 | Enclosure: CSA Type1 4, surface flush mounting:  |
| 2.4 PUSHBUTTONS                  | .1 | Standard. Operator flush type, as indicated. Green, with 1-NO and 1-NC contacts rated at 15 A, AC, labels as indicated. Stop pushbuttons coloured red, provision for padlocking in depressed position labelled "stop". |
| 2.5 SELECTOR<br>SWITCHES         | .1 | Maintained Spring return to , 23 position labelled as indicated standard heavy duty oil tight, operators standard knob wing lever cylinder lock, contact arrangement as indicated, rated V, A, AC DC.                  |
-

<u>2.6 INDICATING LIGHTS</u>	.1	Standard LED type, push-to-test, lens colour: red as indicated, supply voltage: 120V, lamp voltage: 120V, labels as indicated.
------------------------------	----	--

<u>2.7 CONTROL AND RELAY PANELS</u>	.1	CSA Type NEMA 1 sheet steel enclosure with hinged padlockable access door, accommodating relays timers, labels, as indicated, factory installed and wired to identified terminals.
-------------------------------------	----	--

### PART 3 - EXECUTION

<u>3.1 INSTALLATION</u>	.1	Install pushbutton stations, control devices and interconnect.
-------------------------	----	--

<u>3.2 FIELD QUALITY CONTROL</u>	.1	Perform tests in accordance with Section 26 05 01 - Common Work Results - Electrical.
	.2	Depending upon magnitude and complexity, divide control system into convenient sections, energize one section at time and check out operation of section.
	.3	Upon completion of sectional test, undertake group testing.
	.4	Check out complete system for operational sequencing.

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 American National Standards Institute (ANSI)
    - .1 ANSI C82.1-04, Lamp Ballasts-Line Frequency Fluorescent Lamp Ballast.
    - .2 ANSI C82.4-02(R2007), Ballasts for High-Intensity-Discharge and Low-Pressure Sodium Lamps Multi Supply Type.
  - .2 American National Standards Institute/Institute of Electrical and Electronics Engineers ( ANSI/IEEE )
    - .1 ANSI/IEEE C62.41-1991, Recommended Practice for Surge Voltages in Low-Voltage AC Power Circuits.
  - .3 ASTM International Inc.
    - .1 ASTM F 1137-00(2006), Standard Specification for Phosphate/Oil and Phosphate/Organic Corrosion Protective Coatings for Fasteners.
  - .4 Canadian Standards Association (CSA International)
  - .5 ICES-005-07, Radio Frequency Lighting Devices.
  - .6 Underwriters' Laboratories of Canada (ULC)
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
    - .2 Provide complete photometric data prepared by independent testing laboratory for luminaires where specified, for review by Departmental Representative.
    - .3 Photometric data to include: VCP Table where applicable spacing criterion.
-

1.2 ACTION AND INFORMATIONAL SUBMITTALS (Cont'd)	.3	Quality assurance submittals: provide following in accordance with Section 01 45 00 - Quality Control. .1 Manufacturer's instructions: provide manufacturer's written installation instructions and special handling criteria, installation sequence, cleaning procedures and maintenance information.
---	----	---

---

1.3 QUALITY ASSURANCE	.1	Provide mock-ups in accordance with Section 01 45 00 - Quality Control.
--------------------------	----	---

---

1.4 DELIVERY, STORAGE AND HANDLING	.1	Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
	.2	Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
	.3	Packaging Waste Management: remove for reuse and return of pallets, crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
	.4	Divert unused metal materials from landfill to metal recycling facility.
	.5	Disposal and recycling of fluorescent lamps as per local regulations.
	.6	Disposal of old PCB filled ballasts.

## PART 2 - PRODUCTS

2.1 LAMPS	.1	As indicated in luminaire schedule on drawings.
-----------	----	---

2.2 FINISHES	.1	Light fixture finish and construction to meet ULC listings and CSA certifications related to intended installation.
--------------	----	---

---

2.3 OPTICAL CONTROL DEVICES .1 As indicated in luminaire schedule on drawings.

2.4 LUMINAIRES .1 As indicated in luminaire schedule on drawings.

PART 3 - EXECUTION

3.1 INSTALLATION .1 Locate and install luminaires as indicated.  
.2 Provide adequate support to suit ceiling system.

3.2 WIRING .1 Connect luminaires to lighting circuits:  
.1 Install flexible or rigid conduit for luminaires as indicated.

3.3 LUMINAIRE SUPPORTS .1 For suspended ceiling installations support luminaires independently of ceiling support luminaires from ceiling grid in accordance with local inspection requirements.

3.4 LUMINAIRE ALIGNMENT .1 Align luminaires mounted in continuous rows to form straight uninterrupted line.  
.2 Align luminaires mounted individually parallel or perpendicular to building grid lines.

3.5 CLEANING .1 Clean in accordance with Section 01 74 11 - Cleaning.  
.1 Remove surplus materials, excess materials, rubbish, tools and equipment.  
.2 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 1 - GENERAL

<u>1.1 SECTION INCLUDES</u>	.1	Materials and installation for emergency lighting systems.
<u>1.2 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
	.3	Section 26 05 21 - Wires and Cables (0-1000 V).
	.4	Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.
<u>1.3 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CSA C22.2 No.141-M1985(R1999), Unit Equipment fo Emergency Lighting.
<u>1.4 SUBMITTALS</u>	.1	Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
	.2	Data to indicate system components, mounting method, source of power and special attachments.
<u>1.5 WASTE MANAGEMENT AND DISPOSAL</u>	.1	Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
	.2	Remove from site and dispose of packaging materials at appropriate recycling facilities.
	.3	Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.
	.4	Divert unused metal and wiring materials from landfill to metal recycling facility approved by Departmental Representative.

---



- |   |    |  |
|---|----|--|
| 1.5 WASTE<br>MANAGEMENT AND<br>DISPOSAL<br>(Cont'd) | .5 | Dispose of unused batteries at official hazardous material collections site approved by Departmental Representative.   |
|   | .6 | Fold up metal banding, flatten and place in designated area for recycling.   |
| 1.6 WARRANTY  | .1 | For batteries, the 12 months warranty period prescribed in subsection GC32.1 of General Conditions "C" is extended to 120 months, with no-charge replacement during the first 5 years and pro-rate charge on the second 5 years. |

## PART 2 - PRODUCTS

- |               |     |  |
|---------------|-----|--|
| 2.1 EQUIPMENT | .1  | Emergency lighting equipment: to CSA C22.2 No.141.   |
|               | .2  | Supply voltage: 120 V, ac.   |
|               | .3  | Output voltage: 24 V dc.   |
|               | .4  | Operating time: 60 min.  |
|               | .5  | Battery: sealed, maintenance free.   |
|               | .6  | Charger: solid state, multi-rate, voltage/current regulated, inverse temperature compensated, short circuit protected with regulated output of plus or minus 0.01V for plus or minus 10% input variations. |
|               | .7  | Solid state transfer circuit.  |
|               | .8  | Low voltage disconnect: solid state, modular, operates at 80% battery output voltage.  |
|               | .9  | Signal lights: solid state, for 'AC Power ON' and 'High Charge'.   |
|               | .10 | Lamp heads: integral on unit and remote, 345 degrees horizontal and 180 degrees vertical adjustment. Lamp type: LED.   |
|               | .11 | Cabinet: suitable for direct or shelf mounting to wall and c/w knockouts for conduit. Removable or hinged front panel for easy access to batteries.  |
-

2.1 EQUIPMENT  
(Cont'd)

- .12 Finish: white.
- .13 Auxiliary equipment:
  - .1 Test switch.
  - .2 Battery disconnect device.
  - .3 AC input and DC output terminal blocks inside cabinet.
  - .4 Bracket.
  - .5 Direct connection for AC.
  - .6 RFI suppressors.

2.2 WIRING OF  
REMOTE HEADS

- .1 Conduit: type, in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.
- .2 Conductors: type in accordance with Section 26 05 21 - Wires and Cables 0-1000 V, sized as indicated in accordance with manufacturer's recommendations.

PART 3 - EXECUTION

3.1 INSTALLATION

- .1 Install unit equipment and remote mounted fixtures.
- .2 Direct heads.
- .3 Connect exit lights to unit equipment.

PART 1 - GENERAL

- 1.1 REFERENCES
- .1 Canadian Standards Association (CSA International)
    - .1 CSA C22.2 No.141-02, Unit Equipment for Emergency Lighting.
    - .2 CSA C860-01(December 2002), Performance of Internally-Lighted Exit Signs.
  - .2 National Fire Protection Association (NFPA)
    - .1 NFPA 101-2006, Life Safety Code.
- 1.2 SUBMITTALS
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Product Data:
    - .1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
  - .3 Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 02 81 01 - Hazardous Materials.
  - .4 Quality Assurance Submittals: submit following in accordance with Section 01 45 00 - Quality Control.
    - .1 Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence, cleaning procedures and.
- 1.3 WASTE MANAGEMENT AND DISPOSAL
- .1 Separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
-

## PART 2 - PRODUCTS

- |                                    |    |   |
|------------------------------------|----|---|
| <u>2.1 SELF-LUMINOUS<br/>SIGNS</u> | .1 | Exit lights: <ul style="list-style-type: none"><li>.1 No power source or wiring required, spark free.</li><li>.2 Constructed: metal and plastic.</li><li>.3 LED Lamps.</li><li>.4 Viewing distance: in accordance with NFPA.</li><li>.5 Green running man.</li><li>.6 Dispose of lights at end of lifespan as Hazardous Waste in accordance with Section 02 81 01 - Hazardous Materials disposal by manufacturer or authorized agent.</li></ul> |
| <u>2.2 DESIGN X1</u>               | .1 | Wall and ceiling mounting.  |
|                                    | .2 | Single and double face.   |
|                                    | .3 | Arrow: right, left or both directions.  |

## PART 3 - EXECUTION

- |  |    |   |
|--|----|---|
| <u>3.1 MANUFACTURER'S<br/>INSTRUCTIONS</u> | .1 | Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets. |
| <u>3.2 INSTALLATION</u>                    | .1 | Install exit lights to manufacturer's recommendations, listing requirements, NFPA standard and local regulatory requirements.   |
|  | .2 | Connect fixtures to exit light circuits.  |
|  | .3 | Connect emergency lamp sockets to emergency circuits.   |
|  | .4 | Ensure that exit light circuit breaker is locked in on position.  |
-

- 3.3 CLEANING .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

PART 1 - GENERAL

<u>1.1 RELATED SECTIONS</u>	.1	Section 01 33 00 - Submittal Procedures.
	.2	Section 01 74 22 - Construction/Demolition Waste Management And Disposal.
	.3	Section 01 78 00 - Closeout Submittals.
	.4	Section 26 05 00 - Common Work Results - Electrical.
<u>1.2 REFERENCES</u>	.1	Canadian Standards Association (CSA International) .1 CSA C22.2 No.46-M1988, Electric Air-Heaters.
	.2	Underwriters' Laboratories (UL) Inc. .1 UL 1042-1994, Electric Baseboard Heating Equipment.
<u>1.3 PRODUCT DATA</u>	.1	Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
	.2	Submit product data sheets for baseboard convectors. Include: .1 Product characteristics. .2 Performance criteria. .3 Mounting methods. .4 Physical size. .5 kW rating, voltage, phase. .6 Cabinet material thicknesses. .7 Limitations. .8 Colour and finish.
	.3	Manufacturer's Instructions: Provide to indicate special handling criteria, i.stallation sequence, cleaning procedures and
<u>1.4 CLOSEOUT SUBMITTALS</u>	.1	Submit operation and maintenance data for baseboard convectors in accordance with Section 01 78 00 - Closeout Submittals.

---

## 1.5 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 22 - Construction/Demolition Waste Management And Disposal, and with Waste Reduction Workplan.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal and wiring materials from landfill to metal recycling facility approved by Engineer Consultant.
- .5 Collect, package and store existing convectors units for either reuse or recycling and return to recycler in accordance with Waste Management Plan.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- .1 Acceptable products:
  - .1 Chromalux Heavy Duty baseboard.
  - .2 Oulette Heavy Duty baseboard.

### 2.2 BASEBOARD CONVECTORS

- .1 Heaters: to CSA C22.2 No.46 UL 1042 low standard high wattage density as indicated with connection box one both ends.
    - .1 Element through-type fitted with aluminum steel, zinc plated convector vanes and resistor wire enclosed in mineral insulation in copper aluminum sheath.
  - .2 Element: locked to cabinet and supported at additional points throughout length to allow for linear expansion with non metallic supports.
  - .3 Cabinet: to CSA C22.2 No.46 UL 1042, pre-drilled back for securing to wall. Integral air diffusion reflector with wireway at bottom and built-in clamps.
    - .1 Bottom inlet/top outlet.
    - .2 Panel: steel aluminum, metal thickness, bottom 1 mm, front 1.6 mm thick.
-

<u>2.2 BASEBOARD CONVECTORS (Cont'd)</u>	.3	Cabinet:(Cont'd) .3 Finish: phosphatized and finished with coats air-dry baked enamel powder coated finish, white colour.
	.4	Blank cabinet sections and outside inside corners complete with wireway in sections including splice plates, to match heater cabinets in respects for continuous baseboard effect as indicated.

<u>2.3 CONTROLS</u>	.1	Wall mounted thermostats: type line voltage pulsating electronic, Energy Star certified.
---------------------	----	---

PART 3 - EXECUTION

<u>3.1 INSTALLATION</u>	.1	Install baseboard convector heaters, blank sections and controls.
	.2	When wireway is used, remove knock-outs and insert insulating bushing between units.
	.3	Install grounding wire to maintain ground integrity between heating, blank, and auxiliary sections.
	.4	Install thermostats in locations indicated.
	.5	Make power and control connections.

<u>3.2 FIELD QUALITY CONTROL</u>	.1	Perform tests in accordance with Section 26 05 00 - Common Work Results - Electrical.
	.2	Ensure heaters and controls operate correctly.



## PART 1 - GENERAL

- |  |    |  |
|--|----|--|
| <u>1.1 RELATED REQUIREMENTS</u>                | .1 | Section 26 05 00 - Common Work Results for Electrical.   |
| <u>1.2 REFERENCES</u>                          | .1 | Canada Green Building Council (CaGBC)<br>.1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System for New Construction and Major Renovations (including Addendum 2007).<br>.2 LEED Canada-NC-2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System for New Construction and Major Renovations 2009.<br>.3 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System for Commercial Interiors.<br>.4 LEED Canada-EB: O&M-2009, LEED (Leadership in Energy and Environmental Design): Green Building Rating System for Existing Buildings: Operations and Maintenance 2009. |
|  | .2 | CSA International<br>.1 CSA C22.2 No.46-M1988(R2006), Electric Air-Heaters.  |
|  | .3 | National Electrical Manufacturers Association (NEMA)<br>.1 NEMA 250-08, Enclosures for Electrical Equipment (1000 V Maximum).  |
| <u>1.3 ACTION AND INFORMATIONAL SUBMITTALS</u> | .1 | Submit in accordance with Section 01 33 00 - Submittal Procedures.   |
|  | .2 | Product Data:<br>.1 Submit manufacturer's instructions, printed product literature and data sheets for unit heaters and include product characteristics, performance criteria, physical size, finish and limitations.  |
|  | .3 | Manufacturer's Instructions: provide to indicate special handling criteria, installation sequence, cleaning procedures and   |
-

- |   |    |  |
|---|----|--|
| 1.3 ACTION AND<br>INFORMATIONAL<br>SUBMITTALS<br>(Cont'd) | .4 | Sustainable Design Submittals:<br>.1 LEED Canada submittals: in accordance with Section 01 35 21 - LEED Requirements.<br>.2 Construction Waste Management:<br>.1 Submit project Waste Management Plan Waste Reduction Workplan highlighting recycling and salvage requirements.<br>.2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating that 50 75% of construction wastes were recycled or salvaged.<br>.3 Building Energy and Water Consumption: submit copy of Measurement and Verification Plan following IPMVP for monitoring of following end-uses. |
| 1.4 CLOSEOUT<br>SUBMITTALS                                | .1 | Submit in accordance with Section 01 78 00 - Closeout Submittals.  |
|   | .2 | Operation and Maintenance Data: submit operation and maintenance data for unit heaters for incorporation into manual.  |
| 1.5 DELIVERY,<br>STORAGE AND<br>HANDLING                  | .1 | Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.  |
|   | .2 | Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.  |
|   | .3 | Storage and Handling Requirements:<br>.1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.<br>.2 Store and protect unit heaters from nicks, scratches, and blemishes.<br>.3 Replace defective or damaged materials with new.   |
|   | .4 | Develop Construction Waste Management Plan Waste Reduction Workplan related to Work of this Section and in accordance with Section 01 35 21 - LEED Requirements.   |
-

1.5 DELIVERY, STORAGE AND HANDLING (Cont'd)	.5	Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan Waste Reduction Workplan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and Section 01 35 21 - LEED Requirements.
--	----	--

PART 2 - PRODUCTS

2.1 UNIT HEATERS	.1	Unit heater: to CSA C22.2 No.46, horizontal discharge complete with adjustable louvers finished to match cabinet vertical discharge radial type cone type with cone diffusers explosion proof.
	.2	Fan type unit heaters with built-in high-heat limit protection, fan-delay switches.
	.3	Fan motor: totally enclosed, permanently lubricated ball bearing sleeve bearing type with resilient mount explosion proof. .1 Built-in fan motor thermal overload protection.
	.4	Hangers: as indicated.
	.5	Elements: mineral insulated copper coated steel steel stainless steel sheath with aluminum, single continuous helical brazed fins.
	.6	Cabinet: aluminum steel, mm thick, fitted with brackets for rod or wall mounting. .1 Phosphatized and finished with coats air-dry baked enamel in colour.

2.2 CONTROLS	.1	Wall mounted thermostats: type low voltage electronic, Energy Star certified.
	.2	Built in thermostat and support controls.

2.3 MANUFACTURERS INSTRUCTIONS	.1	Acceptable products: .1 Chromalox Heavy Duty Unit Heaters .2 Oulette Heavy Duty Unit Heaters.
-----------------------------------	----	---

---

PART 3 - EXECUTION

- 3.1 EXAMINATION .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for unit heaters installation in accordance with manufacturer's written instructions.
- .1 Visually inspect substrate in presence of Departmental Representative DCC Representative Consultant.
- .2 Inform Departmental Representative DCC Representative Consultant of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative DCC Representative Consultant.
- 3.2 INSTALLATION .1 Suspend unit heaters from ceiling or mount on wall as indicated.
- .2 Install thermostats in locations indicated.
- .3 Make power and control connections.
- 3.3 FIELD QUALITY CONTROL .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Test cut-out protection when air movement is obstructed.
- .3 Test fan delay switch to assure dissipation of heat after element shut down.
- .4 Test unit cut-off when fan motor overload protection has operated.
- .5 Ensure heaters and controls operate correctly.
- 3.4 CLEANING .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
- .1 Leave Work area clean at end of each day.
-

- 3.4 CLEANING  
(Cont'd)
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
  - .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal 01 35 21 - LEED Requirements.
    - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.
- 3.5 PROTECTION
- .1 Protect installed products and components from damage during construction.
  - .2 Repair damage to adjacent materials caused by unit heaters installation.