



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
1230 Government Street, Room 401
1230, rue Government, pièce 401
Victoria
British Columbia
V8W 3X4
Bid Fax: (250) 363-3344

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Marktos Harbour Elec. Upgrade	
Solicitation No. - N° de l'invitation F1571-165012/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F1571-165012	Date 2016-07-06
GETS Reference No. - N° de référence de SEAG PW-\$PWY-032-7807	
File No. - N° de dossier PWY-6-39043 (032)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-12	
Time Zone Fuseau horaire Pacific Daylight Saving Time PDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Large, Kathy(pwy)	Buyer Id - Id de l'acheteur pwy032
Telephone No. - N° de téléphone (250) 216-4455 ()	FAX No. - N° de FAX (250) 363-0395
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Marktos Small Craft Harbour - Flores Island, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1571-165012/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
003
File No. - N° du dossier

Buyer ID - Id de l'acheteur
PWY032
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Vous trouverez l'addenda n° 2 ci-joint.
Les autres conditions ne changent pas.

**Marktosis Electrical Construction
Addendum #2**

Page 1 of 1

Response to Bidders' Inquiries:

Please find below a response to bidder's inquiries received to date.

Q1 – There is potential for interference between buried PVC duct and meter box, please clarify this connection.

A1: Delete PVC duct shown on drawing E1 between service pole and approach. Employ direct burial of Teck cable as specified on drawing E2

Q2 - Please clarify transformer type

A2: Drawing E2 identifies TX-A, TX-B, TX-C. Clarify all transformers are to be stainless housing, epoxy filled, copper wound

Q3 – Please clarify type of bus in panels

A3: Drawing E2 identifies panels, including Main Distribution, RC, TC, etc. Clarify all panelboards on this project to be copper bussed.

Q4 – Please clarify type of material for brackets and light standards

A4: Drawing CE45R14/CE45R20 includes a note indicating "NOTE: ALL BRACKETS, BOLTS & FASTENERS TO BE MARINE GRADE TYPE 316 STAINLESS STEEL". Delete the word "BRACKET" from this note.

All materials for light pole assemble, and ITEM 5 side mount bracket, to be as per the table on dwg CE45R14/CE45R20 and metals treated HDG

Q5 - For lighting, can an alternate be for cabinets: lumark quad cast led parking garage and canopy lights, and for the pole led lights: Philips 90w48led4kr le5 type v 90w

A5: These alternates are not acceptable as specified.