



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Brighton Road Swing Bridge	
Solicitation No. - N° de l'invitation EQ754-170012/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client R.059792.204	Date 2016-07-06
GETS Reference No. - N° de référence de SEAG PW-\$PWL-035-2161	
File No. - N° de dossier PWL-6-39002 (035)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-12	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Woodhall, Lauren	Buyer Id - Id de l'acheteur pwl035
Telephone No. - N° de téléphone (416) 512-5873 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC-TPSGC Joseph Shepard Building 32 4900 Yonge Street Toronto, ON M2N 6A6	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

N° de l'invitation - Sollicitation No.
EQ754-170012/A
N° de réf. du client - Client Ref. No.
R.059792.204

N° de la modif - Amd. No.
Amd 004
File No. - N° du dossier
PWL-6-39002

Id de l'acheteur - Buyer ID
pwl035
N° CCC / CCC No./ N° VME - FMS

Solicitation Amendment 004

This amendment is raised to respond to proponent questions and to incorporate changes to the following section of the RFP: Project Brief.

Revisions to Request for Proposal

- (i) Reference: Project Brief, Required Services (RS), RS 6 Design Concept, 6.7 Overall project Objectives/Goals, article g)

Proponents are hereby instructed to:

Delete: In its entirety.

Insert: Provide new mechanical, hydraulic, electrical and control equipment and wiring/piping as required for 75-year bridge life expectancy and low-maintenance, trouble-free operation. Propose at least two fully automatic operation/control alternatives, with at least one based on PLC controls. The User Department will provide input and guidance on the selection of standardised components for the swing bridge mechanisms, hydraulic components, electrical and control equipment;

- (ii) Reference: Project Brief, Required Services (RS), RS 6 Design Concept, 6.7 Overall project Objectives/Goals, article i)

Proponents are hereby instructed to:

Delete: In its entirety.

Insert: Provide traffic gates, signs, signalization, lighting, etc. The User Department will provide input and guidance on the selection of standardized electrical system and controls, traffic control system, traffic gate system and power distribution system;

N° de l'invitation - Solicitation No.
EQ754-170012/A
N° de réf. du client - Client Ref. No.
R.059792.204

N° de la modif - Amd. No.
Amd 004
File No. - N° du dossier
PWL-6-39002

Id de l'acheteur - Buyer ID
pwl035
N° CCC / CCC No./ N° VME - FMS

Questions and Answers

Q13. We would like to get a clarification on the "PCA standards currently in preparation" referred in RS6, 6.7 Overall Project Objectives/Goals: g) and i) of the RFP on page 40.

A13. The requirement has been amended, see above.

Q14. On RFP page 11, section 4. Electrical and Control System, b) ii) Buried electrical lines.

Could you please clarify if this is a conduit or a submarine cable, which provides power connection to the pivot pier.

A14. There are two 6-3 lines that run from the main building to the centre pier. They are Teck cable that lay on the bottom of the canal and are sandbagged down.

There are also two 20 conductor wires that run from the Kiosk across the canal and are also sandbagged down.

The one 20 conductor stops at the centre pier for controls.

The second 20 conductor runs up the centre pier, is protected across the top with a metal guard and continues across the bottom of the canal to the lights and traffic gate on the north side of the canal.

All other terms and conditions of the solicitation remain the same.