



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions**  
**Travaux publics et Services gouvernementaux**  
**Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Fire Alarm System Replacement	
<b>Solicitation No. - N° de l'invitation</b> EZ899-170601/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2016-07-07
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-019-7815	
<b>File No. - N° de dossier</b> PWY-6-39061 (019)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-07-22</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ngan, Ken (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy019
<b>Telephone No. - N° de téléphone</b> (604) 658-2755 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> CSC - William Head institution - Metchosin, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Les documents français seront disponibles sur demande.**

This Solicitation Amendment 001 is raised to incorporate Questions and Answers received.

All other terms and conditions remain unchanged.

Q1.) Will the site annunciator in building 104 be a large LCD style only? No LEDs?

A1.) Yes, the intent is for the site annunciator within Building 104 to be the large LCD type with annunciation of alarms and troubles to be via multi-line LCD text. LEDs may be used for incidental purposes such as indication of power-on condition.

Q2.) Buildings 101, 103, 104, 105, 106 & 109 show FAAs. Other than the one in 109 that requires control, will these be strictly LED style with zone labels?

A2.) The annunciators in buildings 101, 103, 104 (annunciator at the front door), 105, 106 & 109 (outdoor annunciator) shall be equipped with LED indication with no controls.

Q3.) Buildings 101 and 103 appear to have annunciators on the exterior of these buildings. Is this correct?

A3.) Buildings with annunciators classified as "Outdoor Annunciators" that are also on the exterior of the building include Buildings 101, 103, 105 and 109. Note the requirement for special weatherproof enclosures for these outdoor annunciators, as referenced within the specification.

Q4.) Can existing explosion proof heat detectors (5 TOTAL) and pull station (1 TOTAL) be reconnected via monitor modules or will they need to be replaced?

A4.) New fire alarm devices are required for these locations.

Q5.) Can the existing 4100U FA panels in NUA, NUB, NUC, NUE and NUF be reused if a Simplex system is chosen? They are all quite new and modern technology.

A5.) No, new fire alarm panels are required for these buildings.

Q6.) Are the drawings notes for building 108 an error. It appears that the notes belong to building 103.

A6.) Yes, notes for Building 103 were added to Building 108 by mistake. The notes for Building 108 will be provided in an Addendum.