



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Catamaran Breakwater Installation	
Solicitation No. - N° de l'invitation F1571-165017/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F1571-165017	Date 2016-07-08
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7809	
File No. - N° de dossier PWY-6-39052 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-19	
Time Zone Fuseau horaire Pacific Daylight Saving Time PDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Ucluelet Harbour Authority - Ucluelet, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1571-165017/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-6-39062

CCC - FMS No./N° VME

Amendment 003 is raised to extend the bid closing date and to issue Addendum #002.

Please find Addendum #002 herein.

All other terms and conditions remain unchanged.

Extension of Time for Tenderers

Catamaran Breakwater Installation
Ucluelet West Outer Small Craft Harbour, Ucluelet, B.C
Solicitation No: F1571-165017/A

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.D.T. on July 13, 2016 is hereby extended to **2:00 p.m. P.D.T. on July 19, 2016.**

All other terms and conditions remain unchanged.

Addendum 002

Catamaran Breakwater Installation
Solicitation: F1571-165017/A

The following changes/clarifications in the tender documents are effective immediately.
This addendum will form part of the contract documents.

Addendum 002 is raised to:

- 1) Provide answers to bidder questions.

- 1) Provide answers to bidder questions.

Q1) In regards to the pipe piles specified for this tender, they are proving impossible to find in straight seam, Would spiral pipe of the same grade be acceptable?

A1) Spiral welded pipe piles of the same grade will be accepted. If protruding weld seams are wearing on the UHMWPE wear strips within the pile wells, the Contractor shall grind the weld areas flush with the pipe surface.

Q2) For the anodes attached to each pile, shown in Anode Installation Instructions Drawing. Does the client supply the entire anode set up, including the wire rope, clamps, plate and guide?

A2) Anode, wire rope, clamp, and plate will be provided by the Owner. Guide will be provided by the Contractor.

Q3) Section 31 62 16.19 Steel Piles, Part 23.1, Materials 2.1.1 States, "...12.7mm thick, painted straight seam steel pipe pile...". While amendment No. 2 clarified the wall thickness of the piles, this line states that the piles are painted while other specifications in the documents state that the piles are unpainted. Which is correct?

A3) Piles will not be painted.

Q4) Will the client provide a surveyor, on site, to position the floats and piles?

A4) Contractor is responsible for positioning the piles and catamarans as per drawings and specifications. On site Department Representative/ Engineer will confirm pile completion and final location of catamaran.

Q5) Drawing 003, REV. A, Detail B shows a 12mm plate bracket "for future attachment of anode wire". Is this in addition to the single anodes hanging from each pile or for a separate anode, for another time?

A5) This is the plate that will be provided by the Owner shown in Anode Installation Instructions drawing.

Q6) When will the 2x catamaran floats be ready for delivery in Port Alberni?

A6) Upon award of the contract.

Q7) Will these 2x catamaran floats need to be picked off land, by the contractor, or will they be in the water, ready for tow?

A7) Catamarans will be in the water ready for tow.

Q8) Will the client provide a temporary location to secure the 2x catamaran floats, in Ucluelet Harbour?

A8) No.

Q9) Will you grant an extension for the close date of this tender to July 20th, 2016?

A9) Extension of tender closing dates will be considered, if justified, and posted on the buyandsell.gc.ca website. Please check the buyandsell.gc.ca website regularly for amendments to the solicitation and for changes to the bid closing date.

All other terms and conditions remain unchanged

End of Addendum 002

Solicitation No. - N° de l'invitation
F1571-165017/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-6-39062

CCC - FMS No./N° VME

NOTE TO TENDERERS: Use the mailing label below and affix it securely to the outside of the envelope or package containing your tender. Always ensure your company name, return address, tender number and closing date appear legibly on the outside of your bid submission.

**REAL PROPERTY CONTRACTING
Public Works & Government Services Canada
219- 800 Burrard Street
Vancouver, B.C. V6Z 0B9**

Requisition No.: F1571-165017/A

Tender Closing Date & Time: July 19, 2016 @ 2:00pm P.D.T.

Project Description: Catamaran Breakwater Installation
Ucluelet West Outer Small Craft Harbour, Ucluelet, B.C

TL