



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Public Address System, DJM Bldg PEI	
Solicitation No. - N° de l'invitation 51019-164004/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 51019-164004	Date 2016-07-12
GETS Reference No. - N° de référence de SEAG PW-\$PWB-101-3894	
File No. - N° de dossier PWB-6-39016 (101)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-19	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lomax, Sandra	Buyer Id - Id de l'acheteur pwb101
Telephone No. - N° de téléphone (506) 636-4362 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. three (3) is raised to include the following Addendum No. three (3).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Question and Answers

Q1. Can the existing vertical pathways in the stacked data room can be used?

A1. No, the vertical conduit can be used in the stacked electrical rooms on each floor.

Q2. Can the existing a space be used in the existing racks in each data room on each floor to house equipment? If existing Rackspace is not available can a wall mount rack be placed in every Data room?

A2. New racks must be installed to house the PA system wiring and these racks must be place to not affect access to the IT cabinets.

Q3. Is power available in each data room for installed equipment? If not is there a spare way on each of the existing power distribution boards in the data rooms? Are these power distribution boards currently backed up UPS?

A3. Power must be sourced or installed through the electrical rooms on each floor to ensure a "locked on" dedicated circuit for the system.

Q4. Confirmation of the zones required for announcements within the building?

A4. All speakers must have the ability to be independently controlled.

Q5. What interface is required for the announcements from a remote location?

A5. This tenor is not for remote location activation and control, the software being used must simply have this ability.

Q6. Speaker quantities on RFP document do not match floor plans. Please confirm quantities, including additional speakers on Floor 6 and the additional speaker requirement discussed for Floor 1 on the site walk.

A6. Garage – 7 speakers
Floor 1 – 13 speakers inside
Floor 2 – 10 speakers
Floor 3 – 15 speakers
Floor 4 – 6 speakers
Floor 5 – 5 speakers

Additional speakers required that were not on the RFP:

1. One more speaker in the Communications area on the first floor (Public Programming & Communications Area);
2. One speaker outside Kent Street Entrance;
3. One speaker outside Grafton Street Public entrance;
4. One speaker outside employee entrance in garden area; and
5. One speaker at vehicle entry point on Grafton Street;
6. One speaker at vehicle entry point on Kent Street; and
7. Two speakers in pent house.

Solicitation No. - N° de l'invitation
51019-164004A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwb101

Client Ref. No. - N° de réf. du client
51019-164004

File No. - N° du dossier
PWB-6-39016

CCC No./N° CCC - FMS No./N° VME

Total of 8 additional speakers from original RFP. This brings the total number of speakers required to 64 speaker units.

Q7. Can the speakers denoted as Atrium/Common Areas be defined?

A7. There are only two Atrium/Common area speakers. They are clearly defined on the floor 1 plans heading towards the Grafton and Kent Street entrances.

Q8. Can plans be provided for Floor 6 "Penthouse"?

A8. No, there is no floor plan for this level of the facility available to provide.