



Parks  
Canada

Parcs  
Canada



# TENDER AMENDMENT

## RETURN BIDS TO:

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3  
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

## Issuing Office:

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

# MODIFICATION D'APPEL D'OFFRES

## RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300,  
Calgary, AB T2P 3M3  
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

## Bureau de distribution :

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300  
Calgary (AB) T2P 3M3

### Title:

Johnston Canyon Day Use Area Parking Lot Rehabilitation, Banff National Park

**Solicitation No.: / N°  
de l'invitation :**  
5P420-16-5086/A

**Amendment No.: / N°  
de modification de  
l'invitation :**  
003

**Date:**  
July 12, 2016  
**Date :**  
12 juillet 2016

**GETS Reference No.: / N° de référence de SEAG :**  
PW-16-00735184

### Solicitation Closes: / L'invitation prend fin :

**At:**  
02:00 PM

**On:**  
July 14, 2016

**Time Zone:**  
Mountain Daylight Time (MDT)

**À :**  
14h00

**Le :**  
14 juillet 2016

**Fuseau horaire :**  
Heure avancée des Rocheuses  
(HAR)

**Address Inquiries to: / Adresser toute demande de renseignements à :**  
Nicole Levesque-Welch

**Telephone No.: / N°  
de téléphone :**  
(403) 292-4691

**Fax No.: / N° de  
télécopieur :**  
(403) 292-4475

**Email Address: / Courriel :**  
[nicole.levesque-  
welch@pc.gc.ca](mailto:nicole.levesque-welch@pc.gc.ca)

### TO BE COMPLETED BY THE BIDDER (type or print)

**Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur**

**Address - Adresse**

**Name of person authorized to sign on behalf of the Vendor/Firm  
Nom de la personne autorisée à signer au nom du fournisseur/de  
l'entrepreneur**

**Title - Titre**

**Signature**

**Date**



### AMENDMENT 003

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5086/A:

Q13. Is there an option to use galvanized mild steel, rather than stainless steel for the kiosk and gateway concrete to timber supports?

A13. The steelwork for all timber structures shall be stainless steel 316.

Q14. I see that 033000 - CAST IN PLACE CONCRETE; Page. 2 of 7 / 2.1.15 calls for a few crystalline waterproofing grouts. I would like to request the consideration of our **CEM-KOTE CW PLUS** or **CEM-KOTE FLEX CR** (chemically resistant version) for alternate approval going forward.

A14. The proposed alternate is acceptable.

*All other terms and conditions remain the same.*