



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Catamaran Breakwater Installation	
Solicitation No. - N° de l'invitation F1571-165017/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F1571-165017	Date 2016-07-15
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7809	
File No. - N° de dossier PWY-6-39052 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-19	
Time Zone Fuseau horaire Pacific Daylight Saving Time PDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Ucluelet Harbour Authority - Ucluelet, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 005 is raised to issue Addendum #004.

Les documents français seront disponibles sur demande.
Vous trouverez l'addenda n° 4 ci-joint.
Les autres conditions ne changent pas.

Addendum 004
Catamaran Breakwater Installation
Solicitation: F1571-165017/A

The following changes/clarifications in the tender documents are effective immediately.
This addendum will form part of the contract documents.

Addendum 004 is raised to:

- 1) Provide answers to bidder questions.

- 1) Provide answers to bidder questions.

Q1) How are the 16x anodes fastened to the catamaran float?

A1) Anodes will be secured to the catamaran with 1" galv screw pin shackles supplied by Contractor.

Q2) Who is fabricating the catamaran floats?

A2) Pacific Industrial & Marine.

Q3) Is it possible to have the pile well frames welded to the catamaran float during fabrication?

A3) Cold galvanizing will be accepted on weld areas of pile well frame. Field welding of pile well frame is required to ensure that all pile come to bear evenly.

All other terms and conditions remain unchanged

End of Addendum 004