

PART 1 GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 26 05 00.

1.2 REFERENCE STANDARDS

- .1 CSA International
- .1 CAN/CSA-Z809, last current edition, Sustainable Forest Management.
- .2 Forest Stewardship Council (FSC)
- .1 FSC-STD-01-001, last current edition, FSC Principle and Criteria for Forest Stewardship.
- .3 Insulated Cable Engineers Association, Inc. (ICEA)
- .4 Sustainable Forestry Initiative (SFI)
- .1 SFI Standard, last current edition.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
- .1 Submit manufacturer's instructions, printed product literature and data sheets for conduits and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .2 Storage and Handling Requirements:
- .1 Store materials in dry location, off ground, indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
- .2 Store and protect conduits and pull boxes from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.

PART 2 PRODUCT

2.1 CONDUITS PROTECTION

- .1 38 x 140 mm planks pressure treated with naphthénate copper or 5% pentachlorophénol clear solution.

2.2 MARKERS

- .1 Concrete type cable markers: 600 x 600 x 100 mm with word «conduit» impressed in top surface, with arrows to indicate change in direction of conduits.

PART 3 EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for conduit installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 MARKERS

- .1 Mark cable every 20 m along conduits and changes in direction.
- .2 Mark underground splices.
- .3 Where markers are removed to permit installation of additional cables, reinstall existing markers.

3.3 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform tests using qualified personnel.
 - .1 Include necessary instruments and equipment.

3.4 CLEANING

- .1 Progress Cleaning:
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment.

3.5 PROTECTION

- .1 Repair damage to adjacent materials caused by cables installation.

END OF SECTION