

PART 1 GENERAL

1.1 REFERENCE STANDARDS

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers International (ASME)
 - .1 ANSI/ASME B16.15, Cast Bronze Threaded Fittings, Classes 125 and 250.
 - .2 ANSI/ASME B16.18, Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ANSI/ASME B16.22, Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
 - .4 ANSI/ASME B16.24, Cast Copper Alloy Pipe Flanges and Flanged Fittings, Class 150, 300, 400, 600, 900, 1500 and 2500.
- .2 ASTM International Inc.
 - .1 ASTM A307, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .2 ASTM A536, Standard Specification for Ductile Iron Castings.
 - .3 ASTM B88M, Standard Specification for Seamless Copper Water Tube (Metric).
- .3 American National Standards Institute/American Water Works Association (ANSI)/(AWWA)
 - .1 ANSI/AWWA C111/A21.11, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .4 Canadian Standards Association (CSA International)
 - .1 CSA B242, Groove and Shoulder Type Mechanical Pipe Couplings.
- .5 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Protection Act, 1999, c. 33 (CEPA).
- .6 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .7 Manufacturer's Standardization Society of the Valve and Fittings Industry (MSS)
 - .1 MSS-SP-67, Butterfly Valves.
 - .2 MSS-SP-70, Grey Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-71, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
 - .4 MSS-SP-80, Bronze Gate, Globe, Angle and Check Valves.
- .8 National Research Council (NRC)
 - .1 National Plumbing Code of Canada (NPC).

PART 2 PRODUCT

2.1 PIPING

- .1 Domestic hot, cold, and recirculation systems, located inside the building.
 - .1 To be installed aboveground: hard-drawn copper tube, type L: conform to ASTM B88M.
 - .2 To be buried or embedded: soft-annealed copper tube, type K: conform to ASTM B88M, in chunks of long lengths and with no buried joints in the buried part.

2.2 FITTINGS

- .1 Bronze pipe flanges and flanged fittings, Class 150: conform to ANSI/ASME B16.24.
- .2 Cast bronze threaded fittings, Class 125: conform to ANSI/ASME B16.15.
- .3 Cast copper, solder type: conform to ANSI/ASME B16.18.
- .4 Wrought copper and copper alloy, solder type: conform to ANSI/ASME B16.22.
- .5 NPS 2 or larger: conform to ANSI/ASME B16.18 or ANSI/ASME B16.22 roll grooved to CSA B242.
- .6 NPS 1 ½ or smaller: wrought copper conform to ANSI/ASME B16.22 or cast copper conform to ANSI/ASME B16.18; with stainless steel internal components and EPDM seals. Suitable for operating pressure to 1380 kPa.

2.3 JOINTS

- .1 Rubber gaskets: conform to AWWA C111.
- .2 Hex head bolts, nuts, and washers: conform to ASTM A307, heavy series.
- .3 Solder: tin copper alloy 95/5.
- .4 Teflon tape: for screwed joints.
- .5 Grooved couplings: designed with angle bolt pads to provide rigid joint, complete with EPDM gasket.
- .6 Dielectric fittings between dissimilar metals: completed with thermoplastic liner.

2.4 SWING CHECK VALVES

- .1 NPS 2 or smaller, to be soldered:
 - .1 Conform to MSS-SP-80, Class 125, 860 kPa, bronze body, bronze swing disc, screw in cap, regrindable seat.
- .2 NPS 2 or smaller, to be screwed:
 - .1 Conform to MSS-SP-80, Class 125, 860 kPa, bronze body, bronze swing disc, screw in cap, regrindable seat.

2.5 BALL VALVES

- .1 NPS 2 or smaller, to be screwed:
 - .1 Class 150.
 - .2 Bronze body, stainless steel ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle.
- .2 NPS 2 or smaller, to be soldered:
 - .1 Conform to ANSI/ASME B16.18, Class 150.
 - .2 Bronze body, stainless steel ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle, with NPT conform to copper adaptors.

PART 3 EXECUTION

3.1 APPLICATION

- .1 Manufacturer's instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, as well as datasheets.

3.2 INSTALLATION OF PIPEWORK

- .1 Install the pipe work in accordance with NPC.
- .2 Install the pipe work in accordance with Section 23 05 05 – Installation of Pipework, supplemented as specified herein.
- .3 Assemble piping using fittings manufactured conform to ANSI standards.
- .4 Install CWS piping below and away from HWS and HWC and other hot piping so as to maintain temperature of cold water as low as possible.
- .5 Connect to fixtures and equipment in accordance with manufacturer's and other written instructions unless otherwise indicated.
- .6 Tubing to be buried:
 - .1 Lay in well compacted washed sand bedding in accordance with AWWA Class B.
 - .2 Bend the tubing without folding or reducing its useful section. Minimize the use of fittings.

3.3 VALVES

- .1 Isolate diversion pipes and the supply lines of the sanitary equipment, branches with gate, butterfly, or ball valves.

3.4 PRESSURE TESTS

- .1 Test pressure: must be as the highest of the following values or 860 kPa or the maximum system operating pressure.

3.5 FLUSHING AND CLEANING

- .1 Rinse entire system for 8 hours. Rinse the water outlets for 2 hours.

3.6 PRE-START-UP INSPECTIONS

- .1 Make sure that all system elements are completed prior to rinsing, testing, and start-up.
- .2 Make sure that the system can be completely emptied.
- .3 Make sure that boosters are operating properly.
- .4 Make sure that pneumatic air chambers and expansion compensators are installed properly.

3.7 START-UP

- .1 Start-up of the system after:
 - .1 Hydrostatic tests have been completed.
 - .2 Rinsing and cleaning have been completed.
- .2 Provide continuous supervision during the entire start-up.
- .3 Start-up procedures:
 - .1 Establish circulation and ensure that air is eliminated.
 - .2 Check pressurization to ensure proper operation and to prevent water hammer, flashing and/or cavitation.
 - .3 Bring HWS storage tank up to design temperature slowly.
 - .4 Monitor piping HWS and HWC piping systems for freedom of movement, pipe expansion as designed.
 - .5 Check control, limit, and safety devices for normal and safe operation.
- .4 Rectify start-up deficiencies.

END OF SECTION