

PART 1 GENERAL

1.1 REFERENCE STANDARDS

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE).
- .2 ASTM International.
 - .1 ASTM A480/A480M, Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
 - .2 ASTM A635/A635M, Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Hot-Rolled, Alloy, Carbon, Structural, High-Strength Low-Alloy, and High-Strength Low-Alloy with Improved Formability, General Requirements for.
 - .3 ASTM A653/A653M, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
- .3 Green Seal Environmental Standards (GS).
 - .1 GS-36, Standard for Adhesives for Commercial Use.
- .4 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA HVAC Duct Construction Standards—Metal and Flexible.
 - .2 SMACNA HVAC Air Duct Leakage Test Manual.
 - .3 IAQ Guideline for Occupied Buildings Under Construction.
- .5 South Coast Air Quality Management District (SCAQMD).
 - .1 SCAQMD Rule 1168, Adhesives and Sealants Applications.

PART 2 PRODUCT

2.1 SEAL CLASSIFICATION

- .1 Classification as follows:

Maximum Pressure (Pa)	SMACNA Seal Class
0-500	C

- .2 Seal classification:
 - .1 Class C: transverse joints and connections made air tight with tape or combination thereof sealant and gaskets. Longitudinal seams unsealed.

2.2 SEALANT

- .1 Sustainability Characteristics:
- .2 Sealant: oil resistant, water borne or polymer type flame resistant duct sealant. Temperature range of -30°C to +93°C.
 - .1 Duro-Dyne S-2.

2.3 TAPE

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.
 - .1 Duro-Dyne FT-2.

2.4 DUCT LEAKAGE

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.

2.5 FITTINGS

- .1 Fabrication: conform to SMACNA.
- .2 Radiused elbows:
 - .1 Rectangular: centreline radius: 1.5 times width of duct.
 - .2 Round: centreline radius: 1.5 times diameter.
- .3 Mitred elbows, rectangular:
 - .1 To 400 mm: with double thickness turning vanes.
 - .2 Over 400 mm: with double thickness turning vanes.
- .4 Branches:
 - .1 Rectangular main and branch: with 45° entry on branch, radius on branch 1.5 times width of duct.
 - .2 Round main and branch: enter main duct at 45° with conical connection.
 - .3 Provide volume control damper in branch duct near connection to main duct.
 - .4 Main duct branches: with splitter damper.
- .5 Transitions:
 - .1 Diverging: 20° maximum included angle.
 - .2 Converging: 30° maximum included angle.
- .6 Offsets:
 - .1 As indicated radiused elbows.
- .7 Obstruction deflectors: maintain full cross-sectional area.
 - .1 Maximum included angles: as for transitions.

2.6 FIRE STOPPING

- .1 Retaining angles around duct on both sides of fire separation.
- .2 Fire stopping material and installation must not distort duct.

2.7 GALVANIZED STEEL

- .1 Lock forming quality: conform to ASTM A653/A653M, Z90 zinc coating.
- .2 Thickness, fabrication, and reinforcement: conform to ASHRAE and SMACNA.

- .3 Joints: conform to SMACNA and ASHRAE. Proprietary manufactured flanged duct joint to be considered to be an A class seal.

2.8 HANGERS AND SUPPORTS

- .1 Hangers and Supports:
- .1 Strap hangers: of same material as duct but next sheet metal thickness heavier than duct.
- .1 Maximum size duct supported by strap hanger: 500.
- .2 Hanger configuration: conform to SMACNA and ASHRAE.
- .3 Hangers: conform to following table, ASHRAE, and SMACNA:

Duct Size (mm)	Angle Size (mm)	Rod Size (mm)
up to 750	25 x 25 x 3	6
751 to 1050	40 x 40 x 3	6
1051 to 1500	40 x 40 x 3	10
1501 to 2100	50 x 50 x 3	10
2101 to 2400	50 x 50 x 5	10
2401 and over	50 x 50 x 6	10

- .4 Upper hanger attachments:
- .1 For concrete: manufactured concrete inserts.
- .2 For steel joist: manufactured joist clamp.
- .3 For steel beams: manufactured beam clamps:

PART 3 EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for metal duct installation in accordance with manufacturer's written instructions.

3.2 GENERAL

- .1 Do work in accordance with ASHRAE and SMACNA.
- .2 Do not break continuity of insulation vapour barrier with hangers or rods.
- .3 Support risers in accordance with SMACNA and ASHRAE.
- .4 Install breakaway joints in ductwork on sides of fire separation.
- .5 Install proprietary manufactured flanged duct joints.

3.3 HANGERS

- .1 Strap hangers: install in accordance with SMACNA.
- .2 Angle hangers: complete with locking nuts and washers.

- .3 Hanger spacing: in accordance with ASHRAE and SMACNA as follows:

Duct Size (mm)	Spacing (mm)
to 1500	3000
1501 and over	2500

3.4 WATERTIGHT DUCT

- .1 Form bottom of horizontal duct without longitudinal seams.
- .1 Weld joints of bottom and side sheets.
- .2 Seal other joints with duct sealer.
- .2 Slope horizontal branch ductwork down towards exterior.
- .1 Slope header ducts down toward risers.
- .3 Fit base of riser with 150 mm deep drain sump.

3.5 SEALING AND TAPING

- .1 Apply sealant in accordance with SMACNA.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturers recommendations.

3.6 LEAKAGE TESTS

- .1 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .2 Do leakage tests in sections.
- .3 Make trial leakage tests as instructed to demonstrate workmanship.
- .4 Do not install additional ductwork until trial test has been passed.
- .5 Test section minimum of 30 m long with not less than three branch takeoffs and two 90 degrees elbows.
- .6 Complete test before performance insulation or concealment Work.

END OF SECTION