

Part 1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and installation for fire alarm systems upgrades.
 - .2 Audible signal devices.
 - .3 End-of-line devices.
 - .4 Sustainable requirements for construction and verification.
 - .5 Match existing for partial system installation.

1.2 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .2 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN/ULC-S524-2001, Standard for the Installation of Fire Alarm Systems.
 - .2 CAN/ULC-S525-1999, Audible Signal Device for Fire Alarm Systems.
 - .3 CAN/ULC-S526-2002, Visual Signal Devices for Fire Alarm Systems.
 - .4 CAN/ULC-S527-1999, Control Units.
 - .5 CAN/ULC-S528-1991, Manual Pull Stations for Fire Alarm Systems.
 - .6 CAN/ULC-S529-2002, Smoke Detectors for Fire Alarm Systems.
 - .7 CAN/ULC-S530-M1991, Heat Actuated Fire Detectors for Fire Alarm Systems.
 - .8 CAN/ULC-S531-2002, Standard for Smoke Alarms.
 - .8 CAN/ULC-S536-S537-2004, Burglar and Fire Alarm Systems and Components.
- .3 National Fire Protection Agency
 - .1 NFPA 72-2002, National Fire Alarm Code.
 - .2 NFPA 90A-2002, Installation of Air Conditioning and Ventilating Systems.

1.3 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Submit Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Include:
 - .1 Layout of equipment.
 - .2 Zoning.
 - .3 Complete wiring diagram, including schematics of modules.

- .3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .3 Manufacturer's Field Reports: manufacturer's field reports specified.
- .4 Closeout Submittals:
 - .1 Submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals in accordance with ANSI/NFPA 20.
 - .2 Authority of Jurisdiction will delegate authority for review and approval of submittals required by this Section.
 - .3 Submit to Authority of Jurisdiction 2 sets of approved submittals and drawings immediately after approval but no later than 15 working days prior to final inspection.
 - .4 Submit following:
 - .1 Manufacturer's Data for:
 - .1 Alarm bells.
 - .2 Wiring.
 - .3 Conduit.
 - .4 Outlet boxes.
 - .5 Fittings for conduit and outlet boxes.
 - .2 System wiring diagrams:
 - .1 Submit complete wiring diagrams of system showing points of connection and terminals used for electrical connections in the system.
 - .2 Show modules, relays, switches and lamps in control panel.
 - .3 Design data: Power Calculations:
 - .1 Submit design calculations new work specified to substantiate that battery capacity exceeds supervisory and alarm power requirements.
 - .2 Show comparison of detector power requirements per zone versus control panel smoke detector power output per zone in both standby and alarm modes.
 - .3 Show comparison of notification appliance circuit alarm power requirements with rated circuit power output.

1.4 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Installer: company or person specializing in fire alarm system installations with 10-years documented experience approved by manufacturer.
- .2 Provide services of representative or technician from manufacturer of system, experienced in installation and operation of type of system being provided, to supervise installation, adjustment, preliminary testing, and final testing of system and to provide instruction to project personnel.

- .3 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
- .4 Maintenance Service:
 - .1 Provide one year's free maintenance with two inspections by manufacturer during warranty period. Inspection tests to conform to CAN/ULC-S536. Submit inspection report to Contract Administrator.

1.5 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 In accordance with Waste Management and Disposal Clauses from Section 26 05 01 – Common Work Results – For Electrical.

Part 2 Products

2.1 MATERIALS

- .1 Equipment and devices: ULC listed and labelled and supplied by single manufacturer.
- .2 Power supply: to CAN/ULC-S524.
- .3 Audible signal devices: to CAN/ULC-S525.

2.2 SYSTEM OPERATION

- .1 Existing system is a Simplex 4100U addressable system.
- .2 Add horn/strobe at locations shown to loops as shown.
- .3 Ensure no circuit is overloaded. Provide power supplies and circuits as required.

2.3 POWER SUPPLY

- .1 Verify the size of the power supply to accommodate the new bells and expand as required to maintain 25% spare capacity on all circuits minimum.
- .2 120 V, ac, 60 Hz input, 24 V dc output from rectifier to operate alarm and signal circuits, with standby power of gel cell batteries minimum expected life of 4 years, sized in accordance with NBC-2005.

2.4 AUDIBLE SIGNAL DEVICES

- .1 Audible device(s):
Supply and install horns as indicated.

2.5 END-OF-LINE DEVICES

- .1 End-of-line devices to control supervisory current in alarm circuits and signalling circuits, sized to ensure correct supervisory current for each circuit. Open, short or ground fault in

any circuit will alter supervisory current in that circuit, producing audible and visible alarm at main control panel and remotely as indicated. All end of line devices shall be clearly marked on site and on the as-built drawings (Marker on the device is not acceptable).

2.6 WIRING

- .1 14 AWG min.for power & 18 AWG twisted shielded for data & addressable loop wiring
Wire to remote annunciators: No. 18 AWG minimum solid copper conductor.
- .2 Wire for connection to base telegraphic alarm loop: No. 12 AWG minimum solid copper conductor.
- .3 Insulation 75 degrees C minimum with nylon jacket.
- .4 Colour code wiring.

2.7 AS-BUILT RISER DIAGRAM

- .1 Provide as-built markup to fire alarm riser diagram.

Part 3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install systems in accordance with CAN/ULC-S524
- .2 Connect signalling circuits to main control panel.
- .3 Install end-of-line devices at end of alarm and signalling circuits.

3.3 FIELD QUALITY CONTROL

- .1 Site Tests:
 - .1 Perform tests in accordance with Section 26 05 00 - Common Work Results - for Electrical and CAN/ULC-S537.
 - .2 Fire alarm system:
 - .1 Audibility levels of alarm system to be confirmed post occupancy. A proper audiometric report shall be prepared with a calibrated instrument.
- .2 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

3.4 CLEANING

- .1 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION