



GREENHOUSE — PERIMETER HEATING PLAN 1
SCALE: 1:50
GHM-2

KEYED NOTES:

- 1— REFER TO GHM-01 FOR PIPE SIZE
- 2— REFER TO GHM-01 FOR PIPE SIZE
- 3— 3 WAY MIXING VALVE (TYP.)
- 4— CIRCULATING PUMP (TYP.)
- 5— 32mm ALUM. FINNED PIPE (TYP.)
- 6— PIPE DROP (TYP.)
- 7— PIPE RISER (TYP.)

GENERAL NOTES:

- ONLY ONE REVERSE RETURN HEADER SYSTEM IS REQUIRED IN CORRIDOR FOR OVERHEAD HEATING SYSTEM & FOR PERIMETER HEATING SYSTEM
- PROVIDE AND INSTALL AUTOMATIC AIR VENTS AT HIGH POINTS.
- PROVIDE AND INSTALL SEDIMENT DRAINS AT LOW POINTS.
- REFER TO THE MECHANICAL AND CIVIL DRAWINGS FOR INTERCONNECTIONS BETWEEN THE GREENHOUSE SYSTEMS AND THE EXISTING SYSTEMS IN THE FACILITY.



ghe
Greenhouse Engineering

86 Glenview Avenue, Toronto, Ontario M4R 1P6, Canada
Tel: (416) 489 3816 Fax: (416) 481 3883

**PUBLIC WORKS &
GOVERNMENT SERVICES
CANADA**

**MORDEN, MANITOBA
101 ROUTE 100, UNIT 100**

**MORDEN RESEARCH
AND DEVELOPMENT CENTRE
GREENHOUSE EXTENSION**

Designed by AT Conçu par

Drawn by AE Dessiné par

Approved by Approuvé par

PWGSC Project Manager Administrateur de Projets TPSGC

BRAD SITARZ

Drawing Title Titre du dessin

**GREENHOUSE
PERIMETER HEATING
PLAN**

Project no./No. du projet Drawing no./No. du dessin Revision no.

R.076333.001

GHM-02

0

OF 2