



KEYED NOTES:

EC	- EVAPORATIVE COOLER FILL VALVE - 2#18 - EVAPORATIVE COOLER DRAIN VALVE - 2#18 - EVAPORATIVE COOLER LOW LEVEL SWITCH - 2#18 - EVAPORATIVE COOLER HIGH LEVEL SWITCH - 2#18
NPMD	NEGATIVE PRESSURE FAN MOTORIZED DAMPER - 3#18
PPMD	POSITIVE PRESSURE FAN MOTORIZED DAMPER - 3#18
MV1	OVERHEAD CONTROL VALVE - 3#18
MV2	PERIMETER CONTROL VALVE - 3#18
LCM	LIGHTING CANOPY MOTOR - 3#10
RVP	RIDGE VENT POSITION - 3#18 SHIELDED
RVLS	RIDGE VENT LIMIT SWITCH - 3#18
OHHWS	OVERHEAD HOT WATER SUPPLY TEMPERATURE - 2#18 SHIELDED
OHHWR	OVERHEAD HOT WATER RETURN TEMPERATURE - 2#18 SHIELDED
PHWS	PERIMETER HOT WATER SUPPLY TEMPERATURE - 2#18 SHIELDED
PHWR	PERIMETER HOT WATER RETURN TEMPERATURE - 2#18 SHIELDED
TLMD	TRANSFER LOUVER MOTORIZED DAMPER - 3#18
ECMD	EVAPORATIVE COOLER MOTORIZED DAMPER - 3#18
CO2	CO2 SENSOR - 2#18 SHIELDED + 2#18 CO2 VALVE - 2#18 CO2 ALARM SENSOR - 4#18 SHIELDED
ZS	ZONE SENSOR - AIR TEMPERATURE DRY BULB 1 & 2 AIR TEMPERATURE RELATIVE HUMIDITY SENSOR LIGHT SENSOR ASPIRATED FAN WEST PENN AQ224 CABLE
ZSC	CORRIDOR ZONE SENSOR - AIR TEMPERATURE DRY BULB 1 ASPIRATED FAN WEST PENN AQ224 CABLE

NOTES:
- ALL CONNECTIONS TO BE CONNECTED TO ZONE
PANEL LOCATED IN THE CORRIDOR
- ALL CABLES TO BE STRANDED
- REFER TO DRAWING GH-07, CORRIDOR ELEVATIONS
FOR CONTROL PANELS



ghe
Greenhouse Engineering

86 Glenview Avenue, Toronto, Ontario M4R 1P8, Canada
Tel: (416) 489 3816 Fax: (416) 481 3883

PUBLIC WORKS &
GOVERNMENT SERVICES
CANADA

MORDEN, MANITOBA
101 ROUTE 100, UNIT 100

MORDEN RESEARCH
AND DEVELOPMENT CENTRE
GREENHOUSE EXTENSION

Designed by AT Conçu par

Drawn by AE Dessiné par

Approved by Approved par

PWGSC Project Manager Administrateur de Projets TPSC
BRAD SITARZ

Drawing title Titre du dessin

GREENHOUSE
LOW VOLTAGE
PLAN

Project no./No. du projet
R.076333.001

Drawing no./No. du dessin
GHE-04

Revision no.
0