



Materiel and Procurement Services  
200 Kent Street, Station 9W067  
Ottawa, Ontario  
K1A 0E6

**July 21, 2016**

**Subject: Invitation to Tender: FP802-160091**

**Title: Fanny Bay Catamaran Installation**

**Work site location: Fanny Bay, BC**

**ADDENDUM: NO. 1**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date: July 28, 2016**

**Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)**

**RFP File No: FP802-160091**

---

**NOTE: Please see attachment: Fanny Bay Catamaran Installation drawings dated July 21, 2016**

**REVISION 1**

**Remove:** Section 00 01 11 Schedule of Quantities.

**Question 1**

With regards to section 31 62 16.19 Steel piles. Can the pipe be spiral seam ASTM a252 grade 3 as well? Reason being is the straight seem is very difficult to find.

**Answer 1**

ASTM A252 Grade 3 is an approved equivalent steel pile.

**Question 2**

What is the length of item 5 the extra pile?

**Answer 2**



The extra pile shall be one 40ft long section.

**Question 3**

I cannot find any geotech information or tip elevation of piles for this project?

**Answer 3**

No geotechnical information has been provided at this time. The tip elevation of the piles can be found on Drawing 216105-002 – Float Layout General Arrangement

**All other Terms and Conditions for this requirement remain unchanged.**

Yours truly,

**Natasha Blackstein**

Contracting Officer

Tel: (613) 993-5741

E-mail: [natasha.blackstein@dfo-mpo.gc.ca](mailto:natasha.blackstein@dfo-mpo.gc.ca)