

Addendum/Addenda

No./N° 1

Project Description / Description de projet M24 Breaker Replacement		
Solicitation No./ N° de sollicitation 16-22054	Project No./N° de projet 5223	W.O. No./N° d'ordre de travail A1-009194-07-01
Departmental Representative / Représentant Ministériel Maurice Richard	Date July 21,2016	
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

Q : Drawing 5223-E01 detail 1 assigns note 2 at the main breaker but it is a 1600A trip required...should this not actually be note 3?

A: 1600A main breaker note is revised to be note 3

Q: Are we to simply wire the TCP/IP at breaker Breaker C.B.3. for note 5, or, does this breaker also need us to modify/ add to it the shunt trip close coil and modbus module?

A: C.B.3 is required to add shunt trip and close coil with Modbus com module.