



QUESTIONS & RÉPONSES No.1

QUESTIONS & ANSWERS

Dossier No – File No

5P300-16-5194

Projet - Project

**Annual Inspection & Fire Suppression – Fortress of Louisbourg
NHSC**

**Date limite au plus tard -
Closing Date on or before
Tuesday, August, 16, 2016
at 2 o'clock EDT**

**Date d'émission – Date of issue
July 22, 2016**

OBJET DE LA PRÉSENTE MODIFICATION – THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING

Q1. Is this tender to be awarded for all inspection types as bid or will the individual Fire/Sprinkler and suppression be awarded separately?

A1. All together

Q2. Are Backflow preventers to be included? If so what is the total count?

A1. The backflow preventors on the sprinkler system only are to be tested and there is a total of 17.

Q3. Are Hydrants to be included? If so what is the count and testing procedure as there is a limited water supply.

A3. Hydrants are not to be included.

Q4. A full trip of all systems is required every 3 years on the sprinkler systems, what year would this be included?

A4. The full trip test must happen before December 30, 2016.

Q5. Who is responsible for draining the low points on the dry systems after the full trip?

A5. Parks Canada will complete this work

Q6. Who would be responsible for draining the low points prior to the cold weather?

A6. Parks Canada will complete this work

- Q7. What is the procedure smoke detectors that cannot be reached with the sensitivity tester?
 A7. Contractor will be responsible to find their own safe access method to all smoke detectors which must be approved by Parks Canada prior to implementation.
- Q8. I would also like it clearly noted that the sensitivity has to be read directly from the smoke detectors and NOT from the panels as this countermands code requirements.
 A8. Agreed

TOUTES LES AUTRES CONDITIONS INCLUSES DANS LES INSTRUCTIONS DE TRAVAIL DEMEURENT LES MÊMES / ALL OTHER CONDITIONS INCLUDED IN THE WORK INSTRUCTIONS REMAIN THE SAME.

Par la présente nous reconnaissons avoir reçu la version modifiée des instructions et nous attestons avoir modifié notre soumission en conséquence.

We hereby acknowledge receipt of the amendment instructions and confirm that provisions therefore have been made in our tender.

Pour être prise en considération, toute soumission devra être accompagnée d'un exemplaire signé de la présente modification. Si votre soumission a déjà été envoyée, veuillez signer et envoyer cette modification par télécopieur/courriel avec toutes révisions faites à votre prix de soumission, à nos bureaux avant la date limite. Télécopieur: 418-648-5392

Signed copy of this amendment must accompany each tender in order that the tender be considered. If your submission has already been sent, please sign and send this amendment by fax / email with any revisions made to your bid price, at our office before the deadline. Fax: 418-648-5392.

Signé - Signed	Titre - Title	Date
Société - Company		