Tender notice number: 5P300-16-5026 National Historique Site of Coteau-du-Lac -Date: 20th of July 2016 (Addendum) Repair of Blockhauss **Parks Canada Agency** Addendum: 20th of July 2016 The following modifications have been made to the tender documents issued on July 16th 2016: 1. Questions from the bidders: • Question: For the reinforcement of the roof truss, are steel plates required on both sides of the trusses? **Answer:** No, only on one side.

Louis-Philippe Poirier, eng., M.Sc.A.