



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-5232**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

**The referenced document is hereby
revised; unless otherwise indicated, all
other terms and conditions remain the
same.**

**Ce document est par la présente révisé;
sauf indication contraire, les modalités
de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

| | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|
| Title-Sujet Construction of Green Space, Depot Division, Regina, SK | |
| Solicitation No. - No. de l'invitation M5000-17-0966/A | Date 25 July 2016 |
| Amendment No. - No modif. 05 | |
| Client Reference No. - No. De Référence du Client M5000-17-0966/A | |
| GETS Reference No. - No. de Référence de SEAG PW-17-00739460 | |
| Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 27 July 2016 | |
| F.O.B. - F.A.B. Destination | |
| Address Enquiries to: - Adresser toutes questions à: Teresa Hengen, Procurement Officer | |
| Telephone No. - No de téléphone (639) 625-3449 | Fax No. - N° de FAX: (306) 780-5232 |
| Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police 5600 - 11th Avenue Regina, SK | |
| This document does not contain a PERSONNEL SECURITY Clearance requirements | |
| Delivery Required - Livraison exigée: See Herein Voir aux présentes | Delivery Offered - Livraison proposée |
| Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur | |



This amendment is raised to:

Delete:

Solicitation Closes –L'invitation prend fin
at - à 2 :00 pm Central Standard Time
on - le 26 July 2016

Insert:

Solicitation Closes –L'invitation prend fin
at - à 2 :00 pm Central Standard Time
on - le 27 July 2016

Q1. Where exactly are we going to connect to for the power to the new light poles and bollards?

A1. The power would come from the electrical panel in the Food Services building and electrical wire would have to be run through the tunnel to reach it.

Q2. How are they to be controlled?

A2. They would be controlled by a photo cell sensor installed by the contractor.

Additional Information:

-Lot size - 72.7 m x 47.5 m for 3453.59 M2. The contractor is still responsible to do his own measurement to confirm this number.

-Minimum width of sidewalk needs to be 5 feet for snow removal and in between benches.