



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Dust Extraction & HVAC Upgrade	
Solicitation No. - N° de l'invitation EZ899-170635/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2016-07-26
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7826	
File No. - N° de dossier PWY-6-39067 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-07-28	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - Mission Medium Institution - Mission, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-170635/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-6-39067

CCC - FMS No./N° VME

Please find Addendum #002 herein.

All other terms and conditions remain unchanged.

This addendum varies the Contract Documents and will form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts, including General and Supplementary General Conditions of the Contract and all Sections in Division 1. The cost of all work contained herein is to be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project to the extent referenced and shall become a part thereof.

GENERAL

This addendum is issued prior to receipt of Bids to provide for certain revisions to and clarification to the Contract Documents.

The work required by this Addendum shall be executed in accordance with the requirements of the Contract and Contract Documents.

Include in the Stipulated Price, the cost of all work described in this Addendum.

MECHANICAL CLARIFICATIONS AND CHANGES

1)Reference Drawing M400 (Exhaust Arm Schedule):

CHANGE: EA-1 and EA-2 make , model number, and performance shall read:

Make: Nederman

Model: Extraction Arm NEX DX

Performance: 378 L/S @1000Pa ESP [800cfm @ 4.0"ESP]

SITE PHOTOS (EXISTING ROOF)



Two views of Existing Roof Top and Roof Mounted Air Handling Unit



View of Existing Roof Edge above Hobby Shop.

End of Addendum