

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1. ARCHITECTURAL/STRUCTURAL

SPECIFICATIONS AND DRAWINGS

ITEM No.1: Refer to Section 10 91 13 - Bird Control Devices and Drawings 1& 2/S3.1, 1&2/S3.2 and 4/S4.2. Delete bird control devices (pigeon spikes), all locations.

2. CLARIFICATIONS

STRUCTURAL

ITEM No.1: Refer to drawing S2.2, Keynote A and drawing S3.1, Keynote C: Keynotes indicate that this work is to be "FIXED PRICE". In other words, this work is to be included in the Lump Sum Amount of Appendix 1 - Combined Price Form of the Bid and Acceptance Form (BA).

3. SPECIFICATIONS AND DRAWINGS

ADMINISTRATIVE

ITEM No. 1: The General Contractor shall be responsible for building permit application and all associated costs. Refer also to the Invitation to Tender, page 9 of 17, Item 2.1.2, for submission requirements. The Authority Having Jurisdiction for this project is the South Interlake Planning District (SIPD). Contact information is as follows:

David Klausen
Chief Building Inspector
South Interlake Planning District
P.O. Box 1219, 285 Main Street
Stonewall Manitoba R0C 2Z0
Ph: 204-467-5587
Fax: 204-467-8383
Email: info@sipd.ca

ITEM No. 2: Refer to Specification Section 01 51 00 – Temporary Utilities, Item 1.6.1 to be revised to read as follows (revisions in ***bold italics***): "***Tie-in to the existing electrical 110v. power supply to provide*** temporary power for electric equipment is the responsibility of the General Contractor. ***All tie-ins to be coordinated with the Departmental Representative and CSC facilities staff. Temporary power supply for equipment greater than 110v. will be the responsibility of the General Contractor.***

ITEM No. 3: Refer to Specification Section 01 51 00 – Temporary Utilities, Item 1.6.2. Delete this item in its entirety.

4. STRUCTURAL/MECHANICAL

ITEM No. 1: Refer to drawing 2/M1.1. Drawing call-out “FEED FROM WEEPING TILE SYSTEM. REFER TO ARCHITECTURAL” to be revised to read as follows: “FEED FROM SURFACE MEMBRANE AND PERFORATED STEEL PERIMETER ANGLE. REFER TO DRAWING B/S4.1:

ITEM No. 2: Refer to drawing 2/M1.1. Drawing call-out “REFER TO ARCHITECTURAL FOR SUMP PIT DETAILS” to be revised to read as follows: “REFER TO DRAWING B/S4.1 FOR SUMP PIT DETAILS”.

5. PROJECT NUMBER

Delete all references to: Project No. R.079596.001

Replace with: Project No. R.079596.002

END OF ADDENDUM NO. 1