



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Belly River Group Camp Crossing Culvert Replacement, Waterton Lakes National Park		
Solicitation No.: / N° de l'invitation : 5P420-16-5137/A	Amendment No.: / N° de modification de l'invitation : 002	Date: August 3, 2016 Date : 3 août 2016
GETS Reference No.: / N° de référence de SEAG : PW-16-00740113		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: August 4, 2016	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 4 août 2016	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 002

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5137/A.

A. QUESTIONS AND ANSWERS

Q11. Section 33 42 13 clauses 1.4.3 and 2.1.1.4 of the specification make reference to the manufacturer holding certification to CSA-A23.4. Will Parks Canada Agency accept alternative certification in lieu of the CSA certification?

A11. Alternative certification to the CSA certification may be acceptable provide the Contractor provides documentation indicating the alternative certification is equivalent or better than the CSA certification listed. See herein for changes to the specifications for further details.

Q12. Should the shear stud that forms part of the removable culvert lid on the box culvert be galvanized?

A12. Yes the shear studs and L75 x 75 x 8 angles around all edges of the removable lids shall be galvanized.

B. CHANGES TO THE SPECIFICATIONS

1. Section 33 42 13 – Concrete Box Culvert

Delete:

1.4.3 The Contractor shall provide to the Departmental Representative the precast Concrete Box Culvert manufacturer certification in the appropriate category under CSA-A23.4.

Insert:

1.4.3 The Contractor shall provide to the Departmental Representative the precast Concrete Box Culvert manufacturer certification in the appropriate category under CSA-A23.4 or an alternative pre-approved equivalent or better certification. If an alternative certification is used, it is the Contractor's responsibility to provide suitable documentation demonstrating that the alternative certification is equivalent or better than the CSA certification.

Delete:

2.1.1.4 Manufactured by a manufacturing plant certified in the appropriate category to CSA-A23.4.

Insert:

2.1.1.4 Manufactured by a manufacturing plant certified in the appropriate category to CSA-A23.4 or an alternative pre-approved equivalent or better certification.

2. Section 33 42 13 – Concrete Box Culvert

Insert:

2.1.1.5 The culvert lid shall include galvanized L75 x 75 x 8 angles complete with galvanized 12.7 diameter x 75 mm long shear studs.

All other terms and conditions remain the same.