



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Place Bonaventure, portail Sud-Est

800, rue de La Gauchetière Ouest

7^{ème} étage

Montréal

Québec

H5A 1L6

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Ce besoin comporte des exigences relatives à la sécurité industrielle (LVERS).

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada

Place Bonaventure, portail Sud-Est

800, rue de La Gauchetière Ouest

7^{ème} étage

Montréal

Québec

H5A 1L6

Title - Sujet Relocalisation BSIF	
Solicitation No. - N° de l'invitation EF950-170228/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EF950-17-0228	Date 2016-08-04
GETS Reference No. - N° de référence de SEAG PW-\$MTC-030-13948	
File No. - N° de dossier MTC-6-39072 (775)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-08-16	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Clément, Angelica	Buyer Id - Id de l'acheteur mtc775
Telephone No. - N° de téléphone (514) 496-3798 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Sollicitation No. - N° de l'invitation
EF950-170228/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
mtc030

Client Ref. No. - N° de réf. du client
EF950-17-0228

File No. - N° du dossier
MTC-6-39072

CCC No./N° CCC - FMS No./N° VME

THE INVITATION TO TENDER IS MODIFIED AS MENTIONED BELOW:

Addendum 2

Please find enclosed herewith the above-mentioned addendum which forms part of the tender documents.

ALL OTHER TERMS, CLAUSES AND CONDITIONS REMAIN UNCHANGED



ADDENDUM NO. E-1

Project: Office of the superintendent of financial institutions Canada

Description: Electrical, communication and security drawings and specifications adjustments

Project no.: 2012-186-105

Division: 26, 27 and 28 - Electrical, communication and security

By: Louis St-Pierre, Eng.

Date: 2016-07-26

1. This addendum shall be part of original drawings and specifications and shall form part of the contractual documents. Bidders shall make sure that the cost of this addendum is included in the bid amount.
2. Documents:
 - 2.1 Included documents:
 - 2.1.1 Specifications:
 - 26 50 00, page 4.
 - 2.1.2 Drawings nos.:
 - E06.
 - E07.
 - E09.
 - E10.
3. Description of work:
 - 3.1 Consult issued documents.

2.7 LIST OF MANUFACTURERS

- .1 Lamps:
 - .1 General Electric of Canada
 - .2 Osram/Sylvania
 - .3 Philips
- .2 Fluorescent lights (T- 8):
 - .1 Focal Point
 - .2 Acuity Brands Group
 - .3 Cooper Lighting Group
 - .4 Philips Group
 - .5 Hubbell
- .3 Interior LED luminaires:
 - .1 Acuity Brands Group
 - .2 Cooper Lighting Group
 - .3 Philips Group
 - .4 Lumenpulse
 - .5 Lumenwerx
 - .6 Senso lighting
- .4 Ballasts:
 - .1 Advance
 - .2 Osram/Sylvania
 - .3 Lutron

Part 3 Execution

3.1 INSTALLATION

- .1 Locate and install luminaires as indicated.
- .2 Provide adequate support to suit ceiling system.
- .3 Coordinate on site the exact position of all luminaires installed in mechanical rooms or in ventilation units after the mechanical equipment has been installed.
- .4 Perform the lighting installation work only after more dirty work has been completed.
- .5 Do not use lamps and lenses until having obtained the consent of the engineer. The lamps must not at any time be used as temporary lighting in the building.
- .6 Clean all light fixtures, lamps and lenses immediately prior to acceptance of work.
- .7 Install joints between luminaires installed in continuous rows.
- .8 In some places, some light fixtures are installed in ventilation ducts.
- .9 Provide and install all materials (brackets, plaster frames, supports, etc.) required for the complete installation of lighting.
- .10 Unless otherwise indicated, install an isolating device in all existing fluorescent fixtures powered to 347 V.

