



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Water Treatment System	
Solicitation No. - N° de l'invitation 39903-170154/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 39903-170154	Date 2016-08-08
GETS Reference No. - N° de référence de SEAG PW-\$PWB-101-3913	
File No. - N° de dossier PWB-6-39029 (101)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-08-18	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lomax, Sandra	Buyer Id - Id de l'acheteur pwb101
Telephone No. - N° de téléphone (506) 636-4362 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. Three (3) is raised to include the following Addendum No. Three (3).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Question and Answers

Questions- 4

- 1) In Annex A, the flow rate is stated as 9.5 gpm minimum. Is this flow continuous, ie required 24/7. If not, what is the daily requirement.
- 2) Is there a maximum flow requirement?
- 3) Is there a water analysis that you can provide?
- 4) For the DI portion, do you want a regenerable-in-place system, or service DI exchange tanks?
- 5) Can you provide a list of equipment that will require connection to the HMI?

Answers-4

- 1) RO water production for the boiler operations total 6000US gallons per day. DI lab grade water production 1000 US gallons per day
- 2) Yes, RO minimum of 9.5 US GPM to the boiler operations and DI minimum 2 US GPM to the lab water storage tanks.
- 3) Yes
- 4) Annex B states One Reverse Osmosis system with elrctrodeionization (RO EDI) and ultraviolet (UV) units, this is what CFIA requested there will be no other technologies accepted.
- 5) Distribution pumps and water level sensors for both the deaerator and the lab water storage tanks are on existing controllers and will not be interfaced with the new system. The control of solenoid valves to fill both storage tank systems is also controlled by building automation and will not be changed. The building automation sends a command to the RO/EDI system to start producing water. All other devices required to make the system operational must be provide including water quality sensors, automatic valves, process booster pumps, current sensors, low flow and low pressure switches etc.

Solicitation No. - N° de l'invitation
39903-170154/A
Client Ref. No. - N° de réf. du client
39903-170154

Amd. No. - N° de la modif.
003
File No. - N° du dossier
PWB-6-39029

Buyer ID - Id de l'acheteur
PWB010
CCC No./N° CCC - FMS No./N° VME
