



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1300 - 635 8 Ave SW**  
**Calgary, AB T2P3M3**  
**Bid Fax: (403) 292-4475**

**AMENDMENT / MODIFICATION**

**001**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**Suite 1300**  
**635 - 8 Ave SW**  
**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Museum Foundation Repairs Banff National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-16-5081/A		<b>Date:</b> August 8, 2016
<b>GETS Reference No. - No de reference de SEAG</b> PW-16-00741350		<b>Amendment No. - N° de la modif.</b> 001
<b>Solicitation Closes:</b>		
<b>at - á</b> 02:00 PM	<b>on - le</b> August 11, 2016	<b>Time Zone - Fuseau horaire</b> MDT - HAR
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/>	<b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>		
Jen Maheu		
<b>Telephone No. - No de téléphone</b>		<b>Fax No. - No de FAX:</b>
(403) 292-8502		(403) 292-4475
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>		
See Herein - Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## **Amendment 01**

This amendment is being raised to distribute questions and answers.

### **A. QUESTIONS AND ANSWERS**

Q1. Sand by hand or by machine?

A1. Hand sanding is required to minimize dust. Mechanical grinding is not permitted as per the specifications.

Q2. Is overspray on the masonry of the exterior west annex wall required to be removed?

A2. Yes. Contractor shall clean overspray from exterior masonry. Refer to Revised 04 03 06 Cleaning Historic Masonry - chemical strippers and poulticing under DSP 2 folder. Acceptable product: "Sure Klean Heavy Duty Paint Stripper" by ProSoCo, Inc. <http://www.prosoco.com/products/sure-klean-heavy-duty-paint-stripper>

### **B. MANDATORY SITE VISIT ATTENDANCE**

Please refer to DSP 2 folder for list of attendees.

### **C. REVISION TO ANNEX A – PRICE FORM**

**DELETE:** In its entirety

**REPLACE WITH:** See following page for revised Annex

**All other terms and conditions remain unchanged.**

## ANNEX A – PRICE FORM

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

### LUMP SUM TABLE

Note: Bidders are reminded that it is their responsibility to include in their bid all work as described in the drawings and specifications. Pricing for work not accounted for in the Unit Price Table including but not limited to Mobilization, De-Mobilization, etc. is to be included in the Lump Sum Table.

Item No.	Class of Labour, Plant or Material	Unit of Measurement	Estimated Total Price GST/HST extra
1	Museum Site scope	Lump Sum	\$ _____
2	Interior foundation walls - removal of white paint	Lump Sum	\$ _____
3	Interior foundation walls – removal of paint at areas covered by insulation	Lump Sum	\$ _____
4	Footing installation (If required)	Lump Sum	\$ _____
5	Mobilization/Demobilization	Lump Sum	\$ _____
<b>TOTAL LUMP SUM AMOUNT</b> Transfer amount to subparagraph 1) (a) of BA03			\$ _____