



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1300 - 635 8 Ave SW**  
**Calgary, AB T2P3M3**  
**Bid Fax: (403) 292-4475**

**AMENDMENT / MODIFICATION**

**002**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address  
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**Suite 1300**  
**635 - 8 Ave SW**  
**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Warden HQ Fish Hatchery Demolition and Rehabilitation Jasper National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-16-5141/A	<b>Date:</b> August 12, 2016	
<b>GETS Reference No. - No de reference de SEAG</b> PW-16-00741514	<b>Amendment No. - N° de la modif.</b> 002	
<b>Solicitation Closes:</b>		
<b>at - á</b> 02:00 PM	<b>on - le</b> August 16, 2016	<b>Time Zone - Fuseau horaire</b> MDT - HNR
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Jen Maheu		
<b>Telephone No. - No de téléphone</b> (403) 292-8502	<b>Fax No. - No de FAX:</b> (403) 292-4475	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> See Herein - Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## **Amendment 02**

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5141/A:

### **QUESTIONS AND ANSWERS:**

**Q1.** Is there an approved method or procedure for ensuring the required "weed free" topsoil? (i.e. can it be screened and visibly free of weeds or is it the Contractor's responsibility to pay for a baking process or special testing for the soil prior to installation?)

**A1.** Contractor must provide certificate that topsoil is weed free.

**Q2.** Will alternatives to the ECO BOND LBP product be considered if they are determined to be comparable products?

**A2.** Alternatives will be considered as long as the ECO BOND LDP specifications are met.

**Q3.** Does the granular fill and top soil need to be sourced outside the pit or is there a source within JNP that may be used?

**A3.** Granular fill and top soil are both to be sourced outside of Jasper National Park.

**Q4.** Does the entire work zone need to be fenced in for the construction project?

**A4.** Section 1.8.7 (General Conditions) - The Contractor will ensure work site excavations are secure behind protective fencing when contractor is not on site.

**Q5.** Under Terms of Reference Scope of work Item 2c and 2d seem to contradict each other. Is there asbestos tile to remove for the house?

**A5.** Asbestos tiles were already removed from the house.

**Q6.** Have all the utilities been disconnected from the structures?

**A6.** Electrical: disconnected, lines removed  
Gas: disconnected, meter removed  
Telus: will need to be disconnected  
Sewer: connected, remove during demolition  
Water: connected, service to disconnected during demolition

**Q7.** How many trees are to be removed?

**A7.** The number of trees to be removed is at the discretion of the Contractor, in order to access the work area. A permit from PCA is required before removing trees.

**Q8.** Can we leave the wood from the trees on site?

**A8.** No wood from removal can be left on site. Wood needs to be bucked and limbed in 10 to 12 foot lengths, and transported to Marmot Pit.

**All other terms and conditions remain unchanged.**