



Materiel and Procurement Services  
200 Kent Street, Station 9W070  
Ottawa, Ontario  
K1A 0E6

August 16, 2016

**Subject:** Invitation to Tender: FP802-160167  
**Title:** Boat storage and repair facility construction.  
**Work site location:** Gimli, MB

**ADDENDUM: No. 1**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date:** Wednesday, August 17, 2016  
**Time:** 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)  
**RFP File No:** FP802-160167

---

**\*\* THE FOLLOWING QUESTION WAS SUBMITTED BY A POTENTIAL BIDDER TO THE CONTRACTING AUTHORITY IN RELATION TO THE SUBJECT ITT\*\***

**Q.1 Do you have a geotechnical report (soils report) for this site? (It is required for the foundation design and building permit.)**

A.1 I have a geo technical for a site approximately 50 feet away but not this specific site. It can be referenced if needed. I would recommend bores holes also for this location.

**Q.2 Is the building you want to be a pre-engineered steel structure metal clad or a wood structure metal clad?**

A.2 pre-engineered steel structure metal clad



**All other Terms and Conditions for this requirement remain unchanged.**

**Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.**

Regards

Gricha Zurita  
Team lead, Senior Contracting Officer  
Telephone: (613) 993-2807  
Email: [Gricha.Zurita@dfo-mpo.gc.ca](mailto:Gricha.Zurita@dfo-mpo.gc.ca)

---

***RECEIPT ACKNOWLEDGED***

**Name of Company** \_\_\_\_\_

**Signature** \_\_\_\_\_