



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving
- PWGSC

1550, Avenue d'Estimauville

1550, D'Estimauville Avenue

Québec

Québec

G1J 0C7

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC/PWGSC

601-1550, Avenue d'Estimauville

Québec

Québec

G1J 0C7

Title - Sujet Revitalisation Havre-Kégaska	
Solicitation No. - N° de l'invitation F3731-160062/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client F3731-160062	Date 2016-08-17
GETS Reference No. - N° de référence de SEAG PW-\$QCL-018-16817	
File No. - N° de dossier QCL-6-39095 (018)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-08-24	Time Zone Fuseau horaire Heure Avancée de l'Est HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Piras, Gabriel	Buyer Id - Id de l'acheteur qcl018
Telephone No. - N° de téléphone (418) 649-2870 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No – N° de l'invitation
F3731-160062/A
Client Ref No. – N° de réf. du client
F3731-16-0062

Amd. No. – N° de la modif.
005
File No. – N° du dossier
QCL-6-39095

Buyer ID – id de l'acheteur
QCI018

**TITLE: KEGASKA, LOWER NORTH SHORE – HARBOUR REVITALIZATION
AMENDMENT 005**

Included in the present amendment:

- Addendum no 2

ADDENDUM no 2

See Addendum no 2 attached.

***** All the other clauses and conditions remain unchanged *****

The following changes to the tender documents are effective immediately. This Addendum is a whole part of the tender documents.

PART 1 SPECIFICATIONS

1.1 SPECIFICATIONS - CIVIL

.1 Section 06 05 73 – Wood treatment.

.1 Section 3.2 – Preservation treatment

.1 Replace existing section 3.2.1 by the following text :

.1 Treat materials in compliance with the requirements of the CSA 080 series for use in a marine environment.

.2 Section 35 51 25 – Floating docks.

.1 Section 2.1.2 - Timber.

.1 Replace existing section 2.1.2.1 by the following text :

.1 FSC-certified timber or equivalent certification with proven justification by Contractor.

.2 Replace existing section 2.1.2.5 by the following text :

.1 All timber used to manufacture pontoons shall be pressure-treated with CCA (chromated copper arsenate), a preservative, in accordance with standard CAN/CSA-080-M.

.3 Add new section 2.1.2.8 as follows :

.1 Douglas-fir is accepted for all work involving softwood in the project of Kégaska. In the case of Douglas-fir, the accepted retention of preservation is the one obtained at refusal.

2.1 SPECIFICATIONS - ELECTRICAL

.1 Section 4 – Scope of work

.1 Section 4.1 – Breakwater area

.1 Replace existing section 4.1.1 by the following text :

This section describes the work to be performed by a master electrician and the Contractor shall coordinate with a representative of Hydro-Quebec (HQ).

- .1 Install, connect and identify the base, measuring equipment and all related materials as required and specified by HQ's standard E.21-10 (latest revision).**
- .2 Ground the new electrical main power based on proper installation.**

END OF ADDENDUM