



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Stonework Restorations, Dorchester	
Solicitation No. - N° de l'invitation EC016-170672/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.061890.001	Date 2016-08-18
GETS Reference No. - N° de référence de SEAG PW-\$PWB-007-3920	
File No. - N° de dossier PWB-6-39045 (007)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-08-23	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ellis-Herring , Alison PWB	Buyer Id - Id de l'acheteur pwb007
Telephone No. - N° de téléphone (506) 636-3908 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EC016-170672/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
pwb007

Client Ref. No. - N° de réf. du client
R.061890.001

File No. - N° du dossier
PWB-6-39045

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. three (3) is raised to include the following addendum no. 3.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 3.

1. QUESTION AND ANSWER

Question: Section 01 50 00 Item 1.13.1.2 & Item 1.13.1.3 state that even with the Wardens approval scaffold "...must not be higher than 3 m." and "...scaffolding must be disassembled at the end of each working day." Addendum #2 states that this section is valid, however, the ambient temperature requirements (15 degrees Celsius or above) are not achievable without a fully enclosed scaffold, erected for the duration of the project. Please clarify what will be acceptable for scaffolding.

Answer: The articles of the specifications describing scaffolding height limitations are requirements of the Institution - hence these clauses remain. The review process to request full height scaffolding will be to submit scaffolding shop drawings, stamped by a licensed NB engineer, showing the extent and proposed layout for review by the Warden and supported with an explanation such as is noted in the question above. This is not to say an approval by the Institution is guaranteed.