



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works & Government**  
**Services Canada/Réception des soumissions Travaux**  
**publics et Services gouvernementaux Canada**  
**1713 Bedford Row**  
**Halifax, N.S./Halifax,(N.E.)**  
**B3J 1T3**  
**Halifax**  
**Bid Fax: (902) 496-5016**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.E.)  
B3J 3C9  
Halifax  
Nova Scot

<b>Title - Sujet</b> BIO- Sea Water Cooling	
<b>Solicitation No. - N° de l'invitation</b> EB144-170693/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> EB144-17-0693	<b>Date</b> 2016-08-19
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWA-110-5435	
<b>File No. - N° de dossier</b> PWA-6-76046 (110)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-08-25</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Collier (PWA), Susan	<b>Buyer Id - Id de l'acheteur</b> pwa110
<b>Telephone No. - N° de téléphone</b> (902) 496-5350 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Due to the technical nature of this amendment, it will be available in ENGLISH Only.

**Amendment 003 is raised to answer the question below:**

Question 1: Where in the specification can the following items be found?

- a) The dedicated balancing valves shown on Detail B on drawing H-03
- b) The new exhaust fan shown on drawing H-02.

Answer to Question 1:

Balancing Valve on Detail B drawing M-03: 23 05 23.06 – VALVES - PLASTIC and is covered in 2.1 Butterfly Valves – Resilient Seat – 200 PSIG. Specifically refer to 2.1.7.2, Handwheel operator with lockable position

Exhaust Fan shown on Drawing H-02: 23 34 00 – HVAC FANS and is covered 2.2 In-Line Centrifugal Fans

All Other Terms and Conditions Remain the Same.