



Materiel and Procurement Services  
200 Kent Street, Station 9W071  
Ottawa, Ontario  
K1A 0E6

**FP802-160135**

**August 18, 2016**

**Subject: Invitation to Tender: FP802-160135**

**Title: Electrical upgrades**

**Work site location: Prosser's Rock, St-John's, Newfoundland**

**ADDENDUM: NO. 02**

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#02) is hereby issued.

**Department of Fisheries and Oceans**

**Bid Closing Date: Tuesday, August 30, 2016**  
**Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)**  
**RFP File No: FP802-160135**

---

## **QUESTIONS and ANSWERS**

### **Question 01 from Bidder:**

It seems that the specifications and details for the metering of the power to the pedestal's is missing, can you please confirm that this is or is not part of the project and if it is please issue some documentation for us to use to price the metering system.

### **DFO Answer 01:**

Please note the following modifications:

1. Reference drawing E4
  - a. Delete Metering Panel A and Metering Panel B. Replace with four (4) new Multi-Circuit Meter Panels labelled 1A, 2A, 1B, & 2B. See drawing E-SK-1.
  - b. Add one (1) 15A, 3P breaker in Panel A in circuit #53, 55, 57: circuit description to be: "New Multi-Circuit Meter Panel 1A", load watts to be: 500, wire size to be: 12.



- c. Add one (1) 15A, 3P breaker in Panel A in circuit #50, 52, 54: circuit description to be: "New Multi-Circuit Meter Panel 2A", load watts to be: 500, wire size to be: 12.
  - d. Add one (1) 15A, 3P breaker in Panel B in circuit #43, 45, 47: circuit description to be: "New Multi-Circuit Meter Panel 1B", load watts to be: 500, wire size to be: 12.
  - e. Add one (1) 15A, 3P breaker in Panel B in circuit #48, 50, 52: circuit description to be: "New Multi-Circuit Meter Panel 2B", load watts to be: 500, wire size to be: 12.
2. Add Section 26 09 23.01 – Metering and Switchboard Instruments to the Electrical Specification.

---

**All other Terms and Conditions for this requirement remain unchanged.**

**Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.**

Yours truly,

**Julie Michelle Tremblay**  
Senior Contracting Officer  
Tel: (613) 998-1614  
E-mail: [Julie.Michelle.Tremblay@dfo-mpo.gc.ca](mailto:Julie.Michelle.Tremblay@dfo-mpo.gc.ca)

---

**RECEIPT ACKNOWLEDGED**

**Name of Company** \_\_\_\_\_

**Signature** \_\_\_\_\_

**Canada**