



Materiel and Procurement Services
200 Kent Street, Station 9W087
Ottawa, Ontario
K1A 0E6

August 19, 2016

Subject: Invitation to Tender: FP802-160132

Title: Repairs to Lightkeeper's Dwelling and Ancillary Structures

Work site location: Green Island (Catalina), NL

ADDENDUM: No. 3

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#3) is hereby issued.

Department of Fisheries and Oceans

Bid Closing Date: Wednesday, August 24th, 2016
Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)
RFP File No: FP802-160132

**** THE FOLLOWING QUESTION WAS SUBMITTED BY A POTENTIAL BIDDER TO THE CONTRACTING AUTHORITY IN RELATION TO THE SUBJECT ITT****

Q.1: On drawing sheet C3 it shows the post to be dug down to 6.6 feet. Is this the distance the posts should be dug? Or do contractors just dig until they can no longer dig anymore? The distance dug into the ground may be shorter than 6.6 feet?

A.1: Post is to be dug to the depth shown on the drawings, unless bedrock is encountered in the hole (in which case the hole can be terminated at the depth to bedrock).



All other Terms and Conditions for this requirement remain unchanged.

Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.

Regards,

Iryna Volochay
Senior Contracting Officer
Procurement Hub
Materiel and Procurement Services
Financial and Materiel Management Operations
Fisheries and Oceans Canada
200, Kent Street
Ottawa, ON, K1A 0E6, CANADA
Government of Canada
Telephone: (613) 993-1550
Fax: (613) 991-4545
Email: Iryna.Volochay@dfo-mpo.gc.ca

RECEIPT ACKNOWLEDGED

Name of Company _____

Signature _____