



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

004

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Warden HQ Fish Hatchery Demolition and Rehabilitation Jasper National Park		
Solicitation No. - No. de l'invitation 5P420-16-5141/A	Date: August 22, 2016	
GETS Reference No. - No de reference de SEAG PW-16-00741514	Amendment No. - N° de la modif. 004	
Solicitation Closes:		
at - á 02:00 PM	on - le August 25, 2016	Time Zone - Fuseau horaire MDT - HNR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à : Jen Maheu		
Telephone No. - No de téléphone (403) 292-8502	Fax No. - No de FAX: (403) 292-4475	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 04

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5141/A and change the solicitation closing date:

A. **BID CLOSING DATE**

The closing date for tender 5P420-16-5141/A, titled Warden HQ Fish Hatchery Demolition and Rehabilitation, Jasper National Park, is extended from August 24, 2016 until August 25, 2016 at 2:00PM Mountain Daylight Time (MDT).

QUESTIONS AND ANSWERS:

Q9. Which exterior and interior paints contain high concentration of lead?

A9. As per the Terms of Reference - Scope of Work, Section 1.b - "Exterior cladding on the structure contains lead base paint" regarding the Office Building and as per Section 2.b "Exterior cladding of the structure contains lead base paint" regarding the House. The interior of the House also contains lead base paint, as per the lead paint analysis report completed on May 3, 2016 which is included after Section 02 83 10. The interior of the Office Building does not contain lead paint.

Q10. What paint is Leachable?

A10. Leaching analysis of the structures was not completed, as leaching will be prevented when the structure pieces are encapsulated in lead barrier compound such as Ecobond.

Q11. Which Building contains the high concentration of lead?

A11. The exteriors of the office and house contain in excess of 600 parts per million (ppm) lead, which is considered hazardous waste. The interior of the house contains lead concentrations exceeding 600 ppm, which is considered hazardous waste. Refer to lead paint analysis report completed on May 3, 2016 which is included after Section 02 83 10.

Q12. Does the House contain any Asbestos and/or Lead?

A12. All asbestos has been removed. The exterior and the interior of the house contain lead. See hazardous materials report in Specifications package.

Q13. These specification sections need to be clarified as the contractors cannot be requested to do a site inspection and confirm all hazardous materials. Typical process is that a testing agency, hired by the Owner, investigates and provide their report which outlines the areas to be treated as hazardous materials.

A13. Contractor is responsible to determine quantities.

Q14. This needs to be clarified as unless we know the amount of a material we cannot carry a quotation. It is not possible to carry a cost unless the hazardous removal Subtrades know the amount of hazardous materials that need to be removed.

A14. Contractor is responsible to determine quantities.

Q15. Please confirm the diameter and depth of these two wells.

A15. Dumpleton Well (11U0431159 - 5864847) is 25m (exterior steele casing diameter - 6.75"), Headquarters Well (11U0430940 - 5864970) is 21m (exterior steele casing diameter - 9")

Solicitation No. - N° de l'invitation
5P420-16-5141/A

Amd. No. - N° de la modif.
004

Buyer - l'acheteur
Jen Maheu

Client Ref. No. - N° de réf. du client
711

File Name - Nom du dossier
Démolition de l'écloserie et du Bureau principal des gardes de parc, et remise en
état du terrain - Parc national Jasper

All other terms and conditions remain unchanged.