



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

INVITATION TO TENDER

APPEL D'OFFRES

AMENDMENT / MODIFICATION

005

Tender To: Parks Canada Agency
 We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Trans-Canada Highway Twinning – km 82-88 Yoho National Park		
Solicitation No. - No. de l'invitation 5P420-16-5123/A		Date: August 23, 2016
GETS Reference No. – No de reference de SEAG PW-16-00739080		Amendment No. - N° de la modif. 005
Solicitation Closes:		
at – á 02:00 PM	on – le August 25, 2016	Time Zone - Fuseau horaire MDT - HAR
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Nathaniel Harrison - nathaniel.harrison@pc.gc.ca		
Telephone No. - No de téléphone (403) 292-4572		Fax No. – No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein – Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 5

This amendment has been issued to answer questions from bidders.

A. Questions

Q119 For merchantable timber as defined by the contract, where is acceptable storage of the salvaged timber? Who defines which timber is merchantable or not?

A119 Merchantable timber may be stored at suitable locations along the grade as accepted by the Departmental Representative or in Mannix Pit. Merchantable timber is to be removed from site as soon reasonably possible.
Merchantable timber is all timber with butt diameter in excess of 150 mm and top down to 100 mm.

Q120 Is it mandatory to salvage the stem for firewood?

A120 50% of suitable stems shall be salvaged for firewood. The Departmental Representative may choose to reduce the stem salvage requirement at their sole discretion.

Q121 Can the Reinforced Soil Retaining Wall drawings supplied in the tender documents be used as the basis of shop drawings by the MSE supplier? If not, the design of the walls will not be able to start before winter due to the need for detailed survey in the proposed retaining wall areas.

A121 The Reinforced Soil Retaining Wall wall drawings provided are for general arrangement purposes. The design/builder may use them to develop the shop drawings however it is the Contractor's responsibility to verify elevations in the field. Available survey information will be provided to the Contractor upon request.

All other terms and conditions remain unchanged.