
Washroom Buildings Recapitalization - Malady Head Campground
Terra Nova National Park, NL
Solicitation No. EA003-171099/A
Project No. R.079276.001

Issued August 24, 2016

Addendum No. 1

Page 1 of 2

PART 1 SPECIFICATION

- .1 Reference Specification Division 1 - General Requirements, Section 01 00 00 General Requirements;
 - 1. Delete Section 01 00 00 General Requirements and replace with new Section 01 00 00 General Requirements attached to this addendum.

- .2 Reference Specification Division 1 - General Requirements, Section 01 35 28 Health and Safety Requirements;
 - 1. Delete Section 01 35 28 Health and Safety Requirements and replace with new Section 01 35 28 Health and Safety Requirements attached to this addendum.

- .3 Reference Specification Division 7 - Thermal and Moisture Protection, Section 07 84 00 Firestopping;
 - 1. Delete Section 07 84 00 Firestopping and replace with new Section 07 84 00 Firestopping attached to this addendum.

- .4 Reference Specification Division 7 - Thermal and Moisture Protection, Section 07 90 00 Joint Sealing;
 - 1. Delete Section 07 90 00 Joint Sealing and replace with new Section 07 90 00 Joint Sealing attached to this addendum.

- .5 Reference Specification Division 10 - Specialties, Section 10 21 20 – Solid Plastic Toilet Partitions, Paragraph 2.1.3;
 - .1 Delete paragraph 2.1.3 and add new paragraph 2.1.3.
 - .3 Acceptable Products: Global Partitions and Bobrick.

Washroom Buildings Recapitalization - Malady Head Campground

Terra Nova National Park, NL

Solicitation No. EA003-171099/A

Project No. R.079276.001

Issued August 24, 2016

Addendum No. 1

Page 2 of 2

PART 2 DRAWINGS

- .1 Reference Electrical Drawings E2 - Existing/Demolition Floor Plans and New Building #1 Layout and E3 – Building #2 & #3 New Electrical Layouts

In EACH building, Electrical contractor to supply and install a 120V toggle switch for each washroom exhaust fan. Toggle switch to be located in service room of each building. Coordinate on site.

PART 3 ATTACHMENTS

- .1 Section 01 00 00 General Requirements
.2 Section 01 35 28 Health and Safety Requirements
.3 Section 07 84 00 Firestopping
.4 Section 07 90 00 Joint Sealing

END OF ADDENDUM NO. 1

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all amendments and has included all costs of these requirements in its Total Bid Amount.

All other terms & conditions remain unchanged.
