



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fire Alarm Upgrade	
Solicitation No. - N° de l'invitation EZ899-170812/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2016-08-24
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7842	
File No. - N° de dossier PWY-6-39087 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-08-30	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: TC - Penticton Airport - Penticton, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-170812/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-6-39087

CCC - FMS No./N° VME

Amendment 002 is raised to issue Addendum #001.

Please find Addendum #001 herein.

All other terms and conditions remain unchanged.

THE FOLLOWING ADDENDUM SUPERCEDES INFORMATION CONTAINED IN DRAWINGS AND SPECIFICATIONS ISSUED FOR THE PROJECT TO THE EXTENT REFERENCED. THIS ADDENDUM FORMS PART OF THE TENDER DOCUMENTS AND IS SUBJECT TO ALL OF THE CONDITIONS SET OUT IN THE CONTRACT CONDITIONS.

This addendum contains one(1) page..

Part 1 Specifications

1.1 PROJECT NAME

- .1 Project name should read: PENTICTON AIRPORT FIRE ALARM REPLACEMENT. Revise this throughout the documents.

1.2 SECTION 28 31 00

- .1 Add 1.5.2.7: "Proposed conduit routing drawing for review and approval prior to initiating work. Drawing shall indicate proposed routing, surface/recessed installation and proposed mounting methodology".

Part 2 Drawings

2.1 PROJECT NAME

- .1 Project name should read: PENTICTON AIRPORT FIRE ALARM REPLACEMENT. Revise this throughout the drawings.
- .2 In the Title Block: Replace "Government of Canada Building" with "Penticton Regional Airport".

2.2 DRAWING E200

- .1 Add Note 12: "12. Contractor to provide a proposed conduit routing drawing to Departmental Representative for review and approval prior to initiating work. Drawing shall indicate proposed routing, surface/recessed installation and proposed mounting methodology".
- .2 Add Note 13: "13. Contractor shall allow for and provide multiple fire alarm verifications as required to suit the schedule, installation work flow, allowed hours of work and no disruption to the existing fire alarm system, or operations of the building. Request for extra for additional verifications will not be considered".

2.3 DRAWING E300 AND ASSOCIATED SPECIFICATIONS

- .1 Replace existing site wide fire alarm panel located at "old Fire Hall" with new Edwards QS4 addressable system to allow for a networked communication to new panels in ATB and FSS. Replacement panel shall connect to existing zones using conventional zone modules are appropriate on board inputs. Replicate programming from existing panel into new system. Ensure 100% compatibility with all existing devices and zones connected to this panel as well as new equipment to be installed in ATB and FSS.
- .2 END OF ADDENDUM NO. 01