



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Roof Replacement		
Solicitation No. - N° de l'invitation EP922-171041/A		Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client AAFC EP922-171041		Date 2016-08-25
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-10829		
File No. - N° de dossier PWU-6-39113 (201)	CCC No./N° CCC - FMS No./N° VME	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-09-02		Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector		Buyer Id - Id de l'acheteur pwu201
Telephone No. - N° de téléphone (780) 901-0989 ()		FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: See Herein		

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP922-171041/A
Client Ref. No. - N° de réf. du client
AAFC EP922-171041

Amd. No. - N° de la modif.
003
File No. - N° du dossier
PWU-6-39113

Buyer ID - Id de l'acheteur
pwu201
CCC No./N° CCC - FMS No./N° VME

Veillez consulter la version anglaise de la modification no 003

The following change(s) to the tender documents are effective immediately, and will form part of the contract documents:

1. GENERAL

1.1	The Bidding Documents are amended as noted in this Addendum, which consists of 1 page and attached sketches.
1.2	This Addendum is issued prior to bid closing to incorporate revisions noted herein. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the Contract Documents.
1.3	All affected drawings, schedules and panel changes shall be reflected in final as-built and manual submissions.

2. CHANGES TO PREVIOUS ADDENDA

2.1	N/A
-----	-----

3. DRAWINGS

3.1	<u>Drawing E1.1 – Electrical Existing and Demolition</u> Add: Unit heaters shown in Metabolism Room 100 are to be disconnected and re-installed to allow for replacement of the roof decking.
3.2	<u>Drawing E1.2 – Electrical New Construction</u> Add: Fixtures in sink room 119 are to be type K, Fixtures in office 120 are to be type E there are 2 fixtures in office 121 that are to be type E.

4. SPECIFICATIONS

4.1	<u>Section 28 31 00 – Fire Detection and Alarm</u> Add: Contractor to include all costs associated with fire alarm verification, including costs associated with Manufacturer's Representative, and Engineering Certification.
-----	--

End of Addendum No.2.