

1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Thermal insulation for piping and piping accessories in commercial type applications.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ASHRAE Standard 90.1, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA co-sponsored; ANSI approved; Continuous Maintenance Standard).
- .2 American Society for Testing and Materials International (ASTM)
 - .1 ASTM B209M, Standard Specification for Aluminum and Aluminum Alloy Sheet and Plate Metric.
 - .2 ASTM C335, Standard Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C411, Standard Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C449/C449M, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C533, Calcium Silicate Block and Pipe Thermal Insulation.
 - .6 ASTM C547, Mineral Fiber Pipe Insulation.
 - .7 ASTM C795, Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
 - .8 ASTM C921, Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.
- .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52Ma, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .2 CAN/CGSB-51.53, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts.
- .4 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Assessment Act (CEAA), c. 37.
 - .2 Canadian Environmental Protection Act (CEPA), c. 33.
 - .3 Transportation of Dangerous Goods Act (TDGA), c. 34.
- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .6 Manufacturer's Trade Associations
 - .1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards.
- .7 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102, Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701, Thermal Insulation, Polystyrene, Boards and Pipe Covering.
 - .3 CAN/ULC-S702, Thermal Insulation, Mineral Fibre, for Buildings.
 - .4 CAN/ULC-S702.2, Thermal Insulation, Mineral Fibre, for Buildings, Part 2: Application Guidelines.

1.3 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services in suspended ceilings and non-

accessible chases and furred-in spaces.

.2 "EXPOSED" - will mean "not concealed" as specified.

.2 TIAC ss:

.1 CRF: Code Rectangular Finish.

.2 CPF: Code Piping Finish.

1.4 SUBMITTALS

.1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.

.2 Product Data:

.1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

.1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.

.3 Shop Drawings:

.1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.

.4 Samples:

.1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.

.2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix label beneath sample indicating service.

.5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.

.1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

.2 Instructions: submit manufacturer's installation instructions.

.1 Consultant will make available 1 copy of systems supplier's installation instructions.

1.5 QUALITY ASSURANCE

.1 Qualifications:

.2 Installer: specialist in performing work of this Section, and have at least 3 years successful experience in this size and type of project, qualified to standards of TIAC.

.3 Health and Safety:

.1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health, Safety and Emergency Response Procedures.

1.6 DELIVERY, STORAGE AND HANDLING

.1 Packing, shipping, handling and unloading:

.1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.

.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.3 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

.2 Storage and Protection:

.1 Protect from weather, construction traffic.

.2 Protect against damage.

.3 Store at temperatures and conditions required by manufacturer.

- .3 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse in accordance with Section 01 74 19 - Construction Waste Management Disposal.
 - .2 Place excess or unused insulation and insulation accessory materials in designated containers.
 - .3 Divert unused metal materials from landfill to metal recycling facility approved by Consultant.
 - .4 Dispose of unused adhesive material at official hazardous material collections site approved by Consultant.

2 Products

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102.
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C335.
- .3 TIAC Code A-3: rigid moulded mineral fibre with factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC-S702.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to CAN/ULC-S702.

2.3 INSULATION SECUREMENT

- .1 Tape: self-adhesive, aluminum, plain, 50 mm wide minimum.
- .2 Contact adhesive: quick setting.
- .3 Canvas adhesive: washable.
- .4 Tie wire: 1.5 mm diameter stainless steel.
- .5 Bands: stainless steel, 19 mm wide, 0.5 mm thick.

2.4 CEMENT

- .1 Thermal insulating and finishing cement:
 - .1 Hydraulic setting on mineral wool, to ASTM C449/C449M.

2.5 VAPOUR RETARDER LAP ADHESIVE

- .1 Water based, fire retardant type, compatible with insulation.

2.6 INDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 PRE-INSTALLATION REQUIREMENT

- .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed

and certified.

- .2 Surfaces clean, dry, free from foreign material.

3.3 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
 .2 Apply materials in accordance with manufacturers instructions and this specification.
 .3 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 .1 Install hangers, supports outside vapour retarder jacket.
 .4 Supports, Hangers:
 .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

3.4 PIPING INSULATION SCHEDULES

- .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.
 .2 TIAC Code: A-3.
 .1 Securements: SS wire at 300 mm on centre.
 .2 Seals: VR lap seal adhesive, VR lagging adhesive.
 .3 Installation: TIAC Code: 1501-C on all DCW & DHW lines.
 .4 Thickness: 25mm.

Application	Temp °C	TIAC Code	Pipe sizes (NPS) and insulation thickness (mm)					
			Run out	To 1	1½ to 2	2½ to 4	5 to 6	8 & over
Steam	up to 175	A-1	38	50	65	75	90	90
Steam, Saturated and Super heated	over 175	A-1	38	65	65	75	90	90
Condensate Return	60 - 94	A-1	25	38	38	38	38	38
Pumped Condensate return	up to 94	A-1	25	38	38	38	38	38
Boiler Feed Water		A-1	25	25	25	25	25	25
Hot Water Heating	60 - 94	A-1	25	38	38	38	38	38
Hot Water Heating	up to 59	A-1	25	25	25	25	38	38
Glycol Heating	60 - 94	A-1	25	38	38	38	38	38
Glycol Heating	up to 59	A-1	25	25	25	25	38	38
Domestic HWS		A-1	25	25	25	38	38	38
Chilled Water	4 - 13	A-3	25	25	25	25	25	25
Chilled Water or Glycol	below 4	A-3	25	25	38	38	38	38
Dual Temp. Heating		A-3	—	—	—	—	—	—
Dual Temp. Cooling		A-3	—	—	—	—	—	—
Chilled Water Pump Casing		A-3	25	25	25	25	25	25
Condenser Water Outdoors		—	—	—	—	—	—	—
Condenser Water Indoors		—	—	—	—	—	—	—
Refrigerated Drinking Water		A-3	25	25	25	25	25	25
Domestic CWS		A-3	25	25	25	25	25	25
Domestic CWS with vapour retarder		C-2	25	25	25	25	25	25
Refrigerant hot gas	4 - 13	A-6	25	25	25	25	25	25
Refrigerant hot gas	below 4	A-6	25	25	38	38	38	38
RWL and RWP		C-2	25	25	25	25	25	25
Cooling Coil cond. drain		C-2	25	25	25	25	25	25
Diesel generator exhaust system		A-2	38	65	65	75	90	90

- .3 Finishes:
 .1 Exposed indoors: canvas.
 .2 Exposed in mechanical rooms: canvas.
 .3 Concealed, indoors: Integral all service jacket.
 .4 Use vapour retarder jacket on TIAC code A-3 insulation compatible with insulation.
 .5 Finish attachments: SS screws, at 150 mm on centre. Seals: wing.

.6 Installation: to appropriate TIAC code CRF/1 through CPF/5.

3.5 CLEANING

- .1 Proceed in accordance with Section 01 74 19 - Construction Waste Management Disposal.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SECTION INCLUDES

- .1 Materials and installation for copper domestic water service used in the following:
 - .1 Hard drawn copper domestic hot and cold water services inside building.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 35 29 - Health, Safety and Emergency Response Procedures.
- .3 Section 01 78 00 - Closeout Submittals.
- .4 Section 01 91 13 - General Commissioning Requirements.
- .5 Section 21 05 01 - Common Work Results - Mechanical.
- .6 Section 22 07 19 - Thermal Insulation for Plumbing Piping.

1.3 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers International (ASME).
 - .1 ANSI/ASME B16.15, Cast Bronze Threaded Fittings, Classes 125 and 250.
 - .2 ANSI/ASME B16.18, Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ANSI/ASME B16.22, Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
 - .4 ANSI/ASME B16.24, Cast Copper Alloy Pipe Flanges and Flanged Fittings, Class 150, 300, 400, 600, 900, 1500 and 2500.
- .2 American National Standards Institute / National Sanitation Foundation (ANSI/NSF)
 - .1 ANSI/NSF 61 Drinking Water System Components.
- .3 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A307, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .2 ASTM A536 Standard Specification for Ductile Iron Castings.
 - .3 ASTM B88M, Standard Specification for Seamless Copper Water Tube (Metric).
 - .4 ASTM F492, Standard Specification for Polypropylene (PP) Plastic-Lined Ferrous Metal Pipe and Fittings.
- .4 Department of Justice Canada (Jus).
 - .1 Canadian Environmental Protection Act, (CEPA).
- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .6 National Research Council (NRC)/Institute for Research in Construction.
 - .1 NRCC 38728, National Plumbing Code of Canada (NPC).
- .7 Transport Canada (TC).
 - .1 Transportation of Dangerous Goods Act, (TDGA).

1.4 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit product data for following: piping, fittings, valves.
- .3 Submit WHMIS MSDS - Material Safety Data Sheets.
- .4 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 HEALTH AND SAFETY

- .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health, Safety and Emergency Response Procedures.

1.6 STORAGE AND HANDLING

- .1 Store and manage hazardous materials.

1.7 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse in accordance with Section 01 74 19 - Construction Waste Management Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Separate for reuse and recycling and place in designated containers Steel waste in accordance with Waste Management Plan.
- .4 Place materials defined as hazardous or toxic in designated containers.
- .5 Handle and dispose of hazardous materials in accordance with CEPA and local or municipal regulations.
- .6 Fold up metal banding, flatten and place in designated area for recycling.

2 Products

2.1 PIPING

- .1 Domestic hot, cold and recirculation systems, within building.
 - .1 Above ground:
 - .1 Copper tube, hard drawn, type L: to ASTM B88M.

2.2 FITTINGS

- .1 Cast copper, solder type: to ANSI/ASME B16.18.
- .2 Wrought copper and copper alloy, solder type: to ANSI/ASME B16.22.
- .3 NPS 1½ and under: Cast copper, ANSI/ASME B16.18 or wrought copper, ANSI/ASME B16.22; with 301 stainless steel internal components. EPDM seal and push to connect or press fit joints, hand drawn copper tube type L or K rated for 1300 kPa at ASTM B88.

2.3 JOINTS

- .1 Solder: 95/5 lead free.
- .2 Dielectric connections between dissimilar metals: dielectric fitting to ASTM F492, complete with thermoplastic liner.
- .3 Press Fitted: EPDM gasket, UL classified in accordance with ANSI/NSF 61 for potable water service.

2.4 BALL VALVES

- .1 NPS 2 and under, screwed:
 - .1 Class 150.
 - .2 Bronze body, chrome plated brass ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle.
- .2 NPS 2 and under, soldered:
 - .1 To ANSI/ASME B16.18, Class 150.
 - .2 Bronze body, chrome plated brass ball, PTFE adjustable packing, brass gland and PTFE seat, steel lever handle, with NPT to copper adaptors.

3 Execution

3.1 INSTALLATION

- .1 Install in accordance with NPC and local authority having jurisdiction.
 - .2 Assemble piping using fittings manufactured to ANSI standards.
 - .3 Install CWS piping below and away from HWS and HWC and other hot piping so as to maintain temperature of cold water as low as possible.
-

- .4 Connect to fixtures and equipment in accordance with manufacturer's written instructions unless otherwise indicated.
- .5 Install pipe work by certified Journey Person supplemented as specified herein.

3.2 VALVES

- .1 Isolate equipment, fixtures and branches with ball valves.
- .2 Balance recirculation system as required and mark settings and record on as-built drawings on completion.

3.3 PRESSURE TESTS

- .1 Conform to requirements of Section 21 05 01 - Common Work Results - Mechanical
- .2 Test pressure: greater of 1-½ times maximum system operating pressure or 860 kPa.

3.4 FLUSHING AND CLEANING

- .1 Flush entire system for 8 h. Ensure outlets flushed for 2 h. Let stand for 24 h, then draw one sample off longest run. Submit to testing laboratory to verify that system is clean. Let system flush for additional 2 h, then draw off another sample for testing.

3.5 PRE-START-UP INSPECTIONS

- .1 Systems to be complete, prior to flushing, testing and start-up.
- .2 Verify that system can be completely drained.
- .3 Ensure that pressure booster systems are operating properly.
- .4 Ensure that air chambers, expansion compensators are installed properly.

3.6 DISINFECTION

- .1 Flush out, disinfect and rinse system to requirements of authority having jurisdiction.
- .2 Upon completion, provide laboratory test reports on water quality for Consultant approval.

3.7 START-UP

- .1 Timing: Start up after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Water treatment systems operational.
- .2 Provide continuous supervision during start-up.
- .3 Start-up procedures:
 - .1 Establish circulation and ensure that air is eliminated.
 - .2 Check pressurization to ensure proper operation and to prevent water hammer, flashing and/or cavitation.
 - .3 Bring HWS storage tank up to design temperature slowly.
 - .4 Monitor piping HWS and HWC piping systems for freedom of movement, pipe expansion as designed.
 - .5 Check control, limit, safety devices for normal and safe operation.
- .4 Rectify start-up deficiencies.

3.8 PERFORMANCE VERIFICATION

- .1 Timing:
 - .1 After pressure and leakage tests and disinfection completed, and certificate of completion has been issued by authority having jurisdiction.
- .2 Procedures:
 - .1 Sterilize HWS and HWC systems for Legionella control.
 - .2 Verify performance of temperature controls.

- .3 Verify compliance with safety and health requirements.
- .4 Check for proper operation of water hammer arrestors. Run one outlet for 10 seconds, then shut off water immediately. If water hammer occurs, replace water hammer arrestor or re-charge air chambers. Repeat for outlets and flush valves.
- .5 Confirm water quality consistent with supply standards, verifying that no residuals remain as a result of flushing and/or cleaning.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM B32, Specification for Solder Metal.
 - .2 ASTM B306, Specification for Copper Drainage Tube (DWV).
 - .3 ASTM C564, Specification for Rubber Gaskets for Cast Iron Soil Pipe and Fittings.
- .2 Canadian Standards Association (CSA International).
 - .1 CSA B67, Lead Service Pipe, Waste Pipe, Traps, Bends and Accessories.
 - .2 CAN/CSA-B70, Cast Iron Soil Pipe, Fittings and Means of Joining.
 - .3 CAN/CSA-B125, Plumbing Fittings.

1.2 QUALITY ASSURANCE

- .1 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29 - Health, Safety and Emergency Response Procedures.

1.3 DELIVERY STORAGE AND DISPOSAL

- .1 Waste Management and Disposal:
 - .1 Collect and separate for disposal paper packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.

2 Products

2.1 COPPER TUBE AND FITTINGS

- .1 Above ground sanitary, storm and vent Type DWV to: ASTM B306.
 - .1 Fittings.
 - .1 Cast brass: to CAN/CSA-B125.
 - .2 Wrought copper: to CAN/CSA-B125.
 - .2 Solder: lead free, 95:5 antimonial tin solder, type TA, to ASTM B32.

2.2 CAST IRON PIPING AND FITTINGS

- .1 Above ground sanitary, storm and vent: to CAN/CSA-B70.
 - .1 Joints.
 - .1 Mechanical joints.
 - .1 Neoprene or butyl rubber compression gaskets with stainless steel clamps.

3 Execution

3.1 INSTALLATION

- .1 Install in accordance with Canadian Plumbing Code and local authorities having jurisdiction.

3.2 TESTING

- .1 Hydraulically test to verify grades and freedom from obstructions.

3.3 PERFORMANCE VERIFICATION

- .1 Cleanouts:
 - .1 Ensure accessible and that access doors are correctly located.
 - .2 Open, cover with linseed oil and re-seal.
-

- .3 Verify that cleanout rods can probe as far as the next cleanout, at least.
- .2 Test to ensure traps are fully and permanently primed.
- .3 Ensure that fixtures are properly anchored, connected to system and effectively vented.
- .4 Affix applicable label (storm, sanitary, vent, pump discharge etc.) c/w directional arrows every floor or 4.5 m (whichever is less).

END OF SECTION