

**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A: Bid Receiving/Réception  
des soumissions**

Procurement and Contracting Services  
73 Leikin Drive,  
Visitor Center - Building M1  
Mailstop # 15  
Ottawa, ON K1A 0R2

**Attn: Shannon Plunkett**

**Facsimile Number for Amendments: 613.825.0082**

**AMENDMENT - INVITATION TO TENDER**

**MODIFICATION - APPEL D'OFFRES**

**Tender to: Royal Canadian Mounted Police**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

**Soumission aux: Gendarmerie royale du Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

**Comments - Commentaries**

**Vendor/Firm Name and Address  
Raison sociale et adresse du fournisseur/de l'entrepreneur  
Facsimile No. - No de télécopieur:  
Telephone No. - no de telephone:**

<b>Title-Sujet:</b> CONSTRUCTION – Sept Iles Detachment	
<b>Solicitation No. - No. de l'invitation</b> 201702621	<b>Date</b> Aug 25, 2016
<b>Client Reference No. - No. De Référence du Client</b> 201702621	<b>Amend No.- No. du modif.</b> 005
<b>GETS Reference No. - No. de Référence de SEAG</b> 201702621	
<b>Solicitation Closes –L'invitation prend fin</b>  <b>at - à 14 :00 ET</b> <b>on - le Sept 1 2016</b>	
<b>F.O.B. - F.A.B.</b> Destination	
<b>Address Enquiries to: - Adresser toutes questions à:</b>  <a href="mailto:dale.rudderham@rcmp-grc.gc.ca">dale.rudderham@rcmp-grc.gc.ca</a>	
<b>Telephone No. - No de telephone</b> 613.843.5313	<b>Fax No. - N° de FAX:</b>
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>	
<b>Delivery Required - Livraison exigée:</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>	

Amendment #5 of Solicitation 201702621 has been issued to **distribute the Addendum No.2, and respond to Questions PART 3** as follows:

---

**1. Addendum No.2 is attached to posting**

201702621\_Addendum2.pdf

*Devis et croquis Architecture (F) Addenda A1 -> pp 1 to 17*

*Specs and sketches Architect (E) Addenda A1 -> pp 18 to 80*

*Devis Mecanique (F) Addenda M02 -> pp 81 to 82*

*Specs Mechanical (E) Addenda M02 -> pp 83 to 84*

*Mechanical Dessins/Drawings (B) -> pp 85 to 86*

*Devis Electrique (F) Addenda E2 -> pp 87 to 89*

*Specs Electrical (E) Addenda E2 -> pp 90 to 92*

**2. Questions Part 3**

Q35. Section 09 65 19, art. 2.1.1: Is there a boss laying (pattern) for vinyl tile, as there are 2 colors, or there are 2 colors for the project, but one (1) single color in one room?

**A35. See note 22 on page A400**

Q36. Section 09 30 13, art. 2.6.5: Can you specify where the marble thresholds versus transition strips of stainless steel?

**A36. There will be no marble threshold, see addendum No.2, A02**

Q37. A100 13 NOTES: Does the diagonal lines with a width of 1100 mm in the room 602, in line with the door 503, which correspond to note 13?

**A37. Yes, see addendum No.2, A02**

Q38. A605 TABLE OF FINISHED - Local 103 and 604: There is a discrepancy between the table of finishes (finished walls) and views of the A402 sheet. Confirm that the table finished supersedes views.

**A38. See Addendum No.2, A02.**

Q39. A605 LEGEND FLOOR FINISHES: The vinyl coating sheet is identified by the letters VIN, while in quotes (09 65 16) identifying the product by RS1 letters (article 2.1.1.1 and 2.1.2.1.). We speak indeed of the same coating?

**A39. Yes, see addendum No.2, A02**

Q40. Section 09 65 16, art. 2.1.1.1: We demand an integrated plinth, whereas following point (2.1.2) specifying a flexible baseboard throat. In 2.1.5, we also mentioned a PVC cove base trim with a radius of 1 ½ ?!

**A40. See addendum No.2, A02**

Q41. Section 09 65 16, art. 3.4.9: We mentioned stripes. Ascertaining whether there are stripes. If so, give the boss asks or percentage to predict.

**A41. There will be no decorative band, see addendum No.2, A02.**

Q42. Is it possible to do the work of sod and shrubs plantations after the end date of the work mentioned in the quote, March 31, 2017.

**A42. Yes it will be possible to complete landscaping and paving work after March 31st 2017.**

Q43. Is it possible to add these quotes sections, they are not in the tender documents. 05-12-23 / 05-21-00 / 05-31-00

**A43. See addendum No.1, M01**

Q44. Is it possible to know the color of the coating Corrugated, to quote, it is the color QC-7500 and plans is QC-2624

**A44. See addendum No.2, A02**

Q45. Regarding Article CS01, should we provide this in our submission

**A45. The RCMP will require personnel information after the award of the contract to perform security checks. This is at the expense of the RCMP.**

Q46. What are the weight of the mechanical units (4)?

**A46. Weights of units will vary depending on supplier of the units and there is only 3 rooftop units on the roof;**

**RTU1 and 3 approx.; 350 kg (design based on LCA036H4D as outlined in addendum M01)**

**RTU2 approx.; 720 kg (design based on LCC120S4B as outlined in addendum M01)**

Q47. Do aerodynamics really need to run through the joists? (See General notes # 7 of mech, M300 drawings). If so, can you confirm which part of the building is the "lower roof"? (I guess it's part inverted "L" shape, H-N and K-N, ranging from 1-8).

**A47. Bid as per plans and spec. See architectural drawings**

Q48. Is it possible to provide the quotes section quotes Section 07 52 16 elastomeric bitumen membrane roof, it is not found in the specifications part 1 of 3.

**A48. See addendum No.1, A01.**

Q49. Is it possible to specify the spacing of sub girts please.

**A49. The z-bar spacing will be as per manufacturers recommendation (approximately 1200mm)**

Q50. See among other composition M1-B / M2-B.

**A50. See addendum No.2, A02**

Q51. Spec 26 32 13.04, p6, by 1.5.4; " Tools " no tools are required for the client.

**A51. As per specification description**

Q52, Spec 26 32 13.04, p6, with 1.6 " Quality Assurance Z299.3 " offer ISO9001.

**A52. As per specification description**

Q53. Spec 26 32 13.04, p7, by 2.2.1.7 " Calculation criteria, " the 10% surcharge is not required by CSA C282.

**A53. As per specification description**

Q54. Spec 26 32 13.04, p14, by 2.7.5.1 " Lubrication System ", a pump priming with time stamp is not required, given that there is an automatic exerciser in the automatic transfer switch and this item is not approved by the manufacturer.

**A54. As per specification description**

Q55. Spec 26 32 13.04, p18, by 2.12.7 " start system, " turbo equipped with an accumulator spring for pre-lubrication is not required as there is an automatic exerciser in the transfer switch Automatic and this item is not approved by the manufacturer.

**A55. As per specification description**

Q56. Spec 26 32 13.04, p18, by 2.13.4 " generator ", the current standards are for class H insulation and elevation of 130 degrees C for heating.

**A56. As per specification description**

Q57. Spec 26 32 13.04, p27, by 2.20..6 " factory quality control, " the 10% surcharge is not required by CSA C282.

**A57. Specification description is reasonably clear.**

Q58. Spec 26 36 23, p3, with 2.3 " contactors switchgear ", is the breaker type accepted?

**A58. As per specification description**

Q59. Spec 26 36 23 p4, by 2.3.10 " touch overlapping neutral ", is required?

**A59. As per specification description**

Q60. Spec 26 36 23, p7, by 2.5.9 'Manual Bypass isolator and the two types of sources,' 'validate whether it is an inverter (transfer switch) type' 'Bypass and isolation switches.'

**A60. Specification description is reasonably clear.**

Q61. DIVISION 08 (3 sections missing) and Section 08 50 00 window does not appear in the table of contents)

08 31 00.01 – visitor doors and mechanical systems installation (see part 2 of 3)

**A61. This is part of the mechanical spec**

Q62. DIVISION 10 (One section is missing)

10 44 16.19 – portable fire extinguishers and safety covers (see part 2 of 3);

**A62. This is part of the mechanical spec**

Q63. DIVISION 22 (1 section is missing)

22 15 00 – compressed air systems for general use

**A63. See Addendum No.1, M01**

Q64. DIVISION 23 (8 sections are missing)

23 07 13 – Thermal Insulation for air ducts

**A64. See Addendum No.1, M01**

Q65. 23 23 00 – self-contained refrigeration air-cooled (in the quotation this section is numbered 23 81 40)

**A65. See Addendum No.2, M02**

Q66. 23 31 14 – metal air ducts - Low pressure up to 500 Pa

**A66. See Addendum No.1, M01**

Q67. 23 33 00 – Accessories for air ducts

**A67. See Addendum No.1, M01**

Q68. 23 33 14 – balancing registers

**A68. See Addendum No.1, M01**

Q69. 23 33 53 – acoustic linings for air ducts

**A69. See Addendum No.1, M01**

Q70. 23 34 24 – Fans for domestic use

**A70. See Addendum No.1, M01**

Q71. 23 36 00 – terminal elements of air systems

**A71. See Addendum No.1, M01**

Q72. 23 37 13 – Diffusers, grilles and registers

**A72. See Addendum No.1, M01**

Q73. 23 73 11 - Air treatment - monoblock devices (in the quote this section also has the number 23 05 53.01)

**A73. See Addendum No.1, M01**

Q74. DIVISION 25 (1 section is missing)

25 90 01 – SGE : Site Requirements and systems operating sequences

**A74. See Addendum No.1, M01**

Q75. Are there regulatory drawings queued for release?

**A75. No control schematics see spec addendum M01 section 25 90 01**

Q76. Do we have to control the 3 RTU's and if so, could we have a listing of the points to control or sequences of operation?

**A76. See addendum No.1, M01 section 25 90 01**

Q77. Concerning the VAV Boxes, on drawing #M403 there is a note that says that the boxes are coming with an actuator. In section 25 05 60 1.3.3.1 we have to provide the actuators. Do we have to include them?

**A77. See addendum No.2, M02**

Q78. The E101 design, drawing notes 1, 2 and 3 mention that the thermostat is provided by the division 23. Is it right or is the thermostat provided by us (Division 25)?

**A78. Correction provided in Addendum.**

Q79. Are the costs for obtaining the building permit is the responsibility of the general contractor?

**A.79. Yes.**

Q80. Regarding the masonry work on the new RCMP building in Sept-Iles, is that it would be possible to validate internal and external mortar type? The 045,012 estimate section asks us to use the type of mortar S outside and Type N mortar inside. However the concrete block and brick supplier is recommended to do the opposite, ie the N-type outside and type S inside.

**A81. Use mortar type N both interior and exterior**

Q82. Is it mandatory to use lightweight concrete blocks as requested to quote 042200 Article 2.1.1.1 because it costs 2 times more expensive to purchase and must be added production expenses? Also this block will not be returnable as it is a special production.

**A82. Use standard concrete block instead of light concrete block.**

Q83 You ask in the table doors several doors "CTS-52"; do you want doors with approved label or it will be standard doors steel and wood and is the appetite to its hardware specifications that will index the cutter (index 52 will never be achieved in this way) ?

**A83 homologated door**

Q84 Quote Wood doors are requested without finishing and finishing will be done on site. Normally the finish is done by the factory door manufacturing because it is much cheaper for the customer to do at the factory site by a painter. What should we provide?

**A84. Factory finish**

Q85. Door # 101.1: Table door is requested and door frame exterior steel; the quote is a hardware # 1 for aluminum door. What should we provide?

**A85. Exterior thermally broken door.**

Q86. Door # 203.2: it is not in the table and is the group quote # 7. What should we provide? if not, nomenclature.

**A86 Yes the nomenclature will be similar to 203.1.**

Q87. Door # 201: You ask a wooden door "CTS-52"; there is no manufacturer that makes wooden door with this factor ... The maximum is "CTS-50". If you want to "CTS-52" must provide a steel door. What should we provide?

**A87. A STC-50 wood door is acceptable.**

Q88. The luminaire Type C1 is not in the picture

**A88. For light type C1 see addendum no. E2, also, provide four (4) type 'e2' led lighting fixture to underside of canopy at rear connected to building perimeter lighting fixture circuit 'pe1-1' controlled by photocell. see detail '4/e001'. acceptable material : senso lighting #leto 13 685-581-618-60-01-13 or approved equivalent.**

Q89. Is it possible to propose weapons locker models for fire / hanging wall shelf

**A89. See drawings A100 note no.5**

Q90. **Can we fax our bids instead of mail or deliver them?**

**A90. No, we must receive the original bid prior to closing. However, you may revise your bid amount by fax up to solicitation closing time. Please see «instructions to bidders » in the Invitation to Tender for details.**

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.