



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Rock Creek Campground Upgrades Construction, Grasslands National Park		
Solicitation No.: / N° de l'invitation : 5P420-16-5170/A	Amendment No.: / N° de modification de l'invitation : 003	Date: August 29, 2016 Date : 29 août 2016
GETS Reference No.: / N° de référence de SEAG : PW-16-00742607		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: August 30, 2016	Time Zone: Mountain Daylight Time (MDT)
À : 14h00	Le : 30 août 2016	Fuseau horaire : Heure avancée des Rocheuses (HAR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 003

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5170/A:

A. QUESTIONS AND ANSWERS

Q26. The cable spec has a CEC **bare** ground wire installed from factory. (in this case this conductor will be a “bond” wire as defined by CEC 2015) and will be terminated as specified above. Are you requesting we supply and install a separate conductor for each branch cct and bond it back to the panel as well? (it is unnecessary according to CEC and will add significant cost to the project)

A26. No, a separate conductor is not required. Specified cable ACWU is to ground/bond the system.

Q27. It does not state if sask power will supply the feed from the transformer to our kiosk, or we provide that feed and conduit?

A27. Contractor to supply all feeder cables from the transformers to the electrical kiosks. Feeder sizes are provided on the panel schedules on sheet E4.0. All kiosks are to be grounded/bonded to the transformer.

Q28. On drawing E1 electrical single line drawing it also does not note who is responsible or what is to be provided from the service the kiosk to the transformer.

A28. Contractor to supply all feeder cables from the transformers to the electrical kiosks. Feeder sizes are provided on the panel schedules on sheet E4.0. All kiosks are to be grounded/bonded to the transformer.

Q29. Drawing E4 states the panel feeds to each panel, but typically this is done by the manufacture and is only from the utility termination point to the main breaker on the panel board.

A29. Feeder sizes are provided on the panel schedules on sheet E4.0.

Q30. Can we use RWU wire instead of ACWU?

A30. Armored cable is required.

Q31. How much seed needs to be put down per acre, hector etc?

A31. 50kg/HA

B. ADDENDA

Replace receptacles L6-50R and L5-30R on 50A RV pedestals detail on sheet E5.0 with 6-50R and 5-30R.

Replace receptacles L5-30R on 30A RV pedestals detail on sheet E5.0 with 5-30R

All other terms and conditions remain the same.