

AMENDMENT No.3

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;

1 – The Solicitation Closes date has been changed to September 1, 2016 at 2 PM (EDT):

2 – The attached Addendum #2 shall be added to the plans and specification:

(The form is attached to the end of this amendment)

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

PROJECT: Terra Nova National Park Ecoscience Building Recapitalization

MEI PROJECT #: CC15CRE066

ISSUE DATE: 25 August 2016

NOTICE TO BIDDERS:

The following is issued as an addendum to the above noted tender documents.

Replace existing specification section 02 82 13 1.2 with

1.2 SCOPE

- .1 For this work scope, lead based paint is noted to be present on portions of the existing structure. For the purposes of removal, transportation and disposal, some of the exterior lead based paint is leachable and shall be disposed of at a designated hazardous waste. Refer to the laboratory results appended to the specifications to determine paint that contains leachable lead.
- .2 Comply with requirements of this Section when performing following Work:
 - .1 Removal of potential flaking/peeling paint from the wood and concrete surfaces, as indicated on the drawings. Measures to be taken during removal shall be as determined in the document referenced in Part 1.1.1 of this specification section.
 - .2 Disposal of lead based paint, paint flakes, removed peeled paint and abrasive blasting material in accordance with the NL Department of Environment Regulations, as defined in the reference document noted under Part 1.1.5 of this specification section. For the purposes of removal, transportation and disposal, material containing a leachable lead concentration greater than 5 mg/L will be considered as hazardous waste and shall only be disposed of at a designated hazardous waste site.

Replace existing specification section 02 82 13 1.3.2 with

1.3 SUBMITTALS

- .2 Provide proof satisfactory to Departmental Representative that suitable arrangements have been made to dispose of lead based paint waste in accordance with requirements of authority having jurisdiction. Note that it is the Contractor's responsibility to determine an approved waste site for all flaking/peeling paint, associated substrates and spent abrasives for hazardous and non-hazardous materials.

Add specification section 02 82 13 1.3.7 as follows:

- .7 Provide written methodology outlining how lead paint will be contained during removal, stored, transported, and disposed of at the designated hazardous waste site. Written verification that the designated site is an approved hazardous waste must be provided prior to the start of work.

Replace existing specification section 02 82 13 3.2 with

3.2 RESPIRATORS

- .1 To be determined using the classification system as defined in the document referenced in Part 1.1.1 of this specification section.

Replace existing specification section 02 82 13 3.3.3 with

3.3 GENERAL

- .3 Drop sheets to be used below all lead operations which produce or may produce dust, chips, flakes, peeled paint or debris containing lead.

Replace existing specification section 02 82 13 3.4 with

3.4 MEASURES

- .1 Post signs to warn of lead hazard.
- .2 Wear respirators in accordance with Part 3.2 of this specification section.
- .3 Wear protective clothing to prevent skin contamination, including but not limited to coveralls, gloves, hats and footwear or disposable coverlets; safety glasses, face shields or goggles. All protective clothing to be removed at the end of each shift and be decontaminated.
- .4 Follow all other measures as outlined in the document referenced in Part 1.1.1 of this specification section.