



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Greenhouse Energy Management System	
Solicitation No. - N° de l'invitation EZ899-170983/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2016-08-30
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-7849	
File No. - N° de dossier PWY-6-39105 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-09-06	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 775-9382 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: NRCAN - Pacific Forestry Centre - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-170983/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°
PWY-6-39105

CCC - FMS No./N° VME

Amendment 001 is raised to issue Addendum #001.

Please find Addendum #001 herein.

All other terms and conditions remain unchanged.

Victoria, BC

PROJECT R.076293.001

The following changes/clarifications in the tender documents are effective immediately.
This addendum will form part of the contract documents.

- 1.0 On E1.0, for supply of new internal components: supply new internal wiring, terminal blocks, transformers, 24V power supply.
- 2.0 CSA recertification is required, as alternations to the panel void the previous certification.
- 3.0 Replace bases and relays in control panel.
- 4.0 NIC keynote 2 on E1.0 and E2.0, indicates no work to be done on this system.
- 5.0 Div 13 as per specifications, bidders to confirm with DIV 13 to ensure this is covered in their pricing. No extras to be provided if neither Division carried the cost.
- 6.0 Exit signs are NIC. None to be provided/installed.
- 7.0 Vent motor, and disconnects by DIV 26, supply, install, connect.
- 8.0 Vent motor control and feeder circuits in field to be retained.
- 9.0 T-Stat sensors to be replaced by DIV26.
- 10.0 DIV23 and DIV13 to co-ordinate for supply of electrical services to new control panels, breakers, feeders, power supplies and conduits. Existing 120/208V panel is located in H18. Assume connection from this location for new electrical services.

END OF ADDENDUM No. 1