

RFP 16-22061 Q & A Round 4

Q1: What 3rd party applications are being currently used and will require integration with solution?

A1: There is no any commercial 3rd party application to be integrated. An NRC/PSPC in-house application needs to share the building energy consumption data and work order data with the solution.

Q2: Do the anticipated work dates listed in RFP (September 15 to August 31, 2017) include the additional possible buildings listed in appendix C?

A2: It is possible.

Q3: What is meant by 24/7 support? Is it the software tracking issues 24/7 or is it a manned support portal?

A3: It is expected that the monitoring system will operate without any interruptions and that the results of such monitoring will be available on a 24/7 basis. It is also expected that any detected anomalies will be dealt with promptly.

Q4: Can you list the sites that have DDC remote access at the present time?

A4: No remote access at the present time.

Q5: Section 5.1 states the closing date is Tuesday September 2nd. However, September 2nd is a Friday. Please clarify.

A5: Closing Friday September 2.