



APPENDIX A

Note: This Appendix is for reference only. Contractor is responsible to coordinate with Newfoundland Power Representative and use the latest edition of this document.



NOTES:

1. ALL TRENCHES SHALL BE BACKFILLED WITH SELECT BACKFILL AND TAMPED IN 300mm LAYERS, EXCEPT AT ROAD CROSSINGS WHERE THE BACKFILL SHALL BE THE SAME MATERIAL AS THE ROAD BED AND TAMPED IN 150mm LAYERS. EXCESS FILL SHALL BE PLACED ON TOP TO ALLOW FOR SETTLING.
2. THE DUCTS SHALL BE SUPPORTED BY APPROVED SPACERS. NO METAL TIES ARE TO BE USED.
3. INSTALL MINIMUM #12 FISH WIRE IN EACH DUCT AND SECURELY CAP BOTH ENDS.
4. ELECTRICAL DUCT MUST BE PVC TYPE EB-1 OR APPROVED EQUIVALENT.
5. ALL DUCTS AND FITTINGS MUST BE CSA APPROVED.
6. ALL FITTINGS, COUPLINGS, ADAPTERS ARE TO BE SOLVENT WELD.
7. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS.



DISTRIBUTION STANDARDS



PROVINCE OF NEWFOUNDLAND
PERMIT HOLDER

This Permit Allows
NEWFOUNDLAND POWER INC.

To practice Professional Engineering
in Newfoundland and Labrador.
Permit No. as issued by APEGNL F0032
which is valid for the year 1999.

**DUCT INSTALLATION DETAILS
AT RISER POLE**

Date:	99-09-30	Drawn:	J.K.
App:	<i>AGB</i>	STD No.	27-7