



Materiel and Procurement Services
200 Kent Street, Station 9S018
Ottawa, Ontario
K1A 0E6

September 6, 2016

Subject: Invitation to Tender: FP802-160153

Title: Building Construction and Installation of Oxygen Injection System

Work site location: Coldbrook, NS

ADDENDUM: No. 1

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

Department of Fisheries and Oceans

Bid Closing Date: Tuesday, September 13, 2016
Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)
RFP File No: FP802-160153

QUESTIONS and ANSWERS

Q1. Will temporary 3-phase power be available on-site during construction?

A1. No. Only single-phase power will be available to the contractor during construction. There are outlets available in the small shed adjacent to the new building and in the Hubley Building (large green structure housing ponds).

Q2. Do you have a contact person for the supply of the PurGro 2 equipment?

A2. John H. Archibald
President, inVentures Technologies Inc.
john.archibald@inventures.ca
T.647.988.1543
www.inventures.ca



Q3. Is there a Geotech report which can be provided?

A3. No geotech reports are available.

Q4. Is there a civil plan depicting site elevations which can be provided? Grading details?

A4. There are no civil plans depicting elevations and grading details.

Q5. Please provide description of interior wall assembly.

A5. Interior wall assembly to meet all Code requirements and enable required ventilation. Please provide recommended wall assembly in your proposal.

Q6. Drawing AP-2 details 4 pieces of equipment we are to re-use (supplied by DFO) and we were shown the equipment at the site visit. Are there other items we should be allowed to re-use, such as exhaust hoods from the previous location which we were not shown at the site visit?

A6. There are no additional items available for reuse.

DFO would like to clarify that the parking area adjacent to the site (new building) is to be returned to its original, level, gravelled condition.

All other Terms and Conditions for this requirement remain unchanged.



Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.

Regards

Bozenna Kazmierczak
Senior Contracting Officer
Telephone: (613) 993-8935
Email: Bozenna.Kazmierczak@dfo-mpo.gc.ca

RECEIPT ACKNOWLEDGED

Name of Company _____

Signature _____