

ATT. 23

Q1. The specification (under section 03 30-00-2.1) call for a concrete exposure class of C-1 with a minimum strength of 35MPa at 28 days. The drawings (MA-00) however calls for the same compressive strength requirement but at an exposure class of C XL. This exposure class corresponds with a compressive strength requirement of 50MPa per CSA A 23.1. Please confirm that the specifications govern, and the exposure class is C-

R1. Please disregard note on MA-00. Refer to Specification Section 03 30 00 Part 2.1