



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works & Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
1713 Bedford Row  
Halifax, N.S./Halifax,(N.E.)  
B3J 1T3  
Halifax  
Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.E.)  
B3J 3C9  
Halifax  
Nova Scot

<b>Title - Sujet</b> Indian Falls Fishway Reconstruction	
<b>Solicitation No. - N° de l'invitation</b> EB144-171368/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> EB144-17-1368	<b>Date</b> 2016-09-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWA-310-5449	
<b>File No. - N° de dossier</b> PWA-6-76065 (310)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2016-09-22</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Stevenson, Jacquelyn	<b>Buyer Id - Id de l'acheteur</b> pwa310
<b>Telephone No. - N° de téléphone</b> (902) 403-3520 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Solicitation No. - N° de l'invitation**

EB144-171368/A

**Client Ref. No. - N° de réf. du client**

EB144-171368

**Amd. No. - N° de la modif.**

002

**File No. - N° du dossier**

PWA-5-76065

**Buyer ID - Id de l'acheteur**

PWA310

**CCC No./N° CCC - FMS No/ N° VME**

## Amendment 002

### Indian Falls Fishway Reconstruction

Amendment 002 is raised for the following:

- Delete** Bid And Acceptance Form – in its' entirety.
- Insert** Attached – Bid And Acceptance Form.
- Insert** Attached - APPENDIX 4 – COMBINED PRICE TABLE

**THIS AMENDMENT WILL ANSWER THE BELOW RECEIVED QUESTIONS. ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.**

**Q1: Do we have pre-arranged access to the Indian Falls Park from Lunenburg County, or is this something we have to make our own arrangements for?**

A1: Yes, DFO has prearranged staging area in park with municipality of Lunenburg

**Q2: There is not allot of information regarding the re-facing of the diversion wall, just want to clarify if the entire diversion wall is to be resurfaced. Again the spec references unit pricing for most of the concrete repairs.**

A1: The entire diversion wall is to be resurfaced in accordance with Drawing C-106, to be measured by the cubic meter (Unit Price Pay Item 4).

**Q3: For the design and installation of the coffer dams, do you know how deep the water is along the Fishway and at the outlet at high water season.**

A3: Considering the condition assessment was performed during the dry season and we did not perform a site survey, we do not have an estimate on water depth. DFO likely has the most experience to answer this question. Depth is unknown, and will vary with season and weather. Encourage contractors to visit site to be conversant with all site conditions

**Q4: Will the park be closed during construction, and will we have full access for laydown, cranes, .**

A4: Park will remain accessible to the public during construction.

**Q5: Drawings C-103, says remove existing grating in pool #1 and replace the floor with concrete, are you looking for a suspended slab to replace the grating, or remove the existing concrete floor and replace with new? And does the grating get re-installed.**

A5: The floor grating is to be removed and disposed of off-site. The hole is to be filled flush/level to the existing floor elevation using concrete (Same concrete specification to Pay Item 1 – Fishway Weirs / Baffles).

**Solicitation No. - N° de l'invitation**

EB144-171368/A

**Client Ref. No. - N° de réf. du client**

EB144-171368

**Amd. No. - N° de la modif.**

002

**File No. - N° du dossier**

PWA-5-76065

**Buyer ID - Id de l'acheteur**

PWA310

**CCC No./N° CCC - FMS No/ N° VME**

## **BA01 IDENTIFICATION**

### **INDIAN FALLS FISHWAY RECONSTRUCTION**

**FILE #:** EB144-171368

**PROJECT #:** R.03874.002

## **BA02 BUSINESS NAME AND ADDRESS OF BIDDER**

Name: \_\_\_\_\_

Address: \_\_\_\_\_

Telephone: \_\_\_\_\_ Fax: \_\_\_\_\_ PBN: \_\_\_\_\_

E-mail address: \_\_\_\_\_

Industrial Security Program Organisation Number (ISP ORG#) \_\_\_\_\_  
(when required)

## **BA03 THE OFFER**

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the **TOTAL BID AMOUNT INDICATED IN APPENDIX 4.**

## **BA04 BID VALIDITY PERIOD**

The bid shall not be withdrawn for a period of **(thirty) 30** days following the date of solicitation closing.

## **BA05 ACCEPTANCE AND CONTRACT**

Upon acceptance of the Contractor's offer by Canada, a binding Contract shall be formed between Canada and the Contractor. The documents forming the Contract shall be the contract documents identified in Contract Documents (CD).

## **BA06 CONSTRUCTION TIME**

The Contractor shall perform and complete the Work by March 31, 2018.

## **BA07 BID SECURITY**

The Bidder is enclosing bid security with its bid in accordance with GI08 - Bid Security Requirements of R2710T - General Instructions - Construction Services - Bid Security Requirements.

## **BA08 SIGNATURE**

\_\_\_\_\_  
Name and title of person authorized to sign on behalf of Bidder (Type or print)

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

**Solicitation No. - N° de l'invitation**  
 EB144-171368/A  
**Client Ref. No. - N° de réf. du client**  
 EB144-171368

**Amd. No. - N° de la modif.**  
 002  
**File No. - N° du dossier**  
 PWA-5-76065

**Buyer ID - Id de l'acheteur**  
 PWA310  
**CCC No./N° CCC - FMS No/ N° VME**

## APPENDIX 4 - COMBINED PRICE FORM

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

### LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table as described in Section 01 29 00 Project Particulars and Measurement.

<b>LUMP SUM AMOUNT (LSA)</b> Excluding applicable tax(s)	
---	--

### UNIT PRICE TABLE

The Unit Price Table designates the Work to which a Unit Price Arrangement applies.

- (a) The Price per Unit and the Estimated Total Price must be entered for each Item listed.
- (b) Work included in each item is as described in the referenced specification section and Section 01 29 00 Project Particulars and Measurement.
- (c) The Price per Unit shall not include any amounts for Work that is not included in that unit price Item.

Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measure	Estimated Quantity (EQ)	Price per Unit GST/HST extra (PU)	Estimated Total Price GST/HST extra (EQ x PU)
1	03 30 00	Fishway Weirs / Baffles	m <sup>3</sup>	25		
2	03 30 00	Fishway Exit Walls	m <sup>3</sup>	3.5		
3	03 30 00	Fishway Guide Walls	m <sup>3</sup>	60		
4	03 30 00	Diversion / Training Walls	m <sup>3</sup>	10		
5	05 50 00	HSS Crossbeams	m	50		
6	05 50 00	H.D Galv.Steel Vertical Slot Baffles	units	18		
7	05 50 00	Grating:				
7.1	05 50 00	Remove and Reinstall Grating	m <sup>2</sup>	130		
7.2	05 50 00	Supply and Install New Grating	m <sup>2</sup>	8		
<b>TOTAL EXTENDED AMOUNT (TEA)</b> Excluding applicable tax(s)						

<b>TOTAL BID AMOUNT (LSA +TEA)</b> Excluding applicable tax(s)	
---	--