

F.C. O'Neill, Scriven & Assoc's Limited  
Consulting Engineers  
3450 Commerce Street, Box 140  
Halifax, NS B3H 1A9  
Tel: (902) 454-8800  
Fax: (902) 454-8820  
www.onsa.ca



WILLIAM NYCUM & ASSOCIATES LIMITED  
5505 Young Street, Halifax, NS, Canada, B3K 1Z7  
E: 902.454.8817 F: 902.454.8820  
www.nycum.com



ALL DIMENSIONS SHOWN ON STRUCTURAL DRAWINGS ARE FOR REFERENCE PURPOSES ONLY. REFER TO ARCHITECTURAL DRAWINGS FOR DIMENSIONS.


**ELECTRICAL NOTES:**  
INDICATED BY THE ◊ SYMBOL ON THE DRAWINGS. (I.E. ◊ INDICATES NOTE 1)

NOTE 1: EXISTING PUMPS "ST-3" & "ST-5" CURRENTLY FED FROM EXISTING STRICKLAND BUILDING BASEMENT 120/208V ELECTRICAL PANELS SHALL BE RE-FED FROM THE NEW 120/208V EMERGENCY PANEL. EXTEND EXISTING CIRCUITRY TO NEW EMERGENCY PANEL. REDUNDANT CIRCUITRY TO BE REMOVED.

NOTE 2: EXISTING PUMP "ST-4" & CIRCULATING PUMP CURRENTLY FED FROM EXISTING STRICKLAND BUILDING BASEMENT 347/600V ELECTRICAL PANELS SHALL BE RE-FED FROM THE NEW 347/600V EMERGENCY PANEL. EXTEND EXISTING CIRCUITRY TO NEW EMERGENCY PANEL. REDUNDANT CIRCUITRY TO BE REMOVED.

NOTE 3: EXISTING BAS CONTROL PANEL ASSOCIATED WITH STRICKLAND BUILDING PUMPS "ST-3", "ST-4", "ST-5" & CIRCULATING PUMP SHALL BE RE-FED FROM A 1P-15A CIRCUIT IN EMERGENCY PANEL "1B01". EXACT LOCATION OF CONTROL PANEL TO BE VERIFIED ON SITE BY THE ELECTRICAL CONTRACTOR.

NOTE 4: PROVIDE HOUSEKEEPING PADS FOR ELECTRICAL EQUIPMENT.



**POWER - BASEMENT LEVEL**  
SCALE : 1:100  
0m 1m 2m 3m 4m 5m 6m 7m 8m 9m 10m



revision	note	date
4	ISSUED FOR TENDER	08/23/2016
3	RE-ISSUED FOR 100% REVIEW	07/18/2016
2	ISSUED FOR 100% REVIEW	06/15/2016
1	ISSUED FOR 70% REVIEW	04/08/2016

**BIO GENERATOR UPGRADES FOR CAMPUS HEATING SYSTEM**  
BEDFORD INSTITUTE OCEANOGRAPHY  
DARTMOUTH - NS

**STRICKLAND BUILDING BASEMENT LEVEL**

designed PM	concur
date JULY 2016	
drawn PM	designé
date JULY 2016	
approved HJB	approuvé
date JULY 2016	
Tender	Soumission
PWSC Project Manager Administrateur de projets TPSC	
project number	no. du projet
<b>R.080319.001</b>	
drawing no.	no. du dessin
<b>E-107</b>	