



## AMENDMENT #2 MODIFICATION #2

RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency  
National Contracting Services  
Bid Receiving Unit  
111, Water Street East  
Cornwall ON K6H 6S3

### Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

### Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

### Issuing Office - Bureau de distribution

Parks Canada Agency  
111, Water Street East  
Cornwall ON K6H 6S3

<b>Title-Sujet</b> Masonry Lock Wall Repointing and Restoration, Lock 30 Lovesick		
<b>Solicitation No. - No. de l'invitation</b> 5P300-16-5265/A		<b>Date:</b> September 15, 2016
<b>GETS Reference No. - No de reference de SEAG</b>		<b>Client Ref. No. - No. de réf du client.</b>
<b>Solicitation Closes:</b>		
<b>at - á</b> 02:00 PM	<b>on - le</b> September 22, 2016	<b>Time Zone - Fuseau horaire</b> EDT - HAE
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> X <b>Other-Autre:</b> <input type="checkbox"/>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b> Patrick Alguire – patrick.alguire@pc.gc.ca		
<b>Telephone No. - No de téléphone</b> (613) 938-5955		<b>Fax No. - No de FAX:</b> (877) 558-2349
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>		
See Herein – Voir en ceci		

### TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

<b>Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de téléphone:</b>	
<b>Facsimile No. - N° de télécopieur:</b>	
<b>Email - Courriel:</b>	
<b>Signature</b>	<b>Date</b>

**THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

**1. Revised Drawings**

See "DSP 5P300-16-5265A 2016-09-15.zip".

- a. Grid lines on drawing S2 have been revised to match the grid lines shown in elevation on drawing S3.
- b. Upstream wall height beyond the stop logs was added to drawing S03.

**2. Questions and Answers:**

Q1) Will there be access to a staging area at Lock 28?

A1) Yes, however, protective matting or minimum 100mm gravel on geotextile fabric, must be used on grass areas. This potential staging area is approximately 300 m2.

Q2) Is parking allowed at Lock 28?

A2) Yes, however this area is not maintained through winter.

Q3) Is there vehicle access to the site?

A3) No

Q4) Can the Lock station building be used by the contractor?

A4) No

Q5) Is the Fire Route [that leads to the walking path] plowed by the municipality?

A5) The road is plowed by the municipality up the Fire Road. The Fire Road is plowed by local residents.

Q6) Will the contractor be responsible for consultant transportation?

A6) No

Q7) Are both Lock projects [Lock 30 & 31] to be done at the same time?

A7) Yes

Q8) Will there be access to power on site?

A8) The contractor will be responsible for supplying power and water on site.

Q9) Can a notice be sent to the nearby property owners regarding potential property rental during construction?

A9) Parks Canada will not be distributing notices to nearby property owners.

Q10) Can the contractor break the ice to continue to access the site by water?

A10) Parks Canada does not provide approval for use of the waterways outside of navigation season. Schedule needs to be maintained regardless of winter weather related impacts.

Q11) Can a PCA barge be used for this work?

A11) No, but there may be two barges for sale on the government surplus site shortly.

Q12) Can the crane (currently on site) be used for construction?

A12) No, it will be removed from the site prior to construction

Q13) Can the footpath or hydrocut be used?

A13) It is a walking path only, as you need to cross two dams, with stairs, and that it takes approximately 20 minutes to walk. For the hydrocut there are sections of the cut with steep rock faces which require ladders to ascend.

Q14) What is the width of the lock?

A14) 9.7m

Q15) Must the Cofferdam contractor specialize in cofferdam construction?

A15) As per specifications (section 31 23 19 part 1.4.1.1)

Q16) What is the 911 address or the meter numbers at lock 30?

A16) Trent-Severn Waterway  
24 16th Concession, Lot 40  
Smith Twp, ON

Q17) On drawing 04/S04 is noted the water level 243.1m – please can you provide the bottom grade level?

A17) See “DSP 5P300-16-5265A 2016-09-15.zip”. Upstream wall height beyond the stop logs was added to drawing S03.

Q18) The gridlines 1-10 locations on drawing 1/S02 don't match with gridlines locations on drawings 01/S03 and 02/S03 – they are reversed?

A18) See “DSP 5P300-16-5265A 2016-09-15.zip”. Grid lines on drawing S2 have been revised to match the grid lines shown in elevation on drawing S3.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

**All other terms & conditions remain unchanged.**